

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: February 2022

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	OFF	0.03	0.03	0.03	0.03
2	OFF	0.03	OFF	OFF	0.03	0.03	0.03
3	OFF	0.03	OFF	OFF	OFF	0.03	0.03
4	0.03	0.03	OFF	OFF	0.03	OFF	0.03
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.03	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	0.03	OFF	OFF	0.03	0.03	0.03	0.03
10	0.03	OFF	OFF	0.03	0.03	0.03	0.03
11	0.03	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	OFF	OFF	OFF	0.03	0.03	0.03
13	OFF	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	OFF	OFF	OFF	0.02	0.03	0.03
15	0.03	OFF	OFF	OFF	OFF	OFF	0.03
16	0.03	0.03	OFF	OFF	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	0.03	OFF	OFF	0.03	0.03	0.03
19	OFF	OFF	OFF	OFF	0.03	0.03	0.03
20	0.03	OFF	OFF	OFF	0.03	0.03	0.03
21	0.03	OFF	OFF	0.03	OFF	OFF	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	0.03	0.03	OFF	OFF	OFF	OFF	0.03
24	0.03	0.03	0.03	OFF	OFF	OFF	0.03
25	0.03	0.03	OFF	OFF	0.03	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	OFF	OFF	0.03	0.03	0.03	0.03
28	0.03	OFF	OFF	0.03	0.03	0.03	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL ₂ residual at entry point ≥ 0.2 mg/l?	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:	Printed Name: Richard Mark Cage		
	Signature: <i>Richard Mark Cage</i>		3/1/2022
	Phone: 503-657-5030		CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: Feb-22

Required Log Inactivation: 1.0

Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1207	1.21	256.15	309.94	6.5	7.5	31	Y	7,784
2)	1754	1.37	234.34	321.04	7.0	7.6	37	Y	6,881
3)	1231	1.35	231.91	313.07	7.5	7.7	37	Y	6,742
4)	1028	1.17	239.55	280.28	6.5	7.9	36	Y	8,896
5)	1340	1.22	270.43	329.93	7.0	7.6	37	Y	7,923
6)	1210	1.22	290.40	354.29	7.0	8.2	45	Y	7,159
7)	1255	1.19	294.26	350.17	7.0	8.1	43	Y	7,437
8)	0909	1.28	263.37	337.12	8.0	8.1	45	Y	7,645
9)	1219	1.23	298.07	366.62	7.5	7.8	37	Y	7,228
10)	1404	1.30	248.75	323.37	7.0	8.2	45	Y	6,811
11)	1100	1.22	245.44	299.44	8.0	8.1	45	Y	6,533
12)	1330	1.12	283.49	317.51	8.0	8.4	43	Y	7,923
13)	1530	1.17	223.30	261.26	8.0	8.2	43	Y	6,533
14)	1640	1.26	261.57	329.57	8.0	7.9	37	Y	7,437
15)	1030	1.25	244.13	305.16	7.5	7.9	37	Y	6,742
16)	1325	1.52	237.24	360.60	8.0	7.8	38	Y	9,035
17)	1327	1.19	274.89	327.11	7.5	7.8	36	Y	7,576
18)	1305	1.31	321.53	421.20	8.0	7.9	37	Y	7,020
19)	1130	1.23	284.98	353.38	7.5	8.1	45	Y	7,437
20)	1445	1.20	292.92	351.51	8.0	8.4	45	Y	7,159
21)	1315	1.25	256.60	320.75	7.0	7.8	37	Y	7,645
22)	1818	1.26	228.07	287.36	7.0	8.0	37	Y	6,672
23)	1340	1.24	256.38	317.91	6.0	8.1	37	Y	7,437
24)	1247	1.24	230.84	286.24	6.0	7.9	37	Y	8,062
25)	1240	1.09	272.40	296.92	5.5	8.6	52	Y	7,993
26)	1200	1.21	273.33	330.73	5.5	8.4	45	Y	7,923
27)	1411	1.11	266.44	295.75	5.0	8.1	43	Y	8,132
28)	1455	1.07	290.92	311.29	7.0	8.0	43	Y	7,089