

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A Month/Year: March 2022

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	OFF	OFF	0.03	0.03
2	0.03	0.03	OFF	0.03	OFF	OFF	0.04
3	0.03	0.03	OFF	OFF	0.03	0.03	0.04
4	0.04	0.03	OFF	OFF	0.03	0.03	0.04
5	OFF	OFF	OFF	OFF	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.03	0.03	0.04
7	0.03	OFF	OFF	0.03	0.03	0.03	0.03
8	OFF	OFF	OFF	0.03	0.03	0.03	0.03
9	OFF	OFF	OFF	0.03	0.03	0.03	0.03
10	OFF	OFF	OFF	0.03	0.03	0.03	0.03
11	OFF	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	OFF	OFF	OFF	0.03	0.03	0.03
13	0.03	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	OFF	OFF	0.03	0.03	0.03	0.03
15	0.03	OFF	OFF	OFF	OFF	0.03	0.03
16	0.03	0.03	OFF	0.03	OFF	OFF	0.03
17	0.03	OFF	OFF	OFF	0.03	0.04	0.04
18	0.03	0.03	OFF	OFF	0.04	0.04	0.04
19	0.03	OFF	OFF	OFF	0.03	0.03	0.04
20	0.03	OFF	OFF	OFF	0.03	0.03	0.03
21	0.03	OFF	OFF	OFF	0.04	0.04	0.04
22	0.03	OFF	OFF	OFF	0.03	0.03	0.04
23	0.03	0.03	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	OFF	0.03	0.03
25	0.03	0.03	OFF	OFF	0.03	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	OFF	OFF	0.03
30	0.03	0.03	0.03	0.03	OFF	OFF	0.03
31	0.03	0.03	0.03	OFF	OFF	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No		
Notes:		Printed Name: Richard Mark Cage	
		Signature: <i>Richard Mark Cage</i>	4/5/2022
		Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Indiv. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A						Month/Year:	Mar-22	Required Log Inactivation:	1.0
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1310	1.21	255.63	309.32	6.5	7.6	37	Y	6,464
2)	1221	1.14	236.88	270.04	8.5	7.6	36	Y	6,742
3)	1400	1.19	244.29	290.70	8.5	7.8	36	Y	7,715
4)	1040	1.19	281.85	335.40	8.0	7.7	36	Y	7,645
5)	1345	1.11	235.82	261.76	8.5	7.5	30	Y	6,742
6)	1445	1.10	227.66	250.42	8.5	7.5	30	Y	8,479
7)	1730	1.23	249.88	307.36	9.0	7.6	37	Y	8,062
8)	1145	1.15	246.66	283.66	8.0	7.6	36	Y	6,672
9)	1304	1.36	237.38	322.83	8.0	7.6	37	Y	6,325
10)	1410	1.35	277.16	374.17	8.0	7.7	37	Y	6,186
11)	1050	1.30	258.80	336.44	9.0	7.8	37	Y	6,047
12)	1137	1.18	244.47	288.48	8.0	7.6	36	Y	6,394
13)	1240	1.18	222.02	261.98	8.0	7.8	36	Y	9,174
14)	1745	1.26	301.63	380.05	8.0	7.9	37	Y	7,020
15)	1215	1.22	282.00	344.04	8.0	7.7	37	Y	7,437
16)	1149	1.29	262.69	338.87	8.5	7.7	37	Y	7,784
17)	1106	1.23	316.10	388.81	8.5	7.6	37	Y	6,950
18)	1400	1.13	241.42	272.80	8.5	7.8	36	Y	6,672
19)	1330	1.13	273.26	308.79	9.0	7.7	36	Y	7,576
20)	1030	1.14	311.89	355.56	9.0	8.0	36	Y	7,089
21)	1530	1.29	311.14	401.37	8.5	7.7	37	Y	6,950
22)	1140	1.30	244.54	317.91	9.0	7.7	37	Y	6,394
23)	1228	1.17	293.80	343.74	9.0	7.7	36	Y	7,020
24)	1533	1.14	238.40	271.77	11.0	7.5	22	Y	7,993
25)	1040	1.10	282.35	310.58	10.0	7.9	27	Y	7,923
26)	0945	1.07	309.92	331.61	11.0	7.8	27	Y	7,089
27)	1325	1.16	270.19	313.42	11.0	7.8	27	Y	7,437
28)	1745	1.13	298.57	337.38	11.0	7.8	27	Y	7,089
29)	1415	1.23	306.18	376.60	10.5	7.9	28	Y	6,950
30)	1215	1.19	242.45	288.51	10.5	7.8	27	Y	6,394
31)	1150	1.17	285.94	334.55	10.5	7.6	27	Y	7,576