

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A Month/Year: April 2022

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.03
2	OFF	OFF	OFF	OFF	0.03	0.03	0.03
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	0.02	0.03	0.03
5	0.03	OFF	OFF	OFF	OFF	OFF	0.03
6	0.03	0.03	OFF	0.03	OFF	OFF	0.03
7	0.03	0.03	OFF	0.03	OFF	0.03	0.03
8	0.03	OFF	OFF	0.03	OFF	0.03	0.03
9	0.03	OFF	OFF	OFF	0.03	0.03	0.03
10	OFF	OFF	OFF	OFF	0.03	0.03	0.03
11	0.03	OFF	OFF	OFF	0.02	0.03	0.03
12	0.03	0.03	OFF	OFF	0.03	0.03	0.03
13	0.03	0.03	OFF	0.03	OFF	OFF	0.03
14	0.03	0.03	OFF	0.02	OFF	0.03	0.03
15	0.03	OFF	OFF	0.02	0.03	0.03	0.03
16	OFF	OFF	OFF	OFF	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	OFF	OFF	OFF	0.03	0.03	0.03
19	0.03	OFF	OFF	OFF	OFF	0.03	0.03
20	0.03	0.03	OFF	0.02	OFF	OFF	0.03
21	0.03	0.03	0.02	OFF	OFF	0.03	0.03
22	0.03	0.03	OFF	OFF	0.03	0.03	0.03
23	0.03	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.03	0.03	0.03
25	0.03	OFF	OFF	0.03	0.03	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	0.03	OFF	OFF	OFF	OFF	0.03
28	0.03	0.03	OFF	0.03	0.03	OFF	0.03
29	0.03	OFF	OFF	0.03	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:		Printed Name: Richard Mark Cage	
		Signature: <i>Richard M</i>	5/2/2022
		Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A							Month/Year: Apr-22	Required Log Inactivation: 1.0	
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1000	1.09	314.51	342.81	11.0	7.8	27	Y	7,020
2)	1125	1.20	246.57	295.88	11.0	7.9	28	Y	8,201
3)	0900	1.09	303.62	330.95	10.5	8.1	33	Y	7,020
4)	1200	1.14	301.33	343.52	10.0	8.1	33	Y	6,950
5)	1247	1.15	273.83	314.90	9.5	7.5	30	Y	7,437
6)	0848	1.20	253.23	303.88	10.0	7.7	28	Y	7,715
7)	1217	1.06	270.94	287.19	9.0	7.5	30	Y	7,854
8)	1045	1.00	265.35	265.35	9.5	7.5	30	Y	7,576
9)	1145	1.04	287.06	298.55	10.0	7.8	27	Y	7,784
10)	1340	1.10	282.02	310.22	9.0	7.9	36	Y	7,506
11)	1620	1.12	286.91	321.34	8.5	7.9	36	Y	7,298
12)	1520	1.09	290.97	317.16	8.0	7.5	30	Y	7,159
13)	1007	1.09	279.21	304.34	7.5	7.5	30	Y	7,715
14)	1128	1.05	237.19	249.05	8.0	7.5	30	Y	6,881
15)	1140	1.12	234.47	262.61	8.0	7.8	36	Y	6,811
16)	1150	1.15	296.95	341.49	9.0	8.0	36	Y	7,089
17)	1200	1.23	234.67	288.65	9.0	7.8	37	Y	8,271
18)	1740	1.10	233.21	256.53	9.0	7.5	30	Y	8,966
19)	1210	1.17	250.30	292.85	9.0	7.8	36	Y	6,116
20)	1245	1.04	279.06	290.22	8.5	7.5	30	Y	7,506
21)	0830	1.12	316.94	354.97	10.0	7.5	22	Y	6,950
22)	1020	1.15	270.05	310.56	9.0	7.6	36	Y	7,715
23)	1200	1.13	274.68	310.39	11.5	8.1	33	Y	7,576
24)	1145	1.25	227.27	284.09	12.0	8.0	28	Y	8,896
25)	1730	1.00	290.46	290.46	10.5	8.2	33	Y	7,089
26)	1345	1.08	266.62	287.95	11.5	7.9	27	Y	5,838
27)	1406	1.20	272.39	326.86	10.5	7.8	28	Y	7,298
28)	1317	1.17	279.22	326.69	10.0	7.6	27	Y	7,089
29)	1345	1.09	250.74	273.31	12.0	7.6	27	Y	7,923
30)	1215	1.23	250.15	307.68	10.5	8.1	33	Y	8,340