

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: May 2022

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.03
2	0.03	OFF	OFF	OFF	0.03	0.03	0.03
3	0.03	OFF	OFF	OFF	OFF	OFF	0.03
4	0.03	0.03	OFF	0.03	OFF	OFF	0.03
5	0.03	0.03	OFF	0.02	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.03	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	0.03	0.03	0.03	0.03
9	0.03	OFF	OFF	OFF	0.03	0.03	0.03
10	0.03	0.03	OFF	0.03	OFF	OFF	0.03
11	0.03	0.03	OFF	0.02	OFF	OFF	0.03
12	0.03	0.03	OFF	OFF	0.03	0.03	0.03
13	0.03	0.03	OFF	OFF	0.02	0.02	0.03
14	0.02	OFF	OFF	OFF	0.02	0.02	0.02
15	0.02	OFF	OFF	OFF	0.02	0.03	0.03
16	0.02	OFF	OFF	0.02	0.02	0.03	0.03
17	0.03	OFF	OFF	0.02	OFF	OFF	0.03
18	0.03	0.03	OFF	0.02	OFF	OFF	0.03
19	0.03	0.03	OFF	0.02	OFF	OFF	0.03
20	0.03	0.03	OFF	OFF	0.03	0.02	0.03
21	0.03	OFF	OFF	OFF	0.02	0.02	0.03
22	0.03	OFF	OFF	0.02	0.02	0.02	0.03
23	0.02	OFF	OFF	0.02	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.02	0.03	0.03
25	0.03	OFF	OFF	OFF	0.02	0.03	0.03
26	0.03	0.03	OFF	OFF	OFF	0.03	0.03
27	0.03	OFF	OFF	0.02	0.02	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	0.02	OFF	0.03	0.03
30	0.03	OFF	OFF	0.03	0.03	0.03	0.03
31	0.03	0.03	OFF	OFF	0.02	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes / No
All turbidity readings < IFE ² triggers?	Yes / No ²	Yes / No	Yes / No
Notes:	Printed Name: Richard Mark Cage		
	Signature: <i>Richard Mark Cage</i>		6/1/2022
	Phone: 503-657-5030		CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A							Month/Year:	May-22	Required Log Inactivation:	1.0
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow		
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]		
1)	1438	1.15	280.85	322.98	11.5	7.8	27	Y	7,576	
2)	1250	1.12	287.65	322.16	10.5	7.7	27	Y	7,159	
3)	1305	1.07	263.01	281.42	11.0	7.6	27	Y	7,784	
4)	1330	1.12	251.54	281.72	11.5	7.8	27	Y	7,715	
5)	1345	1.21	252.42	305.42	11.0	7.8	28	Y	7,645	
6)	1214	1.14	235.18	268.11	11.0	7.5	22	Y	6,811	
7)	1200	1.21	234.25	283.44	10.0	7.6	28	Y	6,742	
8)	0920	1.20	261.67	314.01	9.0	7.5	31	Y	7,506	
9)	1545	1.20	277.56	333.08	9.5	7.6	37	Y	7,298	
10)	1210	1.17	280.24	327.88	10.0	7.7	27	Y	7,645	
11)	1320	1.08	275.40	297.43	9.5	7.7	36	Y	7,645	
12)	1500	1.20	285.82	342.99	10.0	7.5	23	Y	7,645	
13)	1005	1.22	265.14	323.47	10.0	8.4	33	Y	7,367	
14)	1105	1.12	275.95	309.06	11.0	7.6	27	Y	7,159	
15)	1500	1.30	248.36	322.87	11.0	7.7	28	Y	8,062	
16)	1715	1.16	282.37	327.55	11.5	7.7	27	Y	7,159	
17)	0830	1.28	270.46	346.19	12.0	7.6	28	Y	7,645	
18)	1425	1.13	273.92	309.53	11.5	7.8	27	Y	7,506	
19)	1430	1.03	272.93	281.11	11.5	7.6	27	Y	7,715	
20)	0920	1.26	272.39	343.22	11.0	7.7	28	Y	7,645	
21)	1035	1.25	221.68	277.10	12.5	7.9	28	Y	8,757	
22)	1320	1.36	213.51	290.37	12.5	7.6	28	Y	9,244	
23)	0850	1.29	258.87	333.94	12.5	8.0	28	Y	8,132	
24)	1200	1.30	255.35	331.96	12.5	7.8	28	Y	8,618	
25)	1215	1.28	273.80	350.50	14.0	8.2	33	Y	7,437	
26)	1350	1.21	282.54	341.87	14.0	7.7	28	Y	7,367	
27)	1140	1.29	294.07	379.35	13.5	7.9	28	Y	7,159	
28)	1108	1.20	244.37	293.24	13.0	7.8	28	Y	8,757	
29)	1145	1.07	235.23	251.69	12.5	7.8	28	Y	8,549	
30)	1410	1.13	266.78	301.46	13.0	7.6	28	Y	7,923	
31)	1830	1.25	220.78	275.97	13.0	7.6	28	Y	9,383	