

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A **Month/Year: June 2022**

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	OFF	0.02	OFF	OFF	0.03
2	0.03	0.03	OFF	OFF	0.03	0.03	0.03
3	0.03	0.03	OFF	OFF	0.03	0.03	0.03
4	OFF	OFF	OFF	0.02	0.03	0.03	0.03
5	0.03	OFF	OFF	0.02	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.02	0.02	0.03
7	0.02	OFF	OFF	0.03	OFF	OFF	0.03
8	0.03	OFF	OFF	0.03	OFF	OFF	0.03
9	0.03	0.03	OFF	OFF	OFF	0.03	0.03
10	0.03	0.03	OFF	OFF	0.03	0.03	0.03
11	OFF	OFF	OFF	OFF	0.03	0.03	0.03
12	0.03	OFF	OFF	OFF	0.03	0.03	0.03
13	0.03	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	OFF	OFF	OFF	OFF	0.03	0.03
15	0.03	0.03	OFF	0.02	OFF	0.03	0.03
16	0.03	OFF	OFF	OFF	0.02	0.03	0.03
17	0.03	OFF	OFF	0.03	0.03	0.03	0.03
18	OFF	OFF	OFF	0.02	0.02	0.02	0.02
19	0.02	OFF	OFF	OFF	0.02	0.02	0.02
20	0.02	OFF	OFF	OFF	0.02	0.02	0.02
21	0.02	0.02	OFF	OFF	0.03	0.02	0.03
22	0.02	0.02	OFF	0.03	0.03	0.03	0.03
23	0.03	0.03	OFF	0.02	0.03	0.03	0.03
24	0.03	0.03	0.03	0.02	0.02	0.03	0.03
25	0.03	OFF	0.02	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.02	0.02	0.03	OFF	0.04
29	0.03	0.03	0.02	0.02	0.03	0.03	0.03
30	0.03	0.03	OFF	0.03	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	CT's met everyday? (see back)	All Cl_2 residual at entry point \geq 0.2 mg/l?
All the 4-hour turbidity readings \leq 1 NTU?	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No	<input checked="" type="radio"/> Yes / <input type="radio"/> No
All turbidity readings < IFE ² triggers?	<input checked="" type="radio"/> Yes / <input type="radio"/> No ²		
Notes:		Printed Name: Richard Mark Cage	
		Signature: <i>Richard Mark Cage</i> 7/5/2022	
		Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A						Month/Year:	Jun-22	Required Log Inactivation:	1.0
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1030	1.03	208.73	214.99	13.5	7.9	54	Y	9,800
2)	1130	1.18	228.65	269.81	12.0	7.5	22	Y	8,340
3)	0850	1.20	244.71	293.65	14.0	7.9	28	Y	8,688
4)	0910	1.03	226.65	233.45	14.0	7.7	27	Y	6,742
5)	0922	1.21	236.87	286.62	15.0	7.9	19	Y	8,757
6)	1310	1.31	209.91	274.98	14.5	7.7	55	Y	9,800
7)	0834	1.25	240.38	300.47	13.0	8.0	28	Y	6,811
8)	1007	1.12	256.96	287.79	14.0	7.8	27	Y	7,923
9)	1410	1.14	255.19	290.92	14.0	7.7	27	Y	7,923
10)	1150	1.14	282.65	322.22	14.0	7.7	27	Y	7,854
11)	1400	1.26	258.24	325.39	14.0	7.7	28	Y	8,062
12)	1500	1.07	256.17	274.10	13.0	7.8	27	Y	7,993
13)	1450	1.32	267.64	353.29	13.0	7.5	23	Y	7,437
14)	0905	1.20	213.78	256.54	11.5	8.0	28	Y	9,313
15)	1240	1.20	188.07	225.68	11.5	7.8	55	Y	11,190
16)	1505	1.20	236.87	284.24	13.5	7.8	28	Y	8,549
17)	1030	1.07	260.69	278.94	13.0	7.7	27	Y	8,410
18)	1410	1.22	264.31	322.46	13.5	7.5	23	Y	7,923
19)	1415	1.20	258.09	309.71	13.5	7.8	28	Y	7,923
20)	1620	1.29	294.13	379.42	15.0	7.6	19	Y	6,950
21)	1500	1.19	269.93	321.21	16.0	8.0	18	Y	7,645
22)	1345	1.08	268.96	290.47	14.0	7.8	27	Y	7,645
23)	1315	1.30	252.54	328.30	17.0	8.0	19	Y	8,062
24)	1415	1.39	239.70	333.19	16.0	7.5	15	Y	8,688
25)	0900	1.36	158.28	215.25	16.5	7.5	31	Y	12,510
26)	0520	1.40	187.94	263.11	16.5	7.5	31	Y	10,703
27)	0640	1.50	178.80	268.20	17.0	7.5	31	Y	11,051
28)	1350	1.36	174.49	237.31	17.0	7.6	37	Y	11,329
29)	1300	1.39	180.20	250.47	17.0	7.8	37	Y	10,703
30)	0930	1.27	162.86	206.83	21.5	7.9	28	Y	11,468