

OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: July 2022
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	0.03	0.02	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.02	0.03	0.03	0.03
3	0.03	OFF	0.03	0.02	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.02	0.02	0.03	0.03	0.03
6	0.03	OFF	0.03	0.02	0.03	0.03	0.03
7	OFF	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.03	0.03
9	0.03	0.03	0.03	0.03	0.03	0.03	0.03
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.05	0.03	0.03	0.05
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	OFF	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.03	0.03
30	0.03	0.03	0.03	0.03	0.03	0.03	0.03
31	0.03	0.03	0.03	0.03	0.03	0.03	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All the 4-hour turbidity readings ≤ 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE <sup>2</sup> triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No <sup>2</sup>	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
<b>Notes:</b>	Printed Name: Richard Mark Cage	
	Signature: <i>Richard Mark Cage</i>	8/1/2022
	Phone: 503-657-5030	CERT #: 2610

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year: Jul-22	Required Log Inactivation: 1.0		
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1250	1.30	200.27	260.35	17.5	7.5	31	Y	9,800
2)	0905	1.28	194.75	249.28	18.0	7.6	37	Y	10,286
3)	0655	1.36	190.43	258.98	17.5	7.5	31	Y	10,842
4)	0845	1.38	188.63	260.30	17.0	7.5	31	Y	10,425
5)	1110	1.40	180.03	252.05	17.0	7.5	31	Y	10,842
6)	1255	1.43	192.93	275.89	18.0	7.5	31	Y	10,217
7)	1400	1.36	221.59	301.36	18.0	7.5	31	Y	9,661
8)	0645	1.30	191.05	248.36	20.5	8.0	28	Y	10,703
9)	0820	1.30	198.03	257.44	18.0	7.7	37	Y	10,286
10)	0655	1.35	171.50	231.53	21.5	7.8	28	Y	12,093
11)	0830	1.38	157.72	217.65	18.5	7.6	37	Y	13,066
12)	1920	1.27	146.43	185.97	19.0	7.6	37	Y	12,997
13)	1200	1.20	153.97	184.76	20.0	7.8	28	Y	12,441
14)	1250	1.27	150.62	191.28	19.0	7.7	37	Y	13,414
15)	0827	1.47	161.67	237.65	19.5	7.5	31	Y	12,719
16)	1100	1.27	162.23	206.04	19.5	7.7	37	Y	12,649
17)	0625	1.31	161.32	211.33	20.0	7.6	28	Y	12,997
18)	1020	1.41	176.43	248.77	19.0	7.5	31	Y	11,815
19)	1330	1.22	146.43	178.65	19.0	7.6	37	Y	13,066
20)	1130	1.34	154.63	207.20	20.5	7.7	28	Y	13,205
21)	1300	1.34	142.41	190.83	23.5	7.6	28	Y	13,275
22)	1354	1.21	168.84	204.30	21.5	7.5	23	Y	12,232
23)	1130	1.42	162.12	230.21	20.0	7.5	23	Y	12,093
24)	0645	1.39	160.62	223.26	20.0	7.5	23	Y	13,275
25)	0940	1.27	136.41	173.25	20.5	7.5	23	Y	15,082
26)	1308	1.33	138.05	183.60	21.0	7.8	28	Y	14,317
27)	2345	1.37	132.40	181.39	23.0	7.8	28	Y	14,943
28)	1415	1.15	137.71	158.37	22.0	7.4	22	Y	14,456
29)	1115	1.31	159.41	208.83	26.0	7.5	15	Y	13,205
30)	1123	1.35	151.58	204.64	23.0	7.5	23	Y	13,900
31)	1030	1.40	163.79	229.31	22.0	7.5	23	Y	12,858