

**OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration**

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A Month/Year: March 2023

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.04	OFF	OFF	OFF	0.03	0.04
2	0.03	0.03	OFF	OFF	OFF	0.03	0.03
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	0.03	0.03	0.03
5	0.04	OFF	OFF	OFF	0.03	0.03	0.04
6	0.03	OFF	OFF	0.03	OFF	OFF	0.03
7	0.04	OFF	OFF	0.03	OFF	OFF	0.04
8	0.03	0.03	OFF	OFF	OFF	OFF	0.03
9	0.03	0.04	OFF	OFF	0.04	0.04	0.04
10	0.04	OFF	OFF	OFF	0.04	0.04	0.04
11	0.03	OFF	OFF	OFF	0.03	0.04	0.04
12	0.03	OFF	OFF	OFF	0.03	0.04	0.04
13	0.04	OFF	OFF	OFF	0.04	0.04	0.05
14	0.04	OFF	OFF	OFF	0.04	0.03	0.04
15	0.04	OFF	OFF	OFF	OFF	0.03	0.04
16	0.03	0.04	OFF	OFF	OFF	0.04	0.04
17	0.04	0.04	OFF	OFF	0.04	0.04	0.04
18	0.04	OFF	OFF	OFF	OFF	0.04	0.04
19	0.04	OFF	OFF	0.04	0.04	0.04	0.04
20	0.04	OFF	OFF	OFF	0.03	0.03	0.04
21	0.04	0.03	OFF	OFF	OFF	0.03	0.04
22	0.03	0.03	OFF	OFF	OFF	0.03	0.03
23	0.03	0.04	OFF	OFF	OFF	0.04	0.04
24	0.04	OFF	OFF	OFF	0.03	0.03	0.04
25	0.03	OFF	OFF	OFF	0.03	0.03	0.04
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	OFF	OFF	OFF	0.04	0.03	0.04
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.04	OFF	OFF	OFF	0.03	0.03	0.04
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
31	0.03	OFF	OFF	OFF	0.03	0.03	0.03

Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No				CT's met everyday? (see back) Yes / No		All CL ₂ residual at entry point ≥ 0.2 mg/l? Yes/No	
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No							
All turbidity readings < IFE ² triggers? Yes / No²							
Notes:				Printed Name: Richard Cage			
				Signature:		4/3/2023	
				Phone: 503-657-5030		CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A						Month/Year:	Mar-23	Required Log Inactivation:	2.5
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1350	1.19	269.77	321.02	6.0	7.6	36	Y	7,506
2)	1345	1.24	251.69	312.09	5.5	7.8	37	Y	7,854
3)	1110	1.20	283.49	340.19	6.5	8.1	45	Y	7,923
4)	1120	1.36	279.53	380.17	6.5	7.8	37	Y	7,715
5)	0950	1.37	275.28	377.13	6.0	8.0	37	Y	7,993
6)	1410	1.15	269.95	310.44	6.0	7.5	36	Y	7,715
7)	1412	1.31	257.73	337.65	6.0	7.7	37	Y	8,618
8)	1140	1.24	283.25	351.23	6.0	7.6	37	Y	7,645
9)	1440	1.30	308.42	400.95	6.5	7.6	37	Y	7,020
10)	1253	1.16	272.50	316.10	7.0	7.7	36	Y	7,854
11)	1250	1.18	316.20	373.12	8.0	8.0	36	Y	7,089
12)	1145	1.26	282.35	355.76	7.0	7.7	37	Y	7,506
13)	1515	1.21	288.76	349.40	8.0	7.4	31	Y	7,228
14)	1130	1.10	290.34	319.37	7.0	7.5	30	Y	7,645
15)	1155	1.41	270.12	380.86	8.5	7.6	38	Y	7,923
16)	1530	1.04	298.24	310.17	7.5	7.4	36	Y	7,020
17)	1130	1.16	293.50	340.46	9.0	8.0	36	Y	7,159
18)	1425	1.14	233.28	265.94	10.0	7.7	27	Y	8,062
19)	0840	1.24	276.89	343.35	8.0	7.7	37	Y	7,854
20)	1240	1.03	291.97	300.73	9.0	7.5	36	Y	7,089
21)	1330	1.22	268.11	327.09	9.0	7.5	37	Y	7,854
22)	1222	1.35	263.46	355.67	9.5	7.6	37	Y	7,993
23)	1455	1.39	264.90	368.21	8.0	7.9	37	Y	7,993
24)	1130	1.14	250.29	285.33	8.0	7.7	36	Y	8,688
25)	1215	1.22	271.49	331.21	8.5	7.9	37	Y	8,062
26)	1010	1.30	259.49	337.33	8.5	7.5	31	Y	8,201
27)	1510	1.27	229.25	291.15	8.5	8.0	37	Y	6,881
28)	1520	1.28	263.11	336.78	8.0	7.5	31	Y	7,784
29)	1140	1.19	269.37	320.55	8.5	7.5	30	Y	7,854
30)	1120	1.24	281.74	349.36	8.5	7.8	37	Y	7,645
31)	1128	1.19	306.43	364.65	8.0	7.8	36	Y	7,020