

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: April 2023
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	OFF	0.03	0.04	0.04
2	0.03	OFF	OFF	OFF	0.04	0.03	0.04
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	OFF	0.03	0.04
5	0.03	OFF	OFF	OFF	OFF	0.03	0.04
6	0.03	0.03	OFF	OFF	OFF	0.04	0.04
7	0.04	0.03	OFF	OFF	0.03	0.03	0.04
8	0.03	OFF	OFF	OFF	0.03	0.03	0.04
9	0.03	OFF	OFF	OFF	0.03	0.03	0.03
10	0.04	OFF	OFF	OFF	OFF	0.03	0.04
11	0.03	0.04	OFF	OFF	OFF	0.04	0.04
12	0.04	0.04	OFF	OFF	OFF	0.04	0.04
13	0.04	OFF	OFF	OFF	0.03	0.03	0.04
14	0.03	OFF	OFF	OFF	0.03	0.03	0.03
15	0.03	OFF	OFF	OFF	0.03	0.03	0.03
16	0.03	OFF	OFF	OFF	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	0.03	OFF	OFF	OFF	0.03	0.03
19	0.03	0.03	OFF	OFF	OFF	0.03	0.03
20	0.03	0.03	OFF	OFF	OFF	0.03	0.03
21	0.03	OFF	OFF	OFF	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	OFF	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	OFF	0.03	0.03
25	0.03	0.03	OFF	OFF	OFF	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	0.03	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	0.03	0.03	0.03	0.03
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All the 4-hour turbidity readings \leq 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No All turbidity readings < IFE ² triggers? <input checked="" type="radio"/> Yes / <input type="radio"/> No ²	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All CL ₂ residual at entry point \geq 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
Notes:	Printed Name: Richard Cage	
	Signature: <i>Richard Cage</i> 5/1/2023	
	Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A				Month/Year: Apr-23		Required Log Inactivation: 2.5			
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1020	1.10	307.03	337.73	8.0	7.7	36	Y	7,089
2)	1500	1.25	266.97	333.71	8.0	7.9	37	Y	7,715
3)	1310	1.04	235.32	244.80	8.5	7.5	30	Y	6,811
4)	1345	1.27	262.65	333.56	9.0	7.6	37	Y	7,993
5)	1700	1.39	279.44	388.42	7.5	7.7	37	Y	7,576
6)	1255	1.37	286.92	393.08	8.0	7.4	31	Y	7,576
7)	1210	1.36	254.53	346.16	8.5	7.8	37	Y	8,271
8)	1025	1.27	265.68	337.42	9.0	7.9	37	Y	8,062
9)	1215	1.36	283.10	385.02	9.0	7.9	37	Y	7,437
10)	1815	1.04	279.44	290.62	9.0	7.6	36	Y	7,576
11)	1745	1.17	282.91	331.00	8.5	7.4	30	Y	7,576
12)	1750	1.26	299.45	377.30	8.5	7.5	37	Y	7,437
13)	1200	1.38	247.60	341.69	8.0	7.5	37	Y	6,672
14)	1330	1.26	257.50	324.45	9.0	7.6	37	Y	7,715
15)	1420	1.20	248.89	298.67	9.5	7.8	37	Y	6,603
16)	1430	1.36	236.87	322.14	9.5	7.6	37	Y	8,827
17)	1830	1.24	231.24	286.74	9.5	7.6	37	Y	8,757
18)	1527	1.39	269.52	374.63	9.5	7.7	37	Y	7,715
19)	1120	1.35	234.09	316.02	8.5	7.6	37	Y	8,618
20)	1230	1.29	294.78	380.26	8.5	7.6	37	Y	7,228
21)	1100	1.30	297.98	387.37	8.5	7.7	37	Y	7,576
22)	1120	1.34	272.82	365.58	10.5	7.9	28	Y	7,715
23)	1320	1.29	263.30	339.66	9.5	7.7	37	Y	7,854
24)	1220	1.24	254.63	315.74	11.0	7.9	28	Y	8,132
25)	1500	1.40	290.75	407.05	11.5	7.6	28	Y	7,159
26)	1515	1.27	288.78	366.75	10.0	7.6	28	Y	7,367
27)	1530	1.27	313.51	398.16	11.5	7.9	28	Y	7,089
28)	1445	1.10	176.31	193.94	11.0	7.7	27	Y	11,746
29)	1045	1.17	275.35	322.16	12.5	8.2	33	Y	7,506
30)	1530	1.10	275.22	302.74	11.0	8.2	33	Y	8,062
31)									