

OHA- Drinking Water Program- Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A							Month/Year: June 2023
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.03	0.03	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	0.03	0.03	0.03	0.04	0.04
9	0.04	0.03	0.03	0.03	0.03	0.03	0.04
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.03	0.03	0.03	0.03	0.03	0.03
12	0.03	0.03	0.03	0.03	0.03	0.03	0.03
13	0.03	0.03	0.03	0.03	0.03	0.03	0.03
14	0.03	0.03	0.03	0.03	0.03	0.03	0.03
15	0.03	0.03	0.03	0.03	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	0.03	0.03	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	0.03	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	0.03	0.03
20	0.03	0.03	0.03	0.03	0.03	OFF	0.03
21	0.03	0.03	0.03	0.03	0.03	0.03	0.03
22	0.03	0.03	0.03	0.03	0.03	0.03	0.03
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	0.03	0.03	0.03	0.03	0.03
25	0.03	0.04	0.03	0.03	0.03	0.03	0.04
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.03	0.03	0.03	0.03
28	0.03	0.03	0.03	0.03	0.03	0.03	0.03
29	0.03	0.03	0.03	0.03	0.03	0.04	0.04
30	0.03	0.03	0.03	0.03	0.03	0.04	0.04
31							

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes/No	CT's met everyday? (see back) Yes/No	All CL ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
All the 4-hour turbidity readings ≤ 1 NTU? Yes/No		
All turbidity readings < IFE ² triggers? Yes/No		
Notes:	Printed Name: Richard Cage	
	Signature: <i>Richard Cage</i>	7/2/2023
	Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A						Month/Year: Jun-23	Required Log Inactivation: 2.5		
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1145	1.17	190.51	222.88	15.0	7.5	36	Y	10,217
2)	1220	1.38	169.46	233.85	18.5	7.9	37	Y	11,537
3)	0915	1.31	157.28	206.03	19.0	7.6	37	Y	12,371
4)	1415	1.23	182.57	224.56	19.0	7.8	37	Y	11,468
5)	1530	1.21	165.24	199.94	19.0	7.6	37	Y	12,024
6)	1430	1.28	153.32	196.25	18.0	7.5	37	Y	12,024
7)	1310	1.26	142.25	182.09	16.0	7.5	37	Y	13,066
8)	1230	1.19	177.07	210.71	18.5	7.6	36	Y	11,676
9)	1200	1.30	257.19	334.35	16.5	7.8	19	Y	8,479
10)	1700	1.36	182.87	248.70	17.0	7.6	37	Y	10,773
11)	0945	1.28	187.24	239.67	17.0	7.5	37	Y	10,356
12)	1530	1.28	143.71	183.94	17.5	7.5	37	Y	13,414
13)	1430	1.27	164.60	209.04	21.0	7.6	28	Y	11,398
14)	1200	1.09	186.28	203.05	17.0	7.6	36	Y	10,981
15)	0830	1.28	167.52	214.42	20.0	7.8	27	Y	11,537
16)	1215	1.36	165.03	224.44	20.0	7.7	27	Y	11,468
17)	1715	1.39	185.89	258.38	18.5	7.7	37	Y	10,634
18)	0845	1.27	228.83	290.74	19.0	7.5	19	Y	9,105
19)	1430	1.35	248.77	335.84	18.0	7.5	19	Y	8,757
20)	1630	1.38	230.40	317.95	16.5	7.6	19	Y	8,896
21)	1500	1.35	171.50	231.53	19.0	7.7	38	Y	11,120
22)	1330	1.36	202.70	275.68	18.5	7.7	38	Y	9,661
23)	1130	1.37	168.68	231.10	21.0	7.8	28	Y	12,024
24)	1030	1.40	167.65	234.71	16.5	7.5	30	Y	11,190
25)	1500	1.41	151.35	213.41	19.0	7.6	38	Y	13,066
26)	1500	1.13	158.88	179.54	19.5	7.5	30	Y	12,232
27)	1420	1.31	149.69	196.10	19.0	7.6	37	Y	13,692
28)	1400	1.33	175.00	232.75	22.5	7.7	28	Y	10,842
29)	1215	1.31	166.81	218.52	21.0	7.5	28	Y	11,746
30)	1245	1.27	148.02	187.99	20.0	7.6	28	Y	13,066
31)								Y	