

**OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration**

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: January 2024
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	OFF	0.03	OFF	0.03
2	0.03	..03	0.03	0.03	OFF	OFF	0.03
3	0.03	0.03	OFF	OFF	OFF	0.03	0.03
4	0.03	OFF	OFF	OFF	0.03	0.03	0.03
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	0.03	OFF	OFF	OFF	0.03	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	0.04	OFF	OFF	0.04
9	0.03	0.03	OFF	0.04	0.04	0.03	0.04
10	OFF	0.06	OFF	OFF	OFF	0.04	0.06
11	0.04	OFF	OFF	OFF	0.04	0.04	0.04
12	0.04	OFF	OFF	OFF	0.04	OFF	0.04
13	0.04	OFF	OFF	OFF	OFF	OFF	0.04
14	0.05	0.05	0.07	0.09	0.05	0.04	0.09
15	0.04	OFF	OFF	0.04	OFF	OFF	0.04
16	0.05	0.04	OFF	0.04	0.04	0.03	0.05
17	0.04	0.05	OFF	0.04	0.05	0.04	0.05
18	0.04	0.04	0.03	0.03	0.04	0.04	0.04
19	OFF	OFF	OFF	0.03	OFF	0.04	0.04
20	0.04	OFF	OFF	0.04	0.04	0.04	0.04
21	0.04	OFF	OFF	0.03	0.03	0.03	0.04
22	0.04	OFF	OFF	0.03	OFF	OFF	0.04
23	0.04	0.04	OFF	OFF	0.04	0.04	0.04
24	0.04	0.04	OFF	OFF	OFF	0.05	0.05
25	0.04	OFF	OFF	OFF	0.04	0.04	0.04
26	0.04	OFF	OFF	OFF	0.04	0.03	0.04
27	0.03	OFF	OFF	OFF	0.04	0.04	0.04
28	0.04	OFF	OFF	0.04	0.04	0.04	0.05
29	0.05	OFF	OFF	OFF	OFF	OFF	0.06
30	0.04	0.04	0.04	OFF	OFF	OFF	0.05
31	0.04	0.04	OFF	OFF	OFF	0.04	0.04

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No All the 4-hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²	CT's met everyday? (see back) Yes / No	All CL ₂ residual at entry point ≥ 0.2 mg/l? Yes/No
Notes: 	Printed Name: Richard Mark Cage Signature: <i>Richard Mark Cage</i> 2/1/2023 Phone: 503-657-5030 CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Jan-24	Required Log Inactivation:	2.5
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1500	1.09	268.90	293.10	9.0	7.6	36	Y	5,699
2)	1215	1.39	287.29	399.33	8.0	7.6	37	Y	7,159
3)	1505	1.37	246.20	337.29	8.5	7.5	31	Y	6,603
4)	1305	1.23	246.78	303.54	9.0	7.6	37	Y	8,688
5)	1150	1.20	254.62	305.54	8.5	7.8	37	Y	8,271
6)	1130	1.36	241.85	328.91	8.0	7.7	37	Y	6,603
7)	1430	1.35	256.77	346.64	8.0	7.6	37	Y	7,993
8)	1340	1.08	238.23	257.29	8.0	7.6	36	Y	6,881
9)	1520	1.10	235.58	259.14	8.5	7.6	36	Y	6,950
10)	1445	1.23	226.05	278.04	8.0	7.5	31	Y	8,966
11)	1520	1.12	225.33	252.39	7.5	7.7	36	Y	6,881
12)	1430	1.12	291.63	326.62	6.5	7.7	36	Y	7,298
13)	2355	1.23	256.79	315.85	6.5	7.7	37	Y	6,116
14)	1040	1.24	245.88	304.89	7.0	7.8	52	Y	7,993
15)	1600	1.19	204.06	242.83	3.0	7.8	51	Y	10,008
16)	1340	1.25	244.48	305.59	2.5	7.6	52	Y	8,618
17)	1320	1.46	272.94	398.49	3.5	7.6	54	Y	7,367
18)	1120	1.18	256.54	302.71	3.5	7.7	51	Y	8,132
19)	1530	1.34	255.23	342.01	7.0	7.5	31	Y	7,993
20)	1125	1.15	232.59	267.48	7.0	8.1	43	Y	8,479
21)	1300	1.23	246.10	302.70	7.0	7.8	37	Y	8,608
22)	1435	1.16	230.62	267.51	8.0	7.6	36	Y	8,688
23)	1530	1.17	284.65	333.03	9.0	7.5	30	Y	7,367
24)	1430	1.30	267.53	347.53	8.5	7.8	37	Y	6,116
25)	1350	1.23	249.10	306.39	9.0	7.8	37	Y	6,742
26)	1310	1.38	231.38	319.30	9.5	7.8	37	Y	8,410
27)	1120	1.14	266.86	304.22	9.5	8.1	43	Y	7,437
28)	1300	1.37	251.21	344.16	9.5	7.5	31	Y	6,603
29)	1603	1.03	229.95	236.85	9.5	7.8	36	Y	8,688
30)	0835	1.20	219.60	263.52	9.0	7.7	37	Y	8,618
31)	1213	1.30	244.12	317.36	9.0	7.6	37	Y	6,742