

OHA- Drinking Water Program- Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A							Month/Year: March 2024
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	0.05	0.05	0.05	0.05
2	0.05	OFF	OFF	0.05	0.04	0.04	0.05
3	0.04	OFF	OFF	0.04	0.04	0.05	0.05
4	0.04	0.04	OFF	OFF	OFF	OFF	0.05
5	0.04	0.04	OFF	OFF	0.05	0.04	0.05
6	0.04	0.05	OFF	0.04	0.04	0.05	0.05
7	0.04	0.05	OFF	OFF	OFF	0.04	0.05
8	0.03	OFF	OFF	OFF	0.04	0.04	0.04
9	0.04	OFF	OFF	0.03	0.04	0.03	0.04
10	0.04	OFF	OFF	0.04	0.04	0.04	0.04
11	0.04	OFF	OFF	0.04	OFF	OFF	0.04
12	0.04	OFF	OFF	OFF	OFF	0.05	0.05
13	0.04	0.04	OFF	OFF	OFF	0.04	0.05
14	0.05	OFF	OFF	0.05	0.05	0.05	0.05
15	0.04	OFF	OFF	OFF	0.04	0.04	0.04
16	0.04	OFF	OFF	0.04	0.04	0.04	0.04
17	0.04	OFF	OFF	OFF	0.04	0.04	0.04
18	0.04	OFF	OFF	0.04	OFF	OFF	0.04
19	0.03	OFF	OFF	OFF	0.04	0.03	0.04
20	0.03	0.03	OFF	0.04	0.03	0.03	0.04
21	0.04	0.04	0.04	0.03	0.03	0.03	0.04
22	0.03	0.03	0.03	0.03	0.03	0.03	0.04
23	0.03	0.03	0.03	0.03	0.03	0.03	0.03
24	0.03	0.03	OFF	0.03	0.03	0.03	0.03
25	0.03	0.03	0.03	0.03	0.03	0.03	0.03
26	0.03	0.03	0.03	0.03	0.02	0.02	0.03
27	0.02	0.03	0.03	0.02	0.02	0.02	0.03
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.03
30	0.03	0.03	0.02	0.02	0.02	0.03	0.03
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All CL ₂ residual at entry point \geq 0.2 mg/l?
All the 4-hour turbidity readings \leq 1 NTU?	Yes / No	Yes / No	Yes/No
All turbidity readings < IFE ² triggers?	Yes / No²		
Notes:	Printed Name: Richard Mark Cage		
	Signature: <i>Richard Mark Cage</i> 4/1/2023		
	Phone: 503-657-5030	CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Mar-24	Required Log Inactivation:	2.5
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1220	1.33	242.07	321.95	7.5	7.6	37	Y	6,533
2)	1235	1.20	276.58	331.89	7.5	8.0	37	Y	7,437
3)	1255	1.22	256.62	313.07	7.0	7.7	37	Y	6,325
4)	1405	1.31	262.18	343.45	7.0	7.6	37	Y	5,769
5)	1240	1.18	261.02	308.00	7.0	7.6	36	Y	5,769
6)	1243	1.03	272.03	280.19	7.5	7.8	36	Y	7,367
7)	1315	1.17	255.60	299.05	7.5	7.5	30	Y	7,923
8)	1532	1.40	259.19	232.86	8.5	8.0	38	Y	6,186
9)	1432	1.30	248.33	310.91	8.0	8.3	45	Y	7,715
10)	1320	1.23	262.74	323.17	8.0	7.8	37	Y	5,838
11)	1520	1.18	265.62	313.44	8.0	7.5	30	Y	7,437
12)	1230	1.10	256.28	281.90	8.5	7.6	36	Y	7,645
13)	1540	1.42	292.94	415.97	8.0	7.8	38	Y	6,950
14)	1005	1.50	294.71	442.06	7.5	7.7	38	Y	6,950
15)	1450	1.21	259.77	314.32	10.0	7.8	37	Y	6,255
16)	1410	1.34	281.19	376.79	10.5	7.8	37	Y	7,367
17)	1350	1.03	242.50	249.77	10.0	7.7	36	Y	8,137
18)	1350	1.07	260.78	279.04	10.0	7.6	36	Y	7,923
19)	1450	1.36	299.87	407.83	11.0	7.5	23	Y	7,020
20)	1425	1.35	228.69	308.73	10.0	7.8	28	Y	6,881
21)	1115	1.38	217.83	300.61	10.0	7.7	28	Y	9,661
22)	1055	1.33	248.67	330.73	9	7.5	31	Y	8,688
23)	1155	1.37	245.43	336.24	10.5	7.9	28	Y	8,132
24)	1115	1.5	220.03	330.05	9	7.6	76	Y	9,939
25)	1240	1.48	206.54	394.48	9	7.5	31	Y	8,132
26)	1510	1.25	190.34	237.93	10	7.7	55	Y	11,051
27)	1530	1.23	251.26	309.05	9	7.7	28	Y	7,854
28)	0850	1.32	239.34	315.92	9	7.7	28	Y	8,966
29)	1105	1.21	214.80	259.91	9	7.6	55	Y	10,078
30)	1115	1.34	260.19	348.66	8	7.5	23	Y	8,479
31)	1045	1.39	241.35	335.48	9.5	7.6	28	Y	8,966