


**OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration**

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A

Month/Year: December 2024

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	OFF	OFF	0.03	0.03	0.03	0.03
2	0.03	OFF	OFF	OFF	0.03	0.03	0.03
3	0.03	0.03	OFF	0.03	OFF	OFF	0.03
4	0.03	0.03	OFF	0.03	OFF	OFF	0.03
5	0.03	0.03	OFF	0.03	0.03	0.03	0.03
6	0.03	OFF	OFF	0.03	0.03	0.03	0.03
7	0.03	OFF	OFF	0.03	0.03	0.03	0.03
8	0.03	OFF	OFF	0.03	0.03	0.03	0.03
9	0.03	OFF	OFF	OFF	0.04	0.03	0.04
10	0.03	0.03	OFF	0.03	0.03	0.03	0.04
11	0.03	OFF	OFF	0.04	0.04	0.03	0.04
12	0.04	0.04	OFF	0.04	0.03	0.04	0.04
13	0.04	OFF	OFF	0.03	0.03	0.04	0.04
14	0.04	OFF	OFF	0.03	0.03	0.04	0.04
15	0.03	OFF	OFF	0.03	0.03	0.04	0.04
16	0.04	OFF	OFF	OFF	0.04	0.04	0.04
17	0.04	0.04	OFF	OFF	0.04	0.04	0.04
18	0.04	0.04	OFF	OFF	0.06	0.05	0.06
19	0.04	0.04	OFF	0.04	0.04	0.04	0.05
20	0.04	OFF	OFF	0.04	0.04	0.04	0.05
21	0.05	OFF	OFF	0.04	0.05	0.05	0.05
22	0.04	OFF	OFF	0.04	0.04	0.04	0.04
23	0.04	OFF	0.04	0.04	0.04	0.04	0.04
24	0.04	OFF	OFF	0.04	0.04	0.04	0.05
25	0.04	0.04	OFF	0.05	OFF	OFF	0.05
26	0.04	OFF	OFF	0.05	OFF	OFF	0.05
27	0.05	0.05	OFF	0.05	0.06	0.05	0.06
28	0.05	OFF	OFF	0.06	0.05	0.05	0.06
29	0.05	OFF	OFF	0.06	0.06	0.06	0.06
30	0.06	OFF	OFF	0.06	0.04	0.05	0.06
31	0.05	0.05	OFF	0.04	OFF	0.05	0.05

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All CL ₂ residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	Yes / No	Yes / No	Yes/No
All turbidity readings < IFE ² triggers?	Yes / No²		
Notes:	Printed Name: Richard Mark Cage		
	Signature: 		1/6/2024
	Phone: 503-657-5030	CERT #:	2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--WTP-A						Month/Year:	Dec-24	Required Log Inactivation:	2.5
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1415	1.17	288.08	349.93	7.5	7.8	36	Y	6,950
2)	1545	1.21	243.59	294.74	7.0	7.6	37	Y	6,603
3)	1253	1.17	290.79	340.22	7.0	7.7	36	Y	7,228
4)	1443	1.16	243.36	282.29	6.0	7.8	36	Y	6,672
5)	1300	1.22	272.07	331.92	6.5	7.7	37	Y	7,784
6)	1240	1.27	227.36	288.75	7.0	7.8	37	Y	6,811
7)	1130	1.16	269.33	312.42	7.0	7.8	36	Y	5,977
8)	1420	1.02	238.58	243.35	7.5	7.8	30	Y	6,742
9)	1545	1.26	24.37	282.71	8.0	7.7	37	Y	6,881
10)	1545	1.22	303.13	369.82	6.0	7.7	37	Y	5,282
11)	1530	1.14	236.82	269.97	8.0	7.7	36	Y	6,672
12)	1515	1.20	239.05	286.86	8.0	7.5	31	Y	6,672
13)	1223	1.28	256.98	328.93	7.5	7.6	37	Y	6,394
14)	1130	1.27	292.83	371.90	8.5	7.6	37	Y	7,228
15)	1339	1.46	268.02	391.31	8.0	7.8	38	Y	7,715
16)	1430	0.91	273.42	248.82	8.0	7.7	35	Y	7,020
17)	1410	1.21	285.77	345.79	8.5	7.5	31	Y	7,298
18)	1525	1.08	292.58	315.99	9.5	7.8	36	Y	6,950
19)	1415	1.13	283.72	320.60	12.0	7.7	27	Y	7,020
20)	1050	1.22	279.31	340.76	10.5	7.7	28	Y	7,228
21)	1140	1.27	274.02	348.01	9.5	7.9	37	Y	7,506
22)	1105	1.26	297.77	375.18	9.0	7.7	37	Y	7,020
23)	1230	1.21	274.92	332.65	9.0	7.7	37	Y	7,784
24)	1348	1.14	256.50	292.41	9.5	7.5	30	Y	8,062
25)	1305	1.26	304.52	383.69	9.0	7.7	37	Y	6,950
26)	1345	1.42	262.78	373.15	9.5	7.6	38	Y	7,784
27)	1125	1.22	262.19	319.87	11.0	7.5	23	Y	8,132
28)	1255	1.18	255.70	301.73	9.0	7.8	36	Y	6,533
29)	1530	1.22	289.23	352.86	10.0	8.3	33	Y	7,506
30)	1345	1.28	236.59	302.84	11.0	7.9	28	Y	6,742
31)	1530	1.26	263.22	331.65	9.0	7.6	37	Y	6,186