


OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP--:WTP-A Month/Year: January 2025

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.05	0.05	OFF	0.04	OFF	OFF	0.05
2	0.05	0.05	OFF	0.05	0.05	0.05	0.05
3	0.05	OFF	OFF	0.05	0.05	0.05	0.05
4	0.05	OFF	OFF	0.05	0.05	0.06	0.06
5	0.06	OFF	OFF	0.06	0.06	0.06	0.06
6	0.06	OFF	OFF	0.06	0.06	0.06	0.06
7	0.06	0.03	OFF	OFF	0.03	0.03	0.06
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	0.03	0.03	OFF	OFF	0.03	0.03	0.03
10	0.03	0.03	OFF	0.03	0.03	0.03	0.03
11	OFF	OFF	OFF	0.04	0.04	0.03	0.04
12	0.03	OFF	OFF	0.03	0.03	0.02	0.03
13	0.04	OFF	OFF	0.04	0.04	0.04	0.04
14	0.04	0.04	OFF	OFF	0.04	0.04	0.04
15	0.05	0.04	OFF	OFF	0.04	0.04	0.05
16	0.04	0.05	OFF	OFF	0.04	0.04	0.05
17	0.05	OFF	OFF	0.03	0.03	0.03	0.05
18	0.03	OFF	OFF	0.03	0.03	0.03	0.03
19	0.03	OFF	OFF	0.03	0.03	0.03	0.03
20	0.03	OFF	OFF	0.03	OFF	OFF	0.03
21	0.03	0.03	0.03	OFF	OFF	0.03	0.03
22	0.03	OFF	OFF	OFF	0.03	0.03	0.03
23	0.03	0.03	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	0.03	0.03	0.04	0.04
25	OFF	OFF	OFF	0.03	0.03	0.03	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	0.03	OFF	OFF	OFF	0.03	0.03
29	0.03	0.03	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
31	0.03	0.03	OFF	0.03	0.03	0.03	0.03

Conventional or Direct Filtration	Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>	CT's met everyday? (see back) <b>Yes / No</b>	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes/No</b>
All the 4-hour turbidity readings ≤ 1 NTU? <b>Yes / No</b>		
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes / No<sup>2</sup></b>		
<b>Notes:</b>	Printed Name: Richard Mark Cage	
	Signature: 	2/3/2025
	Phone: 503-657-5030	CERT #: 2610

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: <b>Jan-25</b>	Required Log Inactivation: <b>2.5</b>	
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1430	1.22	229.00	279.38	8.5	8.0	37	Y	8,271
2)	1255	1.25	242.57	303.22	8	7.9	37	Y	6,603
3)	1415	1.04	266.89	277.57	8.5	7.9	36	Y	6,255
4)	1255	1.39	291.52	405.21	8.5	7.9	37	Y	7,298
5)	1520	1.25	240.34	300.43	9	7.9	37	Y	6,672
6)	1640	1.21	294.23	356.02	9.5	7.7	37	Y	6,950
7)	1740	1.11	297.05	329.73	9.0	7.5	30	Y	7,089
8)	1249	1.24	251.11	311.38	8.5	7.5	31	Y	6,464
9)	1245	1.36	253.31	344.50	7.5	7.7	37	Y	8,132
10)	1300	1.28	264.89	339.06	8.0	8.2	45	Y	6,255
11)	1300	1.24	251.80	312.23	8.0	7.5	31	Y	6,255
12)	1500	1.21	239.12	289.34	8.5	7.9	37	Y	8,688
13)	1710	1.24	254.02	314.98	8	8	37	Y	7,645
14)	1305	1.17	238.04	278.51	7.5	8.3	43	Y	6,672
15)	1545	1.21	236.14	285.72	7.0	8.3	45	Y	6,464
16)	1520	1.31	236.36	309.58	7	7.7	37	Y	6,672
17)	1255	1.22	252.92	308.56	6.5	7.9	37	Y	6,533
18)	1335	1.34	301.51	404.02	6	7.5	31	Y	7,020
19)	1415	1.26	300.38	378.47	6	7.8	37	Y	7,159
20)	1538	1.16	214.85	249.23	6.0	7.7	72	Y	9,730
21)	1545	1.39	229.39	318.86	6.0	8.0	37	Y	8,271
22)	1410	1.11	266.48	295.79	5.5	7.7	36	Y	7,784
23)	1407	1.01	275.36	278.10	5.5	7.9	36	Y	7,784
24)	1155	1.19	202.73	241.25	5.0	7.8	72	Y	10,147
25)	1340	1.16	239.14	277.40	5.0	8.0	36	Y	6,881
26)	1500	1.27	252.06	320.12	4.5	7.8	52	Y	8,201
27)	1530	1.17	307.02	359.21	5.5	8.0	36	Y	7,089
28)	1540	1.22	230.84	281.63	5.5	7.7	37	Y	8,479
29)	1410	1.28	226.30	289.67	5.0	7.8	37	Y	9,174
30)	1425	1.44	287.43	413.90	5.0	7.8	38	Y	7,367
31)	1320	1.13	262.19	296.28	5.0	7.8	36	Y	8,132