

OHA- Drinking Water Program- Turbidity Monitoring Report Form  
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A					Month/Year: February 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.04
2	0.03	OFF	OFF	0.03	0.03	0.03	0.03
3	0.03	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	0.04	OFF	OFF	OFF	0.04	0.04
5	0.04	0.04	OFF	OFF	OFF	0.04	0.04
6	0.04	0.04	OFF	OFF	OFF	OFF	0.04
7	0.04	0.04	OFF	OFF	0.04	0.04	0.04
8	0.04	OFF	OFF	OFF	0.03	0.03	0.04
9	0.04	OFF	OFF	OFF	0.03	0.03	0.04
10	0.04	OFF	OFF	OFF	0.03	0.03	0.04
11	0.03	0.04	OFF	OFF	0.03	0.03	0.03
12	0.03	0.03	OFF	OFF	OFF	0.03	0.03
13	0.03	0.03	OFF	OFF	0.03	0.04	0.04
14	0.03	OFF	OFF	OFF	0.03	0.04	0.04
15	0.04	OFF	OFF	OFF	0.03	0.04	0.04
16	0.04	OFF	OFF	0.03	0.03	0.03	0.04
17	0.03	OFF	OFF	0.04	OFF	OFF	0.04
18	0.04	0.05	0.04	0.04	OFF	OFF	0.05
19	0.04	0.04	OFF	0.04	OFF	OFF	0.04
20	0.05	0.04	OFF	OFF	0.04	0.05	0.05
21	0.04	OFF	OFF	OFF	0.04	0.05	0.05
22	0.04	OFF	OFF	OFF	0.04	0.04	0.05
23	0.04	OFF	OFF	0.05	0.05	0.05	0.05
24	0.05	OFF	OFF	OFF	0.06	0.06	0.06
25	0.05	OFF	OFF	OFF	0.04	0.04	0.05
26	0.04	OFF	OFF	OFF	0.04	0.04	0.04
27	0.04	OFF	OFF	OFF	0.04	0.04	0.04
28	0.04	0.04	OFF	OFF	0.04	0.04	0.04
<b>Conventional or Direct Filtration</b>				<b>Monthly Summary (Answer Yes or No)</b>			
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>				CT's met everyday? (see back)		All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l?	
All the 4-hour turbidity readings ≤ 1 NTU? <b>Yes / No</b>				<b>Yes / No</b>		<b>Yes/No</b>	
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes / No</b> <sup>2</sup>				<b>Yes / No</b>		<b>Yes/No</b>	
<b>Notes:</b>				Printed Name: Richard Mark Cage			
				Signature: <i>Richard Mark Cage</i> 3/4/2025			
				Phone: 503-657-6030		CERT #: 2610	

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1205	1.16	247.43	287.02	6.0	7.9	36	Y	8,062
2)	1424	1.17	276.26	323.22	5.5	7.6	36	Y	7,854
3)	1532	1.08	248.08	267.93	6.0	7.7	36	Y	8,410
4)	1455	1.18	236.39	278.94	6.0	7.7	36	Y	6,672
5)	1355	1.29	293.65	378.81	5.5	7.8	37	Y	7,298
6)	1458	1.10	280.23	308.25	5.5	7.6	36	Y	7,854
7)	1125	1.21	247.16	299.06	6.0	7.6	37	Y	8,688
8)	1640	1.32	290.44	383.38	6.0	8.0	37	Y	7,367
9)	1505	1.17	277.30	324.45	6.5	7.9	36	Y	7,854
10)	1700	1.06	245.29	260.01	6.5	7.9	36	Y	8,271
11)	1650	1.09	257.96	281.17	5.0	7.7	36	Y	7,854
12)	1531	1.05	291.70	306.28	4.0	7.6	51	Y	7,228
13)	0858	1.12	280.92	314.63	4.0	8.1	61	Y	7,506
14)	1345	1.15	284.08	326.69	5.0	8.0	36	Y	7,089
15)	1050	1.22	246.59	300.84	5.0	7.9	37	Y	6,672
16)	1415	1.19	252.16	300.07	5.0	7.8	36	Y	7,715
17)	1312	0.91	294.88	268.34	6.0	7.6	35	Y	7,228
18)	1525	1.20	235.98	283.17	6.5	7.8	37	Y	6,533
19)	1352	1.22	239.33	291.99	7.0	7.7	37	Y	6,672
20)	1525	1.12	239.14	267.84	7.5	7.8	36	Y	8,618
21)	1425	1.10	267.06	293.73	8.0	8.0	36	Y	7,854
22)	1120	1.15	263.66	303.20	8.0	7.5	30	Y	7,715
23)	1100	1.15	236.11	271.52	9.5	7.7	36	Y	8,757
24)	1535	1.12	212.10	237.55	9.5	7.5	60	Y	10,008
25)	1530	1.09	272.91	297.47	8.5	7.9	36	Y	7,854
26)	1435	1.27	273.74	346.74	0.5	7.4	31	Y	7,715
27)	1540	1.13	249.16	281.55	9.0	7.8	36	Y	8,201
28)	1345	1.20	272.81	327.37	9.0	8.0	37	Y	7,784
							Y		
							Y		
							Y		