


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: March 2025
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	OFF	0.05	0.05	0.05
2	0.05	OFF	OFF	0.05	0.05	0.05	0.05
3	0.05	OFF	OFF	0.05	OFF	OFF	0.05
4	0.05	0.04	OFF	OFF	0.04	0.04	0.05
5	0.04	0.04	OFF	OFF	0.04	0.04	0.04
6	0.04	OFF	OFF	OFF	0.04	0.04	0.04
7	0.04	OFF	OFF	0.04	0.04	0.04	0.04
8	0.03	OFF	OFF	0.03	0.03	0.03	0.03
9	0.03	OFF	OFF	0.03	0.03	0.03	0.03
10	0.04	OFF	OFF	OFF	0.03	0.03	0.04
11	0.04	OFF	OFF	OFF	0.04	0.04	0.04
12	0.04	0.04	OFF	OFF	OFF	0.04	0.04
13	0.04	0.04	OFF	OFF	0.04	0.04	0.04
14	0.05	OFF	OFF	OFF	0.04	0.04	0.05
15	0.04	OFF	OFF	OFF	0.04	0.04	0.04
16	0.04	OFF	OFF	OFF	0.04	0.04	0.04
17	0.04	OFF	OFF	OFF	0.05	0.05	0.06
18	0.06	0.06	OFF	OFF	0.05	0.05	0.06
19	0.04	OFF	OFF	OFF	OFF	OFF	0.05
20	0.05	0.05	OFF	OFF	0.05	0.05	0.05
21	0.05	OFF	OFF	OFF	0.03	0.03	0.05
22	OFF	OFF	OFF	0.05	0.03	0.03	0.05
23	0.03	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	0.02	0.02	0.03
25	0.02	0.03	OFF	OFF	OFF	OFF	0.03
26	0.03	0.03	OFF	OFF	0.02	0.02	0.04
27	0.02	OFF	OFF	OFF	0.02	0.02	0.02
28	0.02	OFF	OFF	OFF	0.02	0.02	0.02
29	OFF	OFF	OFF	OFF	0.02	0.02	0.02
30	0.02	OFF	OFF	OFF	0.02	0.02	0.02
31	0.02	OFF	OFF	OFF	0.02	0.02	0.02

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU?	Yes / No	CT's met everyday? (see back)	All CL ₂ residual at entry point $\geq$ 0.2 mg/l?
All the 4-hour turbidity readings $\leq$ 1 NTU?	Yes / No		
All turbidity readings $<$ IFE ² triggers?	Yes / No²	Yes / No	Yes/No
Notes:		Printed Name: Richard Mark Cage	
		Signature:  4/2/2025	
		Phone: 503-657-6030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Mar-25	Required Log Inactivation:	2.5
Date/Time		Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	{GPM}
1)	1050	1.10	258.57	284.43	9.0	7.8	36	Y	8,201
2)	1330	1.20	204.14	244.97	6.0	7.5	61	Y	10,356
3)	1430	1.13	270.43	305.59	9.0	7.6	36	Y	7,576
4)	1534	1.08	250.61	270.65	9.0	7.8	36	Y	7,993
5)	1525	1.26	242.19	305.16	8.5	7.8	37	Y	8,132
6)	1525	1.15	262.42	301.79	10.5	7.9	27	Y	7,993
7)	1450	1.02	275.45	280.95	8.5	7.8	36	Y	7,228
8)	1025	1.30	240.60	312.78	10	8.1	33	Y	6,533
9)	1510	1.16	195.41	226.67	8.5	7.5	60	Y	10,425
10)	1640	1.21	252.99	306.12	9.0	7.6	37	Y	8,757
11)	1508	1.30	246.10	319.93	9.5	7.7	37	Y	8,340
12)	1445	1.35	244.38	329.92	9.5	8.1	45	Y	8,618
13)	1610	1.19	288.92	343.82	9.0	7.9	36	Y	7,298
14)	1430	1.05	242.35	254.47	9.0	7.9	36	Y	6,672
15)	1120	1.25	301.62	377.03	9.5	7.8	37	Y	7,020
16)	1430	1.17	193.02	225.84	8.5	7.9	72	Y	10,564
17)	1450	1.19	256.88	305.68	8.5	7.9	36	Y	7,576
18)	1630	1.20	265.28	318.33	8.5	7.6	37	Y	7,854
19)	1525	1.11	245.88	272.93	9.0	7.6	36	Y	8,827
20)	1405	1.31	270.33	354.13	8.5	7.9	37	Y	7,228
21)	1510	1.17	252.55	295.48	9.0	7.6	36	Y	7,784
22)	1040	1.11	263.55	292.51	9.0	7.6	36	Y	7,784
23)	1312	1.30	240.93	313.20	9.5	7.6	38	Y	9,105
24)	1645	1.15	192.00	220.80	11.0	7.6	27	Y	10,425
25)	1532	1.11	203.24	225.60	11.0	7.7	27	Y	10,008
26)	1605	1.21	243.99	295.23	11	7.8	28	Y	8,271
27)	1525	1.26	257.64	324.62	10.5	7.9	28	Y	7,854
28)	1134	1.02	281.55	287.18	10.5	7.9	27	Y	7,437
29)	1505	0.98	295.23	289.32	9.5	8	35	Y	7,298
30)	1452	1.17	284.54	332.91	9.0	7.9	36	Y	7,437
31)	1550	1.16	292.79	339.63	9.0	7.7	36	Y	7,367