

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A					Month/Year: April 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.02	OFF	OFF	OFF	OFF	OFF	0.02
2	0.02	0.02	OFF	OFF	OFF	OFF	0.02
3	0.02	0.02	OFF	OFF	0.02	0.02	0.02
4	0.02	OFF	OFF	OFF	0.02	0.02	0.02
5	0.02	OFF	OFF	OFF	0.02	0.02	0.02
6	0.02	OFF	OFF	OFF	0.02	0.02	0.02
7	0.02	OFF	OFF	OFF	0.02	0.02	0.02
8	0.02	OFF	OFF	OFF	0.02	0.02	0.03
9	0.03	OFF	OFF	OFF	0.03	0.03	0.03
10	0.03	OFF	OFF	OFF	0.03	0.03	0.03
11	0.03	OFF	OFF	0.03	0.03	0.03	0.03
12	0.03	OFF	OFF	0.03	0.03	0.03	0.03
13	0.03	OFF	OFF	0.03	0.03	0.03	0.03
14	0.03	OFF	OFF	0.03	0.03	0.03	0.03
15	0.03	0.03	OFF	OFF	OFF	0.03	0.03
16	0.03	0.03	OFF	OFF	0.03	0.03	0.04
17	0.03	OFF	OFF	OFF	0.04	0.03	0.04
18	0.03	0.04	OFF	OFF	0.04	0.04	0.04
19	0.04	OFF	OFF	OFF	0.04	0.04	0.04
20	0.04	OFF	OFF	0.04	0.04	0.04	0.04
21	0.04	OFF	OFF	OFF	0.05	0.03	0.05
22	0.03	0.03	OFF	OFF	0.04	0.03	0.04
23	0.03	0.04	OFF	OFF	0.04	0.03	0.04
24	0.04	0.04	OFF	OFF	0.04	0.04	0.04
25	0.04	OFF	OFF	0.05	0.05	0.04	0.05
26	0.03	OFF	OFF	0.04	0.03	0.03	0.04
27	0.04	OFF	OFF	OFF	0.03	0.03	0.04
28	0.03	OFF	OFF	0.05	0.05	0.03	0.05
29	0.03	0.03	OFF	OFF	0.03	OFF	0.06
30	0.03	0.03	OFF	OFF	0.04	0.03	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings $\leq$ 0.3 NTU? <u>Yes / No</u> All the 4-hour turbidity readings $\leq$ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u>	CT's met everyday? (see back) <u>Yes / No</u> All CL₂ residual at entry point $\geq$ 0.2 mg/l? <u>Yes/No</u>		
Notes:		Printed Name: Richard Mark Cage Signature: 5/1/2025 Phone: 503-657-5030 CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year: Apr-25	Required Log Inactivation: 2.5		
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1532	1.07	233.58	249.93	10	7.7	27	Y	9,244
2)	1500	1.15	277.30	318.90	9.5	7.6	36	Y	7,854
3)	1513	1.12	260.37	291.61	9.5	8.0	36	Y	7,923
4)	1550	1.12	244.85	274.23	9.5	7.9	36	Y	7,993
5)	1602	1.03	258.55	266.3	11.5	8.0	27	Y	7,715
6)	1528	1.26	249.39	314.23	10	7.9	28	Y	6,672
7)	1505	1.18	248.54	293.28	11	7.7	27	Y	7,784
8)	1505	1.21	204.94	247.98	10.5	7.6	55	Y	10,078
9)	1615	1.25	196.05	245.07	11.5	7.8	55	Y	10,217
10)	1330	1.14	250.14	285.16	11.0	7.8	27	Y	8,340
11)	1330	1.01	288.47	291.36	11.0	7.9	27	Y	7,298
12)	1345	1.07	284.78	304.71	9.5	7.6	36	Y	7,020
13)	1645	1.28	249.60	319.49	11.5	7.8	28	Y	6,672
14)	1515	1.20	179.98	215.97	11.5	7.6	28	Y	6,464
15)	1830	1.08	146.24	157.94	12.0	7.9	27	Y	7,854
16)	1515	1.18	163.12	192.48	12.5	7.8	27	Y	7,993
17)	1525	1.15	197.23	226.81	13.0	8.0	27	Y	6,186
18)	1400	1.21	142.38	172.28	12.0	7.6	28	Y	7,784
19)	1445	1.01	131.58	132.89	13.5	8.1	33	Y	8,479
20)	1500	1.08	132.98	143.62	12.0	7.6	27	Y	8,618
21)	1555	1.22	149.62	182.54	12.0	7.5	23	Y	7,923
22)	1745	1.10	135.36	148.90	13.0	7.6	27	Y	8,618
23)	1645	1.17	121.23	141.84	12.0	7.6	27	Y	8,966
24)	1440	1.34	154.56	207.11	14.5	8.0	28	Y	9,105
25)	1511	1.22	158.44	193.30	14.5	7.8	28	Y	8,757
26)	1430	1.08	136.22	147.11	14.0	8.0	27	Y	8,757
27)	1515	1.30	161.68	210.18	12.0	7.7	28	Y	7,993
28)	1600	1.10	174.02	191.43	12.5	7.7	27	Y	7,506
29)	1559	1.24	159.85	198.22	14.0	7.7	28	Y	7,437
30)	1530	1.31	143.96	188.59	14.5	7.6	28	Y	7,784