

**OHA- Drinking Water Program- Turbidity Monitoring Report Form**  
**Conventional or Direct Filtration**

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: May 2025
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	0.03	OFF	OFF	0.03	0.03	0.04
2	0.03	0.03	OFF	0.03	0.03	0.03	0.03
3	0.03	OFF	OFF	0.03	0.03	0.03	0.04
4	0.03	OFF	OFF	0.04	0.04	0.04	0.04
5	0.03	OFF	OFF	0.04	0.03	0.04	0.05
6	0.04	0.03	0.03	0.03	0.03	0.03	0.04
7	0.03	0.04	0.03	0.03	0.03	0.04	0.04
8	0.03	0.03	OFF	0.03	0.03	0.03	0.04
9	0.03	OFF	OFF	0.03	0.03	0.03	0.03
10	0.03	0.04	0.04	0.03	0.03	0.04	0.04
11	0.03	OFF	OFF	0.03	0.03	0.03	0.04
12	0.03	OFF	OFF	0.04	0.04	0.03	0.04
13	0.03	0.03	OFF	OFF	0.03	0.03	0.04
14	0.03	0.03	OFF	OFF	0.03	0.03	0.04
15	0.03	0.03	OFF	OFF	0.03	0.03	0.03
16	0.03	0.03	0.03	0.03	0.03	0.03	0.03
17	0.03	OFF	OFF	0.03	0.03	0.03	0.03
18	0.03	0.03	0.03	OFF	0.03	0.03	0.03
19	0.03	0.03	0.03	0.03	0.03	OFF	0.03
20	OFF	0.03	OFF	OFF	0.03	0.03	0.03
21	0.03	0.03	OFF	0.03	0.04	0.03	0.04
22	0.03	0.03	OFF	OFF	0.03	0.03	0.04
23	0.03	0.04	0.04	0.02	0.02	0.02	0.04
24	0.03	0.03	0.02	0.02	0.02	0.02	0.03
25	0.03	OFF	0.03	0.03	0.03	0.02	0.03
26	0.03	0.03	0.03	0.03	0.03	0.03	0.03
27	0.03	0.03	0.03	0.02	0.02	0.02	0.03
28	0.02	0.02	0.02	0.02	0.03	0.02	0.03
29	0.02	0.03	0.03	0.02	0.02	0.02	0.03
30	0.02	0.02	0.02	0.02	0.02	0.03	0.03
31	0.02	0.02	0.20	0.03	0.02	0.02	0.03
<b>Conventional or Direct Filtration</b>					<b>Monthly Summary (Answer Yes or No)</b>		
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <b>Yes / No</b>					CT's met everyday? (see back) <b>Yes / No</b>	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l? <b>Yes/No</b>	
All the 4-hour turbidity readings ≤ 1 NTU? <b>Yes / No</b>							
All turbidity readings < IFE <sup>2</sup> triggers? <b>Yes / No<sup>2</sup></b>							
<b>Notes:</b>					Printed Name: Richard Mark Cage		
					Signature: <i>Richard Mark Cage</i>		6/3/2025
					Phone: 503-657-5030		CERT #: 2610

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C ) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1410	1.18	161.02	190.01	14	7.8	28	Y	7,367
2)	1150	1.24	134.55	166.84	14	8.2	34	Y	7,993
3)	1400	1.04	120.54	125.36	12.5	7.6	55	Y	10,217
4)	1503	1.21	99.31	120.16	13	7.5	47	Y	11,954
5)	1510	1.21	158.63	191.94	12	7.6	28	Y	7,784
6)	1512	1.25	134.31	167.89	14	7.9	28	Y	8,062
7)	1552	1.18	151.96	179.32	16.0	7.8	19	Y	8,201
8)	1500	1.24	157.87	195.76	13.5	7.6	28	Y	8,201
9)	1315	1.17	155.93	182.43	15	7.5	15	Y	7,645
10)	1335	1.29	125.97	162.50	14.5	7.7	28	Y	9,105
11)	1520	1.20	145.10	174.12	15	7.7	19	Y	8,827
12)	1824	1.30	140.94	183.23	14.5	7.7	28	Y	9,105
13)	1545	1.21	177.65	214.96	14.5	7.6	28	Y	7,159
14)	1505	1.13	250.02	282.52	14.0	7.6	28	Y	7,784
15)	1535	1.33	304.52	405.01	14	7.5	23	Y	6,950
16)	1030	1.33	272.82	362.85	14	7.7	28	Y	7,715
17)	1255	1.24	240.82	298.61	13.5	7.8	28	Y	6,533
18)	1515	1.17	259.58	303.70	13.5	7.6	28	Y	8,201
19)	1500	1.27	304.32	386.48	12.5	7.6	28	Y	7,020
20)	1534	1.29	235.52	303.82	13.5	7.4	23	Y	6,811
21)	1815	1.08	207.32	263.30	16	8.2	22	Y	9,174
22)	1430	1.13	260.67	294.56	14	7.5	23	Y	7,993
23)	1255	1.32	236.67	312.40	12.5	7.5	23	Y	8,757
24)	1345	1.02	239.50	244.29	13	7.6	28	Y	8,688
25)	1045	1.30	242.45	315.19	14	7.6	28	Y	8,201
26)	1815	1.34	212.17	284.31	16.5	7.8	19	Y	9,244
27)	1250	1.16	236.68	274.55	17	7.7	19	Y	8,966
28)	1525	1.25	225.89	282.36	19	7.6	19	Y	8,618
29)	1510	1.43	229.93	328.80	18.5	7.5	16	Y	8,549
30)	1130	1.21	195.00	235.95	17	7.7	19	Y	9,591
31)	1055	1.29	196.11	252.99	16.5	7.4	15	Y	9,591