OHA- Drinking Water Program- Turbidity Monitoring Report Form **County: Clackamas**

Conventional or Direct Filtration

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A **Month/Year: July 2025**

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day [1] (NTU)
1	0.03	0.03	0.03	0.03	0.03	0.03	0.03
2	0.03	0.03	0.03	0.03	0.03	0.03	0.03
3	0.03	0.03	0.03	0.03	0.03	0.03	0.03
4	0.03	0.03	0.03	0.03	0.03	0.03	0.03
5	0.03	0.03	0.03	0.03	0.03	0.03	0.03
6	0.03	0.04	0.04	0.03	0.04	0.04	0.04
7	0.04	0.04	0.04	0.04	0.04	0.04	0.04
8	0.04	0.04	0.04	0.04	0.04	0.04	0.04
9	0.04	0.04	0.04	0.04	0.03	0.03	0.04
10	0.03	0.03	0.03	0.03	0.03	0.03	0.03
11	0.03	0.04	0.03	0.04	0.03	0.04	0.04
12	0.04	0.04	0.04	0.04	0.04	0.04	0.04
13	0.04	0.04	0.04	0.04	0.04	0.04	0.04
14	0.04	0.04	0.04	0.04	0.04	0.04	0.04
15	0.04	0.04	0.04	0.04	0.04	0.04	0.04
16	0.04	0.04	0.04	0.04	0.04	OFF	0.04
17	0.04	0.04	0.04	0.04	0.04	0.04	0.04
18	0.04	0.04	0.05	0.04	0.04	0.04	0.05
19	0.04	0.05	0.05	0.05	0.02	0.02	0.05
20	0.02	0.02	0.02	0.03	0.03	0.03	0.03
21	0.03	0.03	0.03	0.02	0.02	0.02	0.03
22	0.01	0.02	0.02	0.02	0.02	0.01	0.02
23	0.01	0.02	0.02	0.01	0.02	0.02	0.02
24	0.02	0.02	0.02	0.02	0.01	0.01	0.02
25	0.02	0.02	0.02	0.01	0.01	0.01	0.02
26	0.01	0.01	0.02	0.01	0.01	0.02	0.02
27	0.02	0.02	0.02	0.02	0.01	0.01	0.02
28	0.01	0.01	0.02	0.02	0.01	0.02	0.02
29	0.02	0.02	0.01	0.01	0.01	0.02	0.02
30	0.02	0.02	0.01	0.01	0.01	0.02	0.02
31	0.02	0.02	0.01	0.01	0.01	0.01	0.02

Conventional or Direct Filtration

95% of the 4-hour turbidity readings ≤ 0.3 NTU? **Yes / No**

All the 4-hour turbidity readings ≤ 1 NTU? **Yes / No**

All turbidity readings < IFE[2] triggers? **Yes / No[2]**

Monthly Summary (Answer Yes or No)

CT's met everyday? (see back) **Yes / No**

All Cl_2 residual at entry point ≥ 0.2 mg/l? **Yes/No**

Notes:

Printed Name: Richard Mark Cage

Signature: Richard Mark Cage 8/5/2025

Phone: 503-657-5030 CERT #: 2610

[1] Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM"

SOUTH FORK WATER BOARD ID#: OR4100591 WTP-:WTP-A					Month/Year:	Jul-25	Required Log Inactivation:	2.5	
	Date/Time	Minimum CL_2 Residual at 1st User (C)[3]	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? [3]	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	(GPM)
1)	1539	1.03	134.83	138.88	21.5	7.3	22	Y	14,734
2)	1337	1.27	132.99	168.90	22	7.5	23	Y	14,317
3)	0842	1.31	152.93	200.33	20.5	7.5	23	Y	12,649
4)	1350	1.24	165.67	205.43	20.5	7.8	28	Y	12,302
5)	1035	1.32	166.65	219.97	19.5	7.9	37	Y	11,885
6)	1520	1.30	160.59	208.76	23	7.7	28	Y	12,927
7)	1420	1.26	155.38	195.78	22	7.7	28	Y	12,232
8)	1505	1.28	135.99	174.06	22	7.5	23	Y	13,622
9)	1315	1.32	170.05	224.47	23	7.5	23	Y	11,746
10)	1125	1.18	145.88	172.14	24	7.5	22	Y	13,761
11)	1330	1.12	127.20	142.46	22	7.5	22	Y	15,012
12)	0855	1.26	159.97	201.56	25	7.6	18	Y	12,093
13)	1230	1.28	165.20	211.46	24.5	7.6	28	Y	11,815
14)	1145	1.22	141.22	172.29	24.0	7.6	7.8	Y	13,831
15)	1515	1.18	148.84	175.63	22.2	7.5	22	Y	13,761
16)	1445	1.10	153.68	169.05	23.5	7.4	22	Y	12,302
17)	1125	1.23	159.45	196.13	23.5	7.6	28	Y	12,768
18)	1050	1.10	159.93	175.93	24.5	7.7	27	Y	12,510
19)	1150	1.26	145.53	183.36	23.5	7.5	23	Y	12,719
20)	1120	1.23	150.61	185.24	23.0	7.6	28	Y	12,024
21)	1457	1.18	168.61	198.96	21.5	7.7	27	Y	11,476
22)	1331	1.22	161.48	197.01	22	7.8	28	Y	12,093
23)	1357	1.11	139.26	154.58	22.5	7.5	22	Y	13,761
24)	1305	1.15	156.95	180.50	23	7.5	22	Y	12,580
25)	1450	1.06	164.08	173.92	24.5	7.6	27	Y	12,580
26)	1215	1.17	152.44	178.36	22.0	7.6	27	Y	12,371
27)	1124	1.18	162.03	191.19	23.5	7.6	27	Y	12,580
28)	1520	1.21	140.18	169.62	22.0	7.6	28	Y	13,622
29)	1450	1.21	151.18	182.93	22.5	7.5	23	Y	12,163
30)	1510	1.02	153.66	156.74	23	7.5	22	Y	12,232
31)	1310	1.34	161.99	217.07	22	7.4	23	Y	12,232