

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A					Month/Year: August 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.02	0.02	0.02	0.02	0.02	0.01	0.02
2	0.02	0.02	0.02	0.02	0.01	0.01	0.02
3	0.02	0.02	0.02	0.02	0.02	0.02	0.02
4	0.01	0.02	0.02	0.02	0.01	0.02	0.02
5	0.02	0.02	OFF	0.02	0.01	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	0.02	0.02	0.02	0.02	0.02	0.01	0.02
8	0.02	0.02	0.02	0.02	0.02	0.02	0.02
9	0.02	0.02	0.02	0.02	0.02	0.02	0.02
10	0.02	0.02	0.02	0.02	0.02	0.02	0.02
11	0.02	0.02	0.02	0.02	0.02	OFF	0.02
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.02	0.02	0.02	0.02	0.02	0.02
14	0.02	0.02	0.02	0.02	0.02	0.02	0.02
15	0.02	0.02	0.02	0.02	0.02	0.02	0.02
16	0.02	0.02	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	0.02	0.02	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.02	0.02	0.02	0.02	0.02
22	0.02	0.02	0.02	0.02	0.02	OFF	0.02
23	0.02	0.02	0.02	0.02	0.02	0.02	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	0.02	0.02	0.02	OFF	0.02
26	0.02	0.02	0.02	0.02	0.02	0.02	0.02
27	0.02	0.02	0.02	0.02	0.02	0.02	0.02
28	0.02	0.02	0.02	0.02	0.02	0.02	0.02
29	0.02	0.02	0.02	0.02	0.02	0.02	0.02
30	0.02	0.02	0.02	0.02	0.02	0.02	0.02
31	0.02	0.02	0.02	0.02	0.02	0.02	0.02

Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No All the 4-hour turbidity readings ≤ 1 NTU? Yes / No All turbidity readings < IFE ² triggers? Yes / No ²				CT's met everyday? (see back) Yes / No All CL ₂ residual at entry point ≥ 0.2 mg/l? Yes/No	
Notes: 				Printed Name: Richard Mark Cage Signature:  9/2/2025 Phone: 503-657-5030 CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Indivd. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Aug-25	Required Log Inactivation:	2.5
Date/Time		Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	{GPM}
1)	1120	1.08	159.00	171.72	22.0	7.5	22	Y	12,163
2)	1320	1.10	136.69	150.36	22.0	7.7	27	Y	14,317
3)	1020	1.12	168.79	189.05	22.0	7.5	22	Y	11,676
4)	1130	1.27	155.25	197.17	21	7.6	28	Y	12,093
5)	2100	1.22	148.18	180.78	21.5	7.6	28	Y	12,927
6)	1215	1.24	153.06	189.79	22.5	7.5	23	Y	12,719
7)	1440	1.37	185.16	253.67	21.5	7.7	28	Y	10,147
8)	1015	1.23	147.01	180.82	20.5	7.7	28	Y	12,510
9)	1025	1.10	165.83	182.41	22.5	7.5	22	Y	12,232
10)	1255	1.11	153.04	169.87	22.5	7.8	27	Y	12,510
11)	1050	1.39	136.93	190.34	23	7.6	28	Y	13,622
12)	0845	1.05	153.72	161.41	23.0	7.5	22	Y	12,441
13)	1300	1.29	164.89	212.70	25.0	7.5	15	Y	12,580
14)	1150	1.30	171.62	223.10	23	7.6	28	Y	10,842
15)	1000	1.27	155.61	197.62	23.5	7.6	28	Y	12,232
16)	0930	1.36	157.82	214.64	22.0	7.5	23	Y	12,371
17)	1140	1.05	172.25	180.7	22.5	7.7	27	Y	11,607
18)	1110	1.24	157.78	196.89	22.0	7.6	28	Y	12,163
19)	1500	1.13	127.88	144.51	22.0	7.3	22	Y	14,943
20)	1457	1.31	143.03	187.37	22.5	7.6	28	Y	12,927
21)	1400	1.23	162.41	199.77	21.1	7.5	23	Y	12,024
22)	0920	1.19	132.54	157.73	23	7.8	27	Y	14,387
23)	1125	1.17	130.01	152.11	24	7.5	22	Y	14,943
24)	1040	1.28	157.86	202.06	23.5	7.5	23	Y	12,719
25)	1140	1.25	141.93	177.41	23	7.5	23	Y	13,761
26)	1330	1.13	153.45	173.40	22.5	7.5	22	Y	12,788
27)	1550	1.28	160.76	205.77	23.0	7.6	28	Y	11,676
28)	1142	1.26	149.17	187.95	22.5	7.4	23	Y	12,649
29)	1035	1.22	161.44	196.95	23	7.6	28	Y	12,232
30)	1050	1.25	163.06	203.83	22.0	7.6	28	Y	12,441
31)	1300	1.24	124.88	154.85	21.0	7.6	28	Y	15,151