


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A					Month/Year: September 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.02	0.02	0.02	0.02	0.02	0.02	0.02
2	0.02	0.02	0.02	0.02	0.02	0.02	0.02
3	0.02	0.02	0.02	OFF	0.02	0.02	0.02
4	0.02	0.02	0.02	0.02	0.02	0.02	0.02
5	0.02	0.02	0.02	0.02	0.02	0.02	0.02
6	0.02	0.02	0.02	0.02	0.02	0.02	0.02
7	OFF	0.02	0.02	0.02	0.02	0.02	0.02
8	0.02	OFF	0.02	0.02	0.02	0.02	0.02
9	0.02	OFF	0.02	0.02	0.02	0.02	0.02
10	0.02	OFF	0.02	0.02	0.02	0.03	0.03
11	0.02	0.02	0.02	0.02	0.02	0.02	0.02
12	0.02	0.02	0.02	0.02	0.02	0.02	0.02
13	0.02	0.03	0.02	0.02	0.02	0.02	0.03
14	0.02	0.02	0.02	0.02	0.02	0.02	0.03
15	0.02	0.02	0.03	0.02	0.02	0.02	0.03
16	0.02	OFF	0.02	0.02	0.02	0.02	0.02
17	0.02	0.02	0.02	0.02	0.02	0.02	0.02
18	0.02	0.02	OFF	0.02	0.02	0.02	0.02
19	0.02	0.02	0.02	0.02	0.02	0.02	0.02
20	0.02	0.02	0.02	0.02	0.02	0.02	0.02
21	0.02	0.02	0.03	0.02	0.02	0.02	0.03
22	0.02	0.02	0.02	0.02	0.02	0.02	0.02
23	0.02	0.02	0.02	0.02	0.02	OFF	0.02
24	0.02	0.02	0.02	0.02	0.02	0.02	0.02
25	0.02	0.02	OFF	0.03	0.02	0.02	0.03
26	0.02	0.02	0.02	0.03	0.03	0.03	0.04
27	0.03	0.03	0.03	0.03	0.04	0.04	0.04
28	0.03	0.04	0.04	0.04	0.04	0.03	0.04
29	0.03	0.04	0.04	0.04	0.04	0.03	0.04
30	0.03	0.03	OFF	0.04	0.04	0.03	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u> ²	CT's met everyday? (see back) <u>Yes / No</u> All CL ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes/No</u>		
Notes: 	Printed Name: Richard Mark Cage		
	Signature:  10/2/2025		
	Phone: 503-657-5030 CERT #: 2610		

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Sep-25	Required Log Inactivation:	2.5
Date/Time		Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp °	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]
1)	1630	1.24	138.84	172.16	22.0	7.7	28	Y	13,483
2)	1755	1.34	126.15	169.05	20.5	7.8	28	Y	14,943
3)	1450	1.26	127.34	160.45	23.0	7.6	28	Y	15,012
4)	1525	1.20	123.47	148.16	21.5	7.7	28	Y	14,943
5)	1150	1.27	137.27	174.33	23.5	7.6	28	Y	14,387
6)	1050	1.12	194.44	217.77	21.0	7.7	27	Y	10,912
7)	1245	1.25	180.57	225.72	21.0	7.8	28	Y	11,398
8)	1130	1.21	156.45	189.30	20.0	7.5	23	Y	12,302
9)	1530	1.27	199.80	253.75	21.0	7.4	23	Y	10,078
10)	0939	1.45	149.84	217.26	21.0	7.6	28	Y	12,510
11)	1235	1.19	246.36	293.17	20.5	7.7	14	Y	8,549
12)	1050	1.20	246.10	295.32	19.5	7.6	19	Y	8,618
13)	1050	1.07	167.45	179.17	20.5	7.9	27	Y	11,607
14)	1115	1.29	275.45	355.33	19.5	7.5	15	Y	7,506
15)	1701	1.29	212.25	273.80	18	7.5	15	Y	9,174
16)	1533	1.17	270.81	316.85	19	7.5	15	Y	7,854
17)	1400	1.23	209.61	257.82	20.0	7.4	23	Y	9,730
18)	1223	1.11	214.75	238.38	19.5	7.6	18	Y	9,174
19)	1050	1.34	209.84	281.19	18.5	7.5	31	Y	9,661
20)	1035	1.24	240.98	298.82	20.0	7.8	14	Y	8,966
21)	1120	1.28	263.66	337.48	18.5	7.5	15	Y	7,715
22)	1802	1.27	276.90	351.66	19.5	7.7	19	Y	7,645
23)	1440	1.42	165.52	235.04	18	7.5	31	Y	11,607
24)	1500	1.31	243.60	319.12	20.0	7.7	14	Y	8,896
25)	1430	1.17	157.27	184.00	18.5	7.7	18	Y	7,993
26)	1415	1.17	133.04	155.66	18.0	7.6	36	Y	9,800
27)	1155	1.14	127.42	145.25	17.0	7.7	18	Y	9,452
28)	1145	1.22	152.53	186.08	16.5	7.5	15	Y	7,923
29)	1100	1.23	145.95	179.52	17.5	7.6	19	Y	8,201
30)	1520	1.31	161.32	211.33	17	7.6	19	Y	7,298