


OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A					Month/Year: October 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	0.03	OFF	0.03	0.03	0.03	0.03
2	0.03	OFF	OFF	0.03	0.03	0.03	0.03
3	0.03	OFF	0.03	0.03	0.03	0.03	0.03
4	0.03	OFF	0.03	0.03	0.03	0.03	0.03
5	0.03	OFF	0.03	0.03	0.03	0.03	0.03
6	0.03	OFF	OFF	0.03	0.03	0.03	0.03
7	0.03	0.03	0.03	0.03	0.03	0.03	0.03
8	0.03	0.03	OFF	OFF	0.03	0.03	0.03
9	0.03	0.03	OFF	0.03	0.03	0.03	0.03
10	0.03	OFF	OFF	0.04	0.03	0.03	0.04
11	0.03	OFF	OFF	0.03	0.03	0.03	0.04
12	0.03	OFF	0.03	0.03	0.03	0.03	0.03
13	0.03	OFF	0.03	0.03	OFF	0.03	0.04
14	0.03	0.03	OFF	OFF	0.03	0.03	0.04
15	0.03	0.03	OFF	OFF	0.03	0.03	0.04
16	0.03	0.03	OFF	0.04	0.03	0.03	0.04
17	0.03	OFF	OFF	0.03	0.03	0.03	0.04
18	0.03	OFF	OFF	0.04	0.03	0.04	0.04
19	0.03	OFF	OFF	OFF	0.03	0.04	0.03
20	0.03	OFF	OFF	0.04	0.03	0.03	0.04
21	0.03	0.03	OFF	OFF	0.04	0.03	0.04
22	0.03	0.03	OFF	OFF	OFF	0.04	0.04
23	0.04	0.03	OFF	OFF	OFF	0.03	0.04
24	0.04	OFF	OFF	OFF	0.03	0.04	0.04
25	0.04	OFF	OFF	0.04	0.04	0.04	0.04
26	0.04	OFF	OFF	OFF	0.04	0.04	0.04
27	0.05	OFF	OFF	0.04	OFF	OFF	0.05
28	0.04	0.04	OFF	OFF	0.04	0.03	0.05
29	0.03	OFF	OFF	OFF	OFF	0.03	0.04
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03
31	0.03	OFF	OFF	OFF	0.03	0.03	0.03

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u> ²	CT's met everyday? (see back) <u>Yes / No</u> All CL ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes/No</u>		
Notes: 		Printed Name: Richard Mark Cage Signature:  11/3/2025 Phone: 503-657-5030 CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Oct-25	Required Log Inactivation:	2.5
Date/Time		Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]
1)	1545	1.10	171.03	188.14	16	7.5	15	Y	7,993
2)	1330	1.20	145.79	174.95	15.5	7.8	19	Y	8,132
3)	1300	1.20	172.30	206.76	15.5	7.5	15	Y	7,715
4)	1300	1.26	118.88	149.79	16	7.6	19	Y	6,672
5)	1140	1.19	173.80	206.82	15.5	7.5	15	Y	7,020
6)	1450	1.18	148.72	175.49	15	7.7	18	Y	8,479
7)	1625	1.28	195.26	249.93	16	7.5	15	Y	7,089
8)	1430	1.19	172.35	205.10	15.0	7.5	15	Y	7,298
9)	1500	1.23	178.34	219.36	14.5	7.5	23	Y	7,159
10)	1230	1.37	108.84	149.11	14.5	7.7	28	Y	6,742
11)	1219	1.37	130.02	178.13	14.5	7.5	23	Y	6,255
12)	1245	1.33	122.23	162.57	14.0	7.7	28	Y	6,603
13)	1511	1.29	122.89	158.53	14.5	7.6	28	Y	6,255
14)	1715	1.26	114.67	144.48	14.0	7.7	28	Y	6,742
15)	1326	1.18	165.94	195.81	14.0	7.6	27	Y	7,298
16)	1540	1.12	116.60	130.59	12.5	7.8	27	Y	6,881
17)	1345	1.31	128.59	168.45	14.0	8.2	33	Y	6,116
18)	1450	1.19	109.22	129.97	13.5	7.6	27	Y	6,881
19)	1430	1.21	137.81	166.75	13.5	7.5	23	Y	8,132
20)	1534	1.10	114.37	125.80	13.5	7.6	27	Y	6,881
21)	1520	1.22	154.20	188.12	13.5	7.8	28	Y	7,784
22)	1800	1.23	169.13	208.03	13.0	7.8	28	Y	7,437
23)	1440	1.20	169.17	203.00	13.0	7.6	28	Y	7,367
24)	1500	1.24	146.37	181.50	12.5	7.8	28	Y	8,340
25)	0920	1.25	152.28	190.35	12.5	7.5	23	Y	7,715
26)	1515	1.22	158.82	193.76	13.0	7.5	23	Y	8,132
27)	1540	1.26	193.60	243.94	12.0	7.8	28	Y	7,159
28)	1825	1.22	166.04	202.57	13.0	7.5	23	Y	7,437
29)	1828	1.14	172.63	196.79	13.0	7.5	22	Y	7,020
30)	1650	1.25	113.20	141.50	11.5	7.5	23	Y	6,672
31)	1515	1.11	143.12	158.86	11.5	7.5	22	Y	8,410