

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:WTP-A					Month/Year: November 2025		
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.00	OFF	OFF	OFF	0.03	0.03	0.03
2	OFF	OFF	OFF	OFF	0.03	0.03	0.04
3	0.03	OFF	OFF	0.03	OFF	OFF	0.03
4	0.03	0.03	OFF	OFF	OFF	OFF	0.03
5	0.03	0.03	OFF	OFF	OFF	0.03	0.03
6	0.03	0.03	OFF	OFF	OFF	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.04	0.04
9	0.03	OFF	OFF	OFF	0.03	0.04	0.04
10	0.04	OFF	OFF	OFF	OFF	0.04	0.04
11	0.04	0.04	OFF	0.04	OFF	OFF	0.04
12	0.04	0.03	OFF	OFF	OFF	0.03	0.04
13	0.03	0.03	OFF	OFF	0.03	0.02	0.03
14	0.03	OFF	OFF	OFF	0.02	0.02	0.03
15	0.03	OFF	OFF	OFF	0.02	0.02	0.03
16	OFF	OFF	OFF	OFF	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	0.03	0.03	0.03
18	0.03	0.03	OFF	OFF	OFF	0.03	0.03
19	0.03	0.03	OFF	OFF	OFF	0.03	0.03
20	0.03	0.03	OFF	OFF	0.03	0.02	0.03
21	0.02	OFF	OFF	OFF	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.02	0.03	0.03
23	0.03	OFF	OFF	OFF	0.03	0.03	0.03
24	0.03	OFF	OFF	OFF	OFF	0.03	0.03
25	0.03	0.03	OFF	OFF	OFF	0.03	0.03
26	0.03	OFF	OFF	0.03	OFF	OFF	0.03
27	0.03	0.03	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	OFF	OFF	OFF	OFF	0.03	0.03	0.03
30	0.03	OFF	OFF	OFF	0.03	0.03	0.03

Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU? <u>Yes / No</u> All the 4-hour turbidity readings ≤ 1 NTU? <u>Yes / No</u> All turbidity readings < IFE ² triggers? <u>Yes / No</u> ²		CT's met everyday? (see back) <u>Yes / No</u> All CL ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes/No</u>		Printed Name: Richard Mark Cage Signature:  12/3/2025 Phone: 503-657-5030 CERT #: 2610	
Notes:					

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A						Month/Year:	Nov-25	Required Log Inactivation:	2.5
Date/Time		Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
		ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM}
1)	1322	1.17	145.15	169.83	13.0	7.6	27	Y	8,688
2)	1430	1.13	129.56	146.40	12.0	7.6	27	Y	8,757
3)	1350	1.31	124.26	162.78	11.5	7.5	23	Y	6,672
4)	1533	1.08	155.44	167.88	12.8	7.7	27	Y	7,854
5)	1825	1.00	167.30	167.30	12.5	7.4	22	Y	7,228
6)	2105	1.13	179.04	202.32	12.0	8.2	33	Y	7,089
7)	0911	1.11	180.43	200.27	12.5	7.7	27	Y	7,367
8)	1500	1.23	170.77	210.04	12.0	7.5	23	Y	7,923
9)	1450	1.21	132.37	160.17	12.0	7.6	54	Y	10,147
10)	1830	1.07	187.29	200.40	11.5	7.5	22	Y	7,159
11)	1424	1.29	145.05	187.11	12.0	7.5	23	Y	8,201
12)	1650	1.17	159.33	18.42	12.5	7.5	22	Y	8,688
13)	0945	1.31	162.08	212.32	12.0	8.2	33	Y	8,201
14)	0930	1.23	178.26	219.26	12.0	7.6	28	Y	7,715
15)	1135	1.30	175.11	227.64	12.5	7.9	28	Y	7,854
16)	1450	1.18	181.80	214.53	12.5	7.7	27	Y	7,298
17)	1845	1.28	149.30	191.10	12.5	8.1	33	Y	8,271
18)	1405	1.33	178.50	237.40	11.5	7.5	23	Y	7,576
19)	2345	1.47	152.08	223.55	11.0	7.7	28	Y	8,271
20)	1120	1.46	146.61	214.06	11.5	7.8	28	Y	8,618
21)	1120	1.21	141.94	171.75	10.5	7.9	28	Y	8,618
22)	1125	1.29	164.86	212.67	10.0	7.9	28	Y	7,923
23)	1507	1.21	159.32	192.78	10.5	7.7	28	Y	8,132
24)	1430	1.15	180.52	207.59	10.5	7.8	27	Y	7,159
25)	1140	1.13	154.20	174.24	10.0	7.6	27	Y	7,784
26)	0925	1.20	156.88	188.26	10.5	8.3	33	Y	7,923
27)	1415	1.19	150.46	179.04	10.5	7.5	22	Y	8,201
28)	0945	1.19	181.99	216.57	11.0	7.5	22	Y	7,367
29)	1135	1.16	180.12	208.97	10.5	7.7	27	Y	7,298
30)	1438	1.14	157.91	180.01	10.5	7.7	27	Y	8,132
								Y	