

OHA- Drinking Water Program- Turbidity Monitoring Report Form  
 Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A Month/Year: December 2025

Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day <sup>1</sup> (NTU)
1	0.03	OFF	OFF	OFF	OFF	0.03	0.03
2	0.03	0.03	OFF	OFF	OFF	0.03	0.03
3	0.03	OFF	OFF	OFF	0.02	0.03	0.03
4	OFF	OFF	OFF	OFF	0.02	0.02	0.03
5	0.03	OFF	OFF	OFF	0.03	0.03	0.03
6	0.03	OFF	OFF	0.03	0.03	0.03	0.03
7	0.03	OFF	OFF	0.03	0.03	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	0.03	0.03	OFF	OFF	0.03	0.03	0.03
10	0.03	OFF	OFF	0.03	0.03	0.03	0.03
11	0.03	OFF	OFF	0.03	0.03	0.03	0.03
12	0.03	OFF	OFF	OFF	0.04	0.03	0.04
13	0.03	OFF	OFF	OFF	0.03	0.03	0.03
14	OFF	OFF	OFF	0.03	0.03	0.03	0.03
15	0.04	OFF	OFF	OFF	0.03	0.03	0.04
16	0.04	OFF	OFF	OFF	OFF	OFF	0.04
17	0.03	OFF	OFF	OFF	OFF	0.03	0.04
18	0.04	0.04	OFF	OFF	0.04	0.04	0.05
19	0.04	OFF	OFF	0.05	0.08	0.05	0.08
20	0.04	OFF	OFF	0.03	0.05	0.03	0.05
21	0.03	OFF	OFF	0.03	0.03	0.03	0.03
22	0.03	OFF	OFF	OFF	0.04	0.03	0.04
23	0.03	0.03	OFF	0.03	OFF	OFF	0.03
24	0.03	0.03	OFF	OFF	OFF	OFF	0.03
25	0.03	0.03	OFF	OFF	OFF	OFF	0.03
26	0.03	OFF	OFF	OFF	0.03	0.03	0.03
27	0.03	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.03	0.03	0.03
29	0.03	OFF	OFF	OFF	0.03	0.03	0.03
30	0.04	0.04	OFF	OFF	OFF	0.04	0.04
31	0.04	OFF	OFF	OFF	0.04	0.04	0.04

Conventional or Direct Filtration		Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings ≤ 0.3 NTU?	<b>Yes / No</b>	CT's met everyday? (see back)	All CL <sub>2</sub> residual at entry point ≥ 0.2 mg/l?
All the 4-hour turbidity readings ≤ 1 NTU?	<b>Yes / No</b>	<b>Yes / No</b>	<b>Yes/No</b>
All turbidity readings < IFE <sup>2</sup> triggers?	<b>Yes / No<sup>2</sup></b>		
<b>Notes:</b>		Printed Name: Richard Mark Cage	
		Signature: <i>Richard Mark Cage</i>	1/5/2026
		Phone: 503-657-5030	CERT #: 2610

<sup>1</sup> Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. <sup>2</sup> IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

**OHA-Drinking Water Program-Surface Water Quality Data Form**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: Dec-25	Required Log Inactivation: 2.5	
Date/Time	Minimum CL <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1813	1.24	153.37	190.18	10.0	7.7	28	Y	8,271
2)	1350	1.08	166.03	179.32	10.0	7.6	27	Y	7,506
3)	1435	1.18	163.48	192.91	10.0	7.8	28	Y	8,201
4)	1440	1.21	122.92	148.74	9.0	7.8	37	Y	6,811
5)	1110	1.23	154.86	190.47	10.5	8.0	28	Y	8,271
6)	0940	1.22	170.71	208.27	11.0	7.4	23	Y	7,854
7)	1452	1.15	176.57	203.05	11.0	7.8	27	Y	7,784
8)	1115	1.16	136.33	156.79	10.5	7.6	27	Y	5,769
9)	1725	1.26	165.60	208.66	13.0	7.6	28	Y	7,159
10)	1505	1.27	260.88	331.32	10.0	7.5	23	Y	7,854
11)	0945	1.16	271.94	315.45	13.0	7.9	27	Y	7,437
12)	1438	1.08	143.08	154.53	13	7.5	22	Y	7,993
13)	1140	.94	192.30	180.76	11.5	7.9	26	Y	7,506
14)	1419	1.37	181.24	248.30	11.0	7.7	28	Y	7,506
15)	1830	1.17	166.18	194.43	10.5	7.7	27	Y	8,271
16)	1450	1.16	169.25	196.33	12.0	8.0	27	Y	7,854
17)	1810	1.14	153.77	175.29	12.0	8.2	33	Y	8,271
18)	0950	1.38	251.74	347.41	11.5	8.0	28	Y	8,618
19)	1550	1.18	262.30	309.52	10.5	7.5	22	Y	7,576
20)	1220	1.10	264.87	291.35	11.0	7.5	22	Y	7,645
21)	1515	1.12	252.91	283.33	10.5	7.5	22	Y	7,576
22)	1645	1.18	263.57	311.01	11.0	7.9	27	Y	7,645
23)	1015	1.33	240.95	320.46	11.0	7.9	28	Y	8,410
24)	1430	1.21	234.81	284.13	10.0	7.5	23	Y	8,132
25)	1525	1.17	223.58	261.59	10.0	7.7	27	Y	8,479
26)	1120	1.32	220.59	291.18	10.0	7.8	28	Y	9,035
27)	1425	1.13	226.42	255.85	9.5	8.0	36	Y	8,966
28)	1430	1.05	274.94	288.69	9.0	7.9	36	Y	7,367
29)	1145	1.18	136.81	161.43	8.5	7.8	36	Y	8,966
30)	1735	1.26	127.89	161.14	8.5	7.8	37	Y	8,827
31)	1155	1.20	199.19	239.02	8.5	7.7	37	Y	7,020