

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: January 2026
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.04	OFF	OFF	OFF	OFF	OFF	0.04
2	0.04	OFF	OFF	OFF	0.04	0.05	0.05
3	0.04	OFF	OFF	OFF	0.04	0.04	0.04
4	0.02	OFF	OFF	OFF	0.02	0.02	0.03
5	0.03	OFF	OFF	OFF	OFF	0.02	0.04
6	0.03	OFF	OFF	OFF	0.03	0.03	0.03
7	0.03	OFF	OFF	OFF	0.03	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	0.02	OFF	OFF	OFF	0.03	0.03	0.03
10	OFF	OFF	OFF	OFF	0.02	0.02	0.03
11	0.03	OFF	OFF	OFF	0.02	0.02	0.03
12	0.03	OFF	OFF	OFF	OFF	0.03	0.03
13	0.03	0.02	OFF	OFF	OFF	0.02	0.03
14	0.02	OFF	OFF	OFF	OFF	0.02	0.04
15	0.02	OFF	OFF	OFF	0.02	0.02	0.02
16	0.02	OFF	OFF	OFF	0.02	0.02	0.02
17	0.02	OFF	OFF	OFF	0.02	0.02	0.03
18	0.02	OFF	OFF	OFF	0.02	0.02	0.02
19	0.02	OFF	OFF	0.02	OFF	OFF	0.02
20	0.02	0.03	OFF	OFF	OFF	0.02	0.03
21	0.02	0.03	OFF	OFF	OFF	0.02	0.03
22	0.02	OFF	OFF	OFF	OFF	0.02	0.03
23	0.02	0.02	OFF	OFF	0.02	0.02	0.02
24	0.02	OFF	OFF	OFF	0.02	0.02	0.03
25	OFF	OFF	OFF	OFF	0.03	0.03	0.03
26	0.02	OFF	OFF	OFF	0.02	0.03	0.03
27	0.02	0.02	OFF	OFF	OFF	0.03	0.03
28	0.03	0.03	OFF	OFF	OFF	0.03	0.03
29	0.03	0.03	OFF	OFF	OFF	0.02	0.03
30	0.03	0.03	OFF	OFF	0.02	0.02	0.03
31	OFF	OFF	OFF	0.03	0.03	0.03	0.03

Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)	
95% of the 4-hour turbidity readings \leq 0.3 NTU?	Yes / No	CT's met everyday? (see back)	Yes / No	All CL ₂ residual at entry point \geq 0.2 mg/l?	
All the 4-hour turbidity readings \leq 1 NTU?	Yes / No			Yes/No	
All turbidity readings < IFE ² triggers?	Yes / No				
Notes:				Printed Name: Richard Mark Cage	
				Signature: <i>Richard Mark Cage</i>	2/4/2026
				Phone: 503-657-5030	CERT #: 2610

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year:	Jan-26	Required Log Inactivation:	2.5
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow		
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]		
1)	1420	1.53	279.47	427.59	8.0	8.0	38	Y	7,298	
2)	1440	1.30	260.38	338.49	8.5	7.8	37	Y	8,201	
3)	1455	1.27	232.06	294.71	8.0	7.7	37	Y	8,896	
4)	1341	1.30	267.30	347.49	9.5	7.9	37	Y	8,062	
5)	1020	1.19	230.05	273.76	10.5	7.8	27	Y	6,742	
6)	1535	1.21	290.11	351.03	9.5	8.0	37	Y	7,228	
7)	1400	1.18	250.85	296.00	9.0	7.8	36	Y	8,271	
8)	1425	1.18	215.02	253.73	8.5	7.5	30	Y	9,174	
9)	1010	1.15	289.33	332.73	8.5	7.7	36	Y	7,367	
10)	0930	1.24	266.53	330.49	8.0	8.1	45	Y	7,298	
11)	1455	1.15	234.29	269.43	8.5	7.6	36	Y	8,062	
12)	1550	1.15	245.70	282.55	9.0	7.8	36	Y	8,062	
13)	1530	1.31	235.88	309.00	8.5	7.9	37	Y	8,201	
14)	1450	1.22	230.06	280.67	8.0	8.3	45	Y	7,993	
15)	1405	1.21	265.88	321.71	8.5	7.8	37	Y	7,576	
16)	1415	1.37	222.07	304.23	8.0	7.9	37	Y	8,062	
17)	1100	1.31	229.66	300.85	7.5	7.8	37	Y	8,340	
18)	1418	1.30	300.18	390.24	7.0	8.2	45	Y	7,089	
19)	1245	1.25	220.63	275.79	7.5	8.4	45	Y	8,410	
20)	1650	1.34	240.91	322.82	7.0	7.9	37	Y	8,271	
21)	1730	1.50	227.64	341.46	7.0	8.2	46	Y	6,811	
22)	1325	1.38	245.65	339.00	6.5	8.0	37	Y	8,201	
23)	1530	1.21	230.59	279.02	6.0	7.8	37	Y	9,035	
24)	1415	1.28	300.25	384.32	5.5	7.8	37	Y	7,367	
25)	1515	1.13	216.16	244.26	5.0	7.9	36	Y	8,966	
26)	1120	1.25	243.23	304.4	5.0	7.9	37	Y	8,896	
27)	1520	1.37	296.80	406.62	4.5	7.9	52	Y	7,298	
28)	1840	1.15	265.42	305.24	5.5	7.8	36	Y	8,132	
29)	1400	1.33	234.50	311.89	6.5	8.1	45	Y	8,410	
30)	1520	1.40	288.97	404.56	6.5	7.9	38	Y	7,576	
31)	1325	1.38	231.50	319.47	7.0	7.8	37	Y	9,174	