

OHA- Drinking Water Program- Turbidity Monitoring Report Form
Conventional or Direct Filtration

County: **Clackamas**

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: February 2026
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	0.03	OFF	OFF	OFF	0.03	0.03	0.03
2	0.03	OFF	OFF	OFF	0.03	0.03	0.03
3	OFF	OFF	OFF	OFF	0.03	0.03	0.03
4	0.03	OFF	OFF	OFF	0.03	0.03	0.03
5	0.03	0.03	OFF	OFF	0.02	0.02	0.03
6	0.02	OFF	OFF	OFF	0.02	0.02	0.03
7	0.02	OFF	OFF	OFF	0.02	0.03	0.03
8	0.03	OFF	OFF	OFF	0.03	0.03	0.03
9	OFF	OFF	OFF	OFF	0.03	0.03	0.03
10	0.03	0.03	OFF	0.04	OFF	OFF	0.04
11	0.03	0.03	OFF	OFF	0.03	0.03	0.03
12	0.03	0.03	OFF	OFF	0.03	0.04	0.04
13	OFF	OFF	OFF	OFF	0.04	0.04	0.04
14	0.03	OFF	OFF	OFF	0.04	0.05	0.05
15	0.03	OFF	OFF	0.03	0.04	0.03	0.04
16	OFF	OFF	OFF	0.04	OFF	OFF	0.05
17	0.04	0.04	OFF	OFF	OFF	0.04	0.05
18	0.04	0.04	OFF	OFF	OFF	0.04	0.05
19	0.04	OFF	OFF	OFF	0.02	0.02	0.05
20	0.02	OFF	OFF	OFF	0.02	0.02	0.02
21	OFF	OFF	OFF	OFF	0.02	0.03	0.03
22	0.03	OFF	OFF	OFF	0.02	0.03	0.03
23	0.03	OFF	OFF	OFF	OFF	OFF	0.03
24	0.03	0.03	OFF	OFF	0.03	0.03	0.03
25	0.03	OFF	OFF	OFF	OFF	0.03	0.03
26	0.03	0.03	OFF	OFF	0.03	0.03	0.04
27	0.03	OFF	OFF	OFF	0.03	0.03	0.03
28	0.03	OFF	OFF	OFF	0.02	0.03	0.03
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of the 4-hour turbidity readings ≤ 0.3 NTU? Yes / No				CT's met everyday? (see back)		All CL ₂ residual at entry point ≥ 0.2 mg/l?	
All the 4-hour turbidity readings ≤ 1 NTU? Yes / No				Yes / No		Yes/No	
All turbidity readings < IFE ² triggers? Yes / No²							
Notes:				Printed Name: Richard Mark Cage			
				Signature: <i>Richard Mark Cage</i>		3/5/2026	
				Phone: 503-657-5030		CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Eff. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: Feb-26	Required Log Inactivation: 2.5	
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1331	1.33	221.88	295.09	7.0	7.6	37	Y	8,827
2)	1630	1.10	246.49	271.14	8.0	7.8	36	Y	6,811
3)	1125	1.13	272.61	308.05	8.0	7.6	36	Y	7,367
4)	1825	1.34	261.40	350.28	8.5	7.8	37	Y	7,923
5)	1300	1.26	238.88	300.99	8.5	7.8	37	Y	8,062
6)	1410	1.22	242.60	295.98	8.0	7.6	37	Y	8,271
7)	1455	1.24	269.32	333.95	8.0	7.7	37	Y	8,271
8)	1435	1.38	292.08	403.06	8	7.8	37	Y	7,298
9)	1900	1.15	243.29	279.78	9	7.5	30	Y	6,672
10)	1527	1.32	233.34	308.02	8.5	7.6	37	Y	7,993
11)	1415	1.23	293.05	360.45	8.5	8.0	37	Y	6,950
12)	1330	1.29	247.78	319.64	7.5	7.5	31	Y	8,410
13)	1350	1.21	237.14	286.94	8.5	7.8	37	Y	7,854
14)	1135	1.25	258.71	323.39	8.5	7.8	37	Y	8,340
15)	1415	1.32	246.46	325.32	8.5	7.9	37	Y	8,201
16)	1440	1.14	241.42	275.22	8	7.6	36	Y	6,811
17)	1411	1.36	224.72	305.62	8	7.7	37	Y	6,603
18)	1330	1.46	252.91	369.33	7.5	7.8	38	Y	8,201
19)	1510	1.32	234.01	308.89	8.0	7.8	37	Y	9,174
20)	1525	1.26	286.90	361.49	8.0	7.8	37	Y	7,298
21)	1425	1.13	261.17	295.12	8.0	7.9	36	Y	8,340
22)	1440	1.33	248.86	330.98	8.5	7.8	37	Y	8,340
23)	1410	1.19	268.70	319.75	8.0	7.7	36	Y	7,367
24)	1710	1.18	251.57	296.85	8.5	7.6	36	Y	8,201
25)	1255	1.12	221.45	248.02	9.0	8.1	43	Y	8,479
26)	1455	1.21	215.02	260.18	9.0	8.4	45	Y	8,132
27)	1425	1.20	282.45	338.94	8.5	7.8	37	Y	7,506
28)	1125	1.29	267.52	345.10	8.0	8.2	45	Y	7,923