

OHA- Drinking Water Program- Turbidity Monitoring Report Form
 Conventional or Direct Filtration

County: Clackamas

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: March 2026
Day	12 AM (NTU)	4 AM (NTU)	8 AM (NTU)	NOON (NTU)	4 PM (NTU)	8 PM (NTU)	Highest Reading of the Day ¹ (NTU)
1	OFF	OFF	OFF	OFF	0.02	0.03	0.03
2	0.03	OFF	OFF	OFF	0.02	0.02	0.03
3	0.03	0.03	OFF	OFF	OFF	OFF	0.03
4	0.02	OFF	OFF	OFF	OFF	0.02	0.03
5	0.02	0.03	OFF	OFF	OFF	0.02	0.03
6	0.02	OFF	OFF	OFF	0.02	0.03	0.03
7	0.03	OFF	OFF	OFF	0.02	0.03	0.03
8	OFF	OFF	OFF	OFF	0.02	0.02	0.03
9	0.03	OFF	OFF	OFF	OFF	0.02	0.03
10	0.02	OFF	OFF	OFF	OFF	0.02	0.03
11	0.02	0.03	OFF	OFF	OFF	0.02	0.03
12	0.02	0.03	OFF	OFF	0.03	0.03	0.03
13	OFF	OFF	OFF	OFF	0.03	0.03	0.03
14	0.03	OFF	OFF	OFF	0.03	0.03	0.03
15	0.03	OFF	OFF	OFF	0.04	0.03	0.04
16	0.03	OFF	OFF	0.03	0.03	0.03	0.03
17	0.03	OFF	OFF	OFF	OFF	0.03	0.03
18	0.03	0.03	OFF	OFF	0.03	0.03	0.03
19	0.03	OFF	OFF	OFF	OFF	0.02	0.03
20	0.03	OFF	OFF	OFF	0.02	0.02	0.03
21	OFF	OFF	OFF	OFF	0.02	0.03	0.03
22	OFF	OFF	OFF	OFF	0.02	0.02	0.02
23	0.02	OFF	OFF	OFF	0.02	OFF	0.03
24	0.02	OFF	OFF	OFF	OFF	OFF	0.04
25	0.03	0.03	OFF	OFF	OFF	0.03	0.03
26	OFF	OFF	OFF	OFF	0.02	0.02	0.03
27	0.02	OFF	OFF	OFF	0.02	0.02	0.03
28	0.03	OFF	OFF	OFF	0.02	0.03	0.03
29	0.03	OFF	OFF	OFF	0.02	0.02	0.03
30	0.02	OFF	OFF	OFF	OFF	OFF	0.03
31	0.02	0.02	OFF	OFF	OFF	0.02	0.03
Conventional or Direct Filtration				Monthly Summary (Answer Yes or No)			
95% of the 4-hour turbidity readings \leq 0.3 NTU? Yes / No				CT's met everyday? (see back)		All CL ₂ residual at entry point \geq 0.2 mg/l?	
All the 4-hour turbidity readings \leq 1 NTU? Yes / No				Yes / No		Yes/No	
All turbidity readings < IFE ² triggers? Yes / No²				Yes / No		Yes/No	
Notes:				Printed Name: Richard Mark Cage			
				Signature: <i>Richard Mark Cage</i> 4/1/2026			
				Phone: 503-657-5030		CERT #: 2610	

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² IFE= Individ. Filter Effl. (OAR 333-061-0040(1)(e)(B&C))

OHA-Drinking Water Program-Surface Water Quality Data Form

SOUTH FORK WATER BOARD ID#: OR4100591 WTP:-WTP-A							Month/Year: Mar-26	Required Log Inactivation: 2.5	
Date/Time	Minimum CL ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow	
	ppm or mg/L	minutes	C x T	(°C)		Use tables	Yes / No	[GPM]	
1)	1430	1.35	290.39	392.03	9.0	8.1	45	Y	7,159
2)	1912	1.19	252.33	300.28	9.5	8.1	43	Y	8,271
3)	1448	1.48	247.04	365.63	9.0	7.8	38	Y	8,132
4)	1820	1.19	246.36	293.17	10.0	8.0	27	Y	7,576
5)	1320	1.39	272.49	378.76	10.5	7.6	28	Y	7,784
6)	1550	1.11	229.25	254.46	10.5	7.7	27	Y	6,881
7)	1418	1.21	232.17	280.93	11.0	7.8	28	Y	6,881
8)	1500	1.13	277.02	313.03	10.0	7.9	27	Y	7,437
9)	1930	1.21	227.58	275.37	11.0	7.5	23	Y	6,881
10)	1920	1.22	252.97	308.62	10.0	7.8	28	Y	7,784
11)	1610	1.29	262.01	338.00	10.0	8.3	33	Y	7,367
12)	1300	1.17	251.02	373.12	9.5	8.0	38	Y	7,784
13)	1540	1.17	268.36	313.98	11.0	7.8	22	Y	7,367
14)	1235	1.16	234.88	272.16	10.5	7.9	27	Y	7,993
15)	1430	1.24	249.29	309.12	9.5	7.7	37	Y	7,576
16)	1330	1.24	261.24	323.94	9.0	7.8	37	Y	7,228
17)	1545	1.21	250.08	302.60	10.5	7.9	28	Y	7,367
18)	1355	1.19	257.53	306.46	11.0	8.0	27	Y	7,298
19)	1930	1.28	287.43	367.91	11.0	7.6	28	Y	7,367
20)	1535	1.16	317.77	368.62	10.5	8.0	27	Y	7,020
21)	1510	1.20	228.86	274.64	12.0	7.9	28	Y	6,533
22)	1405	1.30	232.61	302.39	10.5	7.9	28	Y	6,742
23)	1700	1.31	292.08	382.62	11.0	8.2	33	Y	7,298
24)	1447	1.10	260.90	286.99	11.0	7.8	27	Y	7,298
25)	1710	1.17	242.44	283.66	10.5	7.8	27	Y	6,394
26)	1500	1.24	134.84	167.20	12.0	7.8	55	Y	7,506
27)	1420	1.39	146.45	203.57	11.5	7.8	55	Y	7,020
28)	1125	1.35	141.53	191.06	12.5	7.8	55	Y	7,367
29)	1430	1.24	111.24	137.94	10.5	7.7	55	Y	8,896
30)	1510	1.33	145.29	193.24	10.5	7.8	55	Y	6,742
31)	1850	1.32	109.09	144.00	10.5	7.7	55	Y	9,244