

OHA - Drinking Water Services – Turbidity Monitoring Report Form County: July/2021
 Slow Sand, Membrane, Diatomaceous Earth Filtration or Unfiltered Systems

System Name: CAR District Improvement Co. ID #: 4100600 WTP-: _____ Month/Year: 07/2021

DAY	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the Day ¹ [NTU]
1	.FF	1	.055	.FF	1	1	.055
2	1	1	.026	.FF	1	1	.026
3	1	1	1	1	1	1	1
4	1	1	1	1	1	1	1
5	1	1	1	1	1	1	1
6	1	1	.185	.FF	1	1	.185
7	1	1	1	1	1	1	1
8	1	1	.031	.FF	1	1	.031
9	1	1	1	1	1	1	1
10	1	1	1	1	1	1	1
11	1	1	.054	.FF	1	1	.054
12	1	1	1	1	1	1	1
13	1	1	.021	.FF	1	1	.021
14	1	1	1	1	1	1	1
15	1	1	1	1	1	1	1
16	1	1	1	1	1	1	1
17	1	1	1	1	1	1	1
18	1	1	.122	.FF	1	1	.122
19	1	1	1	1	1	1	1
20	1	1	.042	.FF	1	1	.042
21	1	1	1	1	1	1	1
22	1	1	1	1	1	1	1
23	1	1	.107	.FF	1	1	.107
24	1	1	1	1	1	1	1
25	1	1	1	1	1	1	1
26	1	1	1	1	1	1	1
27	1	1	.034	.FF	1	1	.034
28	1	1	.054	.FF	1	1	.054
29	1	1	1	1	1	1	1
30	1	1	.135	.FF	1	1	.135
31	1	1	1	1	1	1	1

50
GPM



Slow Sand/Membrane/DE Filtration/Unfiltered Monthly Summary 95% of daily turbidity readings ≤ 1 NTU? ² <u>Yes</u> / No All daily turbidity readings ≤ 5 NTU? <u>Yes</u> / No	Monthly Summary (Answer Yes or No)	
	CT's met everyday? (see back) <u>Yes</u> / No	All Cl ₂ residual at entry point ≥ 0.2 mg/l? <u>Yes</u> / No
Notes:	PRINTED NAME: <u>TREVOR SCHNABEL</u>	
	SIGNATURE: <u>T. Schnabel</u>	DATE: <u>8/3/2021</u>
	PHONE #: <u>(541) 992-1090</u>	CERT #: <u>T-436613</u>

¹ Including continuous turbidity data, if applicable, for optimization recording purposes. Compliance values in columns "12 AM" through "8 PM" may not correspond to continuous readings' maximum. ² Filtered systems only.

July/2021

Oregon DHS - Drinking Water Program - Surface Water Quality Data Form

System Name: CHR District Improvement Co ID #: 41 00600 Month/Year: 07/2021

Date / Time	Minimum Cl ₂ Residual at 1 st User (C)	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met?
	ppm or mg/L	minutes	C X T	°C		Use tables	Yes / No
1 / 1100	.6	47	28	13°	7.5	21	Yes
2 / 1030	.8		37	14°	↓	22	Yes
3 / 1130	.9		42	↓	↓	22	Yes
4 / 1000	.8		37	15°	↓	15	Yes
5 / 0900	.8		37	↓	↓	15	Yes
6 / 0900	.8		37	↓	↓	15	Yes
7 / 1030	.8		37	14°	↓	22	Yes
8 / 1000	.8		37	15°	↓	15	Yes
9 / 1200	.9		42	14°	↓	22	Yes
10 / 1000	.9		42	15°	↓	15	Yes
11 / 1200	.7		32	↓	↓	15	Yes
12 / 0900	.8		37	↓	7.6	18	Yes
13 / 1035	.8		37	↓	7.5	15	Yes
14 / 1000	.8		37	↓	↓	15	Yes
15 / 0900	.8		37	↓	↓	15	Yes
16 / 1000	.8		37	↓	↓	15	Yes
17 / 1200	1.0		47	↓	↓	15	Yes
18 / 1000	.9		42	↓	↓	15	Yes
19 / 1000	.9		42	↓	↓	15	Yes
20 / 1200	.8		37	↓	↓	15	Yes
21 / 1000	.8		37	↓	↓	15	Yes
22 / 1100	.6		28	↓	↓	14	Yes
23 / 0930	.7		32	↓	↓	15	Yes
24 / 1000	.7		32	↓	↓	15	Yes
25 / 1200	.8		37	↓	↓	15	Yes
26 / 1000	.7		32	↓	↓	15	Yes
27 / 1030	.6		28	↓	↓	14	Yes
28 / 1030	.7		32	↓	↓	15	Yes
29 / 1000	.7		32	↓	↓	15	Yes
30 / 0930	.8		37	↓	↓	15	Yes
31 / 1200	.7		32	↓	↓	15	Yes