

MARCH 2025

OHA - DWS

Membrane Filter Monthly Operating Report

System Name: CHH District Improvement Co.

County: TILLAMOOK

PWS ID#: 41 - 00600

Month/Year: 03 / 2025

Plant ID: WTP - 7 (e.g., "A")

Minimum test pressure applied || req'd: 30 psi || 30 psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇄

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR_{Max} [psi/min]
.14

LRC [log removal]
4.00

DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
2	<u>.022</u>	<u>—</u>	<u>.022</u>	<u>.01</u>		Y
3	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
4	<u>.013</u>	<u>—</u>	<u>.013</u>	<u>.01</u>		Y
5	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
6	<u>.014</u>	<u>—</u>	<u>.014</u>	<u>.01</u>		Y
7	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
8	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
9	<u>.022</u>	<u>—</u>	<u>.022</u>	<u>.03</u>		Y
10	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
11	<u>.017</u>	<u>—</u>	<u>.017</u>	<u>.02</u>		Y
12	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
13	<u>.013</u>	<u>—</u>	<u>.013</u>	<u>.03</u>		Y
14	<u>.013</u>	<u>—</u>	<u>.013</u>	<u>.03</u>		Y
15	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
16	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
17	<u>.022</u>	<u>—</u>	<u>.022</u>	<u>.01</u>		Y
18	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
19	<u>.024</u>	<u>—</u>	<u>.024</u>	<u>.01</u>		Y
20	<u>.022</u>	<u>—</u>	<u>.022</u>	<u>.01</u>		Y
21	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
22	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
23	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
24	<u>.029</u>	<u>—</u>	<u>.029</u>	<u>.01</u>		Y
25	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
26	<u>.018</u>	<u>—</u>	<u>.018</u>	<u>.01</u>		Y
27	<u>.015</u>	<u>—</u>	<u>.015</u>	<u>.01</u>		Y
28	<u>.020</u>	<u>—</u>	<u>.020</u>	<u>.01</u>		Y
29	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
30	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off
31	<u>—</u>	<u>—</u>	<u>—</u>	<u>—</u>		off

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? <u>(Y/N)</u>	All turbidity readings ≤ 5 NTU? <u>(Y/N)</u>	All IFE turbidity readings ≤ 0.15 NTU? <u>(Y/N)</u>	Performance std met? <u>(Y/N)</u> (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily? <u>Yes</u>
CT's met daily? (p. 2) <u>Yes</u>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <u>Yes</u>	PDR ≤ PDR _{Max} ? <u>Yes</u>	LRV _{ambient} ≥ LRC? <u>Yes</u>	

PRINTED NAME: TREVOR SCHWABEL

SIGNATURE: Trevor Schwab

Notes:

DATE: 4-01-2025

WT CERT #: J-436613

PHONE #: (541) 996-4143

p. 1 of 2

MARCH/2025

Disinfection Monthly Operating ReportSystem Name: CHL-District Improvement Co.PWS ID#: 41 - 00600Plant ID : WTP - U

0.5

 ⇐ Log Inactivation Required via Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	.6	47	28	9°	7.3	29	YES	50	off
2	.8		37	10°	7.4	22	Yes		ON
3	.8		37		7.3	22	Yes		off
4	.9		42		7.2	22	Yes	GPM	ON
5	.9		42		7.3	22	Yes		off
6	.7		32			21	Yes		ON
7	.6		28			21	Yes		off
8	.8		37			22	Yes		off
9	.9		42			22	Yes		ON
10	.8		37			22	Yes		off
11	.9		42			22	Yes		ON
12	.9		42			22	Yes		off
13	.8		37		7.4	22	Yes		ON
14	.8		37			22	Yes		ON
15	.8		37		7.3	22	Yes		off
16	.8		37		7.4	22	Yes		off
17	.8		37		7.3	22	Yes		ON
18	.9		42			22	Yes		off
19	.9		42			22	Yes		ON
20	1.1					23	Yes		ON
21	1.0		47			22	Yes		off
22	1.0		47			22	Yes		off
23	.9		42			22	Yes		off
24	.8		37			22	Yes		ON
25	.7		32			21	Yes		off
26	1.1		51	10°	7.5	23	Yes		ON
27	1.2		56	11°	7.4	23	Yes		ON
28	1.1		51	10°		23	Yes		ON
29	1.0		47	11°		22	Yes		off
30	1.0		47			22	Yes		off
31	.9		42		7.3	22	Yes		off

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dmce@odhsoha.oregon.gov

fax: 971-673-0458

p. 2 of 2