

APRIL/2025

OHA - DWS

Membrane Filter Monthly Operating Report

County: TILLAMOOKSystem Name: CHB-District Improvement Co. Month/Year: 04-2025PWS ID#: 41 - 00600 Minimum test pressure applied || req'd: 30 psi || 30 psiPlant ID: WTP - ✓ (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇔

PDR = Pressure Decay Rate

LRC = Log Removal Credit

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	PDR _{Max} [psi/min]	LRC [log removal]	DIT Daily [Y/N] or "off"
				<u>.14</u>	<u>4.00</u>	
1	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
2	<u>.015</u>	<u>✓</u>	<u>.015</u>	<u>.00</u>		<u>Y</u>
3	<u>.015</u>	<u>✓</u>	<u>.015</u>	<u>.00</u>		<u>Y</u>
4	<u>.022</u>	<u>✓</u>	<u>.022</u>	<u>.00</u>		<u>Y</u>
5	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
6	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
7	<u>.019</u>	<u>✓</u>	<u>.019</u>	<u>.00</u>		<u>Y</u>
8	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
9	<u>.019</u>	<u>✓</u>	<u>.019</u>	<u>.00</u>		<u>Y</u>
10	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
11	<u>.015</u>	<u>✓</u>	<u>.015</u>	<u>.01</u>		<u>Y</u>
12	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
13	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
14	<u>.021</u>	<u>✓</u>	<u>.021</u>	<u>.00</u>		<u>Y</u>
15	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
16	<u>.014</u>	<u>✓</u>	<u>.014</u>	<u>.00</u>		<u>Y</u>
17	<u>.013</u>	<u>✓</u>	<u>.013</u>	<u>.00</u>		<u>Y</u>
18	<u>.013</u>	<u>✓</u>	<u>.013</u>	<u>.00</u>		<u>Y</u>
19	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
20	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
21	<u>.013</u>	<u>✓</u>	<u>.013</u>	<u>.00</u>		<u>Y</u>
22	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
23	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
24	<u>.019</u>	<u>✓</u>	<u>.019</u>	<u>.00</u>		<u>Y</u>
25	<u>.016</u>	<u>✓</u>	<u>.016</u>	<u>.00</u>		<u>Y</u>
26	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
27	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
28	<u>.020</u>	<u>✓</u>	<u>.020</u>	<u>.00</u>		<u>Y</u>
29	<u>✓</u>	<u>✓</u>	<u>✓</u>	<u>✓</u>		<u>off</u>
30	<u>.013</u>	<u>✓</u>	<u>.013</u>	<u>.00</u>		<u>Y</u>

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? <u>(Y/N)</u>	All turbidity readings ≤ 5 NTU? <u>(Y/N)</u>	All IFE turbidity readings ≤ 0.15 NTU? <u>(Y/N)</u>	Performance std met? <u>(Y/N)</u> (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily? <u>Yes</u>
CT's met daily? (p. 2) <u>Yes</u>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <u>Yes</u>	PDR ≤ PDR _{Max} ? <u>Yes</u>	LRV _{ambient} ≥ LRC? <u>Yes</u>	

PRINTED NAME: TREVOR SCHWABELSIGNATURE: Tim Smith

Notes:

DATE: 5-01-2025
WT CERT #: T-436613
PHONE #: (541) 996-4443

p. 1 of 2

~~MARCH~~ / 2025
APRILDisinfection Monthly Operating ReportSystem Name: CHR-District Improvement Co.PWS ID#: 41 - 00600Plant ID : WTP - TH

0.5

 Log Inactivation Required via Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [° C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	.9	47	42	11°	7.3	22	Yes	50	off
2	1.0		47			22	Yes		ON
3	.9		42			22	Yes		ON
4	1.0		47	10°		22	Yes	6PM	ON
5	.9		42			22	Yes		off
6	.9		42	11°		22	Yes		off
7	.7		32		7.4	21	Yes		ON
8	.7		32		7.3	21	Yes		off
9	.8		37			22	Yes		ON
10	.8		37		7.5	22	Yes		off
11	.7		32		7.3	21	Yes		ON
12	.7		32			21	Yes		off
13	.7		32			21	Yes		off
14	.8		37		7.4	22	Yes		ON
15	.9		42			22	Yes		off
16	.7		32			21	Yes		ON
17	1.2		56			23	Yes		ON
18	1.0		47			22	Yes		ON
19	1.0		47			22	Yes		off
20	1.2		56		7.3	23	Yes		off
21	1.2		56		7.4	23	Yes		ON
22	1.2		56		7.3	23	Yes		off
23	1.1		51			23	Yes		off
24	1.2		56			23	Yes		ON
25	1.0		47		7.4	22	Yes		ON
26	1.0		47		7.3	22	Yes		off
27	.9		42		7.4	22	Yes		off
28	.8		37			22	Yes		ON
29	.9		42			22	Yes		off
30	.9		42		7.3	22	Yes		ON

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350
email: dwp.dmce@odhsoha.oregon.gov
fax: 971-673-0458

p. 2 of 2