

JUNE/2025

OHA - DWS

Membrane Filter Monthly Operating Report

County: TILLAMOOKSystem Name: CHR-District Improvement Co Month/Year: 06-2025PWS ID#: 41 - 00600Minimum test pressure applied || req'd: 30 psi || 30 psiPlant ID: WTP - H (e.g., "A")

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

PDR_{Max} [psi/min]

LRC [log removal]

LRC = Log Removal Credit

.144.00DIT
Daily

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 min duration)	Highest PDR of day [psi/min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	.013	✓	.013	.00	✓	Y
2	✓	✓	✓	✓	✓	off
3	✓	✓	✓	✓	✓	off
4	.020	✓	.020	.00	✓	Y
5	.013	✓	.013	.00	✓	Y
6	.013	✓	.013	.00	✓	Y
7	✓	✓	✓	✓	✓	off
8	.012	✓	.012	.00	✓	Y
9	.013	✓	.013	.00	✓	Y
10	✓	✓	✓	✓	✓	off
11	.015	✓	.015	.00	✓	Y
12	.015	✓	.015	.00	✓	Y
13	.012	✓	.012	.00	✓	Y
14	✓	✓	✓	✓	✓	off
15	.015	✓	.015	.00	✓	Y
16	.014	✓	.014	.00	✓	Y
17	✓	✓	✓	✓	✓	off
18	.016	✓	.016	.01	✓	Y
19	✓	✓	✓	✓	✓	off
20	.020	✓	.020	.01	✓	Y
21	✓	✓	✓	✓	✓	off
22	.013	✓	.013	.01	✓	Y
23	.018	✓	.018	.01	✓	Y
24	✓	✓	✓	✓	✓	off
25	.024	✓	.024	.01	✓	Y
26	✓	✓	✓	✓	✓	off
27	.013	✓	.013	.01	✓	Y
28	✓	✓	✓	✓	✓	off
29	.014	✓	.014	.01	✓	Y
30	.012	✓	.012	✓	✓	Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? ☒ [Y/N]	All turbidity readings ≤ 5 NTU? ☒ [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? ☒ [Y/N]	Performance std met? ☒ [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily? <u>Yes</u>
CT's met daily? (p. 2) <u>Yes</u>	All Cl ₂ residual at EP ≥ 0.2 mg/L? <u>Yes</u>	PDR ≤ PDR _{Max} ? <u>Yes</u>	LRV _{ambient} ≥ LRC? <u>Yes</u>	

PRINTED NAME: TREVOR SCHNABELSIGNATURE: Trevor Schnabel

Notes:

DATE: 7-2-2025WT CERT #: T-436613PHONE #: (541) 996-4443

p. 1 of 2

JUNE/2025

Disinfection Monthly Operating Report

System Name: CHR-District Improvement Co.PWS ID#: 41 - 00600Plant ID: WTP - 110.5Log
Inactivation
Required via
Disinfection

Day	Minimum Cl ₂ Residual at 1 st User (C) * [mg/L = ppm]	Contact Time (T) [minutes]	Actual CT C x T (Formula)	Temp [°C]	pH	Required CT (Formula)	CT Met? * [Yes / No] (Formula)	Peak Hourly Demand Flow [GPM]	Notes (e.g. "Plant Off")
1	.5	47	23	12°	7.2	21	Yes	50	ON
2	1.0	47	47	1	7.4	22	Yes	50	off
3	1.0	47	47	1	7.4	22	Yes	6 PM	off
4	.7	32	32	13°	7.5	22	Yes		ON
5	.6	28	28	1	7.4	21	Yes		ON
6	1.0	47	47	1	7.5	22	Yes		ON
7	1.0	47	47	1	7.4	22	Yes		off
8	.8	37	37	1	7.4	22	Yes		ON
9	1.2	56	56	1	7.4	23	Yes		ON
10	1.0	47	47	1	7.4	22	Yes		off
11	.8	37	37	1	7.5	22	Yes		ON
12	1.2	56	56	1	7.4	23	Yes		ON
13	1.2	56	56	1	7.4	23	Yes		ON
14	1.1	51	51	1	7.4	23	Yes		off
15	.8	37	37	1	7.5	22	Yes		ON
16	1.2	56	56	1	7.4	23	Yes		ON
17	1.2	56	56	1	7.4	23	Yes		off
18	.9	42	42	1	7.4	22	Yes		ON
19	.9	42	42	1	7.4	22	Yes		off
20	.9	42	42	1	7.5	22	Yes		ON
21	.9	42	42	1	7.4	22	Yes		off
22	.7	32	32	1	7.4	22	Yes		ON
23	.6	28	28	1	7.4	21	Yes		ON
24	.6	28	28	1	7.4	21	Yes		off
25	.5	23	23	1	7.4	21	Yes		ON
26	1.5	40	40	14°	7.6 - 7.8	28	Yes		off
27	1.1	51	51	1	7.5	23	Yes		ON
28	1.1	51	51	1	7.5	23	Yes		off
29	1.1	51	51	1	7.4	23	Yes		ON
30	1.1	51	51	1	7.4	23	Yes		ON

* If chlorine concentration at entry point < 0.2 mg/L, or CT not met, notify DWS within 24 hours.

Submit this monthly report by the 10th of following month by

mail: Drinking Water Services
PO Box 14350
Portland, OR 97293-0350

email: dwp.dnce@odhsqa.oregon.gov

fax: 971-673-0458

p. 2 of 2

Revised 7/31/2023