

**OHA - Drinking Water Services - Surface Water Quality Data Form**  
**Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

County: **Lincoln**  
 Month/Year: **Sep-24**

System Name: <b>Hiland WC - Riverbend</b>		ID#: <b>41 00601</b>		WTP : TP - <b>A</b>			
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day <sup>1</sup> [NTU]
9/1/2024	0.03	0.01	0.01	0.01	0.01	0.01	0.03
9/2/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/3/2024	0.01	0.01	0.02	0.01	0.01	0.01	0.04
9/4/2024	0.01	0.01	0.01	0.01	0.01	0.03	0.03
9/5/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/6/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/7/2024	0.08	0.01	0.01	0.01	0.01	0.01	0.08
9/8/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/9/2024	0.01	0.03	0.01	0.01	0.04	0.01	0.04
9/10/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/11/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/12/2024	0.01	0.01	0.01	0.01	0.01	0.02	0.02
9/13/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/14/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/15/2024	0.01	0.01	0.01	0.02	0.01	0.01	0.02
9/16/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/17/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/18/2024	0.05	0.01	0.01	0.01	0.01	0.01	0.05
9/19/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/20/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/21/2024	0.01	0.01	0.02	0.03	0.01	0.01	0.03
9/22/2024	0.02	0.01	0.01	0.01	0.01	0.01	0.02
9/23/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/24/2024	0.01	0.01	0.01	0.01	0.01	0.05	0.05
9/25/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/26/2024	0.01	0.01	0.01	0.01	0.04	0.01	0.04
9/27/2024	0.01	0.02	0.01	0.01	0.01	0.01	0.02
9/28/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/29/2024	0.01	0.01	0.01	0.01	0.01	0.01	0.01
9/30/2024	0.01	0.01	0.04	0.05	0.05	0.02	0.05

<b>Slow Sand/Membrane/DE Filtration/Unfiltered</b> 95% of daily turbidity readings ≤ 1 NTU? <sup>2</sup> <input checked="" type="radio"/> Yes <input type="radio"/> No All daily turbidity readings ≤ 5 NTU? <input checked="" type="radio"/> Yes <input type="radio"/> No	<b>Monthly Summary (Answer Yes or No)</b> CT's met everyday? (see <input checked="" type="radio"/> Yes <input type="radio"/> No)		All Cl2 residual at entry point <input checked="" type="radio"/> Yes <input type="radio"/> No
	<b>Notes:</b>		
PRINTED NAME: <b>JJ Olson</b>		SIGNATURE: <i>JJ Olson</i>	
PHONE #: <b>(503) 554-8333</b>		10/09/2024 CERT #: T766039	

<sup>1</sup> Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 PM may correspond to continuous readings' maximum. <sup>2</sup> Filtered systems only.

<b>OHA - Drinking Water Services - Surface Water Quality Data Form</b>				WTP- : <b>A</b>	
System Name: Hiland WC - Riverbend      ID#: 41 00601      Month/Year: Sep-24				Disinfection <i>Giardia</i> Log Inactiv: <b>0.5</b>	

Date / Time	Minimum Cl <sub>2</sub> Residual at 1st User (C) <sup>3</sup>	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? <sup>3</sup>	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	<b>C X T</b>	[° C]		formula	Yes / No	[GPM]
9/1/2024	1.01	63	63.6	13.4	6.95	14.9	Yes	60
9/2/2024	1.49	63	93.6	12.8	6.92	16.1	Yes	60
9/3/2024	1.35	63	85.1	12.8	6.91	15.9	Yes	60
9/4/2024	1.11	63	69.8	13.4	6.90	14.7	Yes	60
9/5/2024	1.13	63	71.4	12.9	6.92	15.4	Yes	60
9/6/2024	1.04	63	65.5	13.1	6.94	15.2	Yes	60
9/7/2024	1.04	63	65.3	12.8	6.89	15.2	Yes	60
9/8/2024	0.82	63	51.8	13.6	6.94	14.3	Yes	60
9/9/2024	0.97	63	61.1	13.6	6.96	14.7	Yes	60
9/10/2024	0.68	63	43.1	12.9	6.93	14.7	Yes	60
9/11/2024	1.05	63	66.3	13.4	6.97	15.0	Yes	60
9/12/2024	1.51	63	95.0	13.4	6.94	15.7	Yes	60
9/13/2024	1.51	63	95.4	13.5	6.97	15.8	Yes	60
9/14/2024	1.39	63	87.3	13.4	6.95	15.5	Yes	60
9/15/2024	1.33	63	83.8	13.5	6.99	15.6	Yes	60
9/16/2024	1.30	63	81.9	13.6	6.98	15.4	Yes	60
9/17/2024	1.07	63	67.6	13.2	7.07	15.9	Yes	60
9/18/2024	0.63	63	39.4	12.9	7.03	15.2	Yes	60
9/19/2024	0.53	63	33.5	12.9	7.03	15.0	Yes	60
9/20/2024	0.73	63	46.1	12.8	7.04	15.5	Yes	60
9/21/2024	1.99	63	125.4	13.4	7.16	18.0	Yes	60
9/22/2024	1.99	63	125.4	13.5	7.14	17.7	Yes	60
9/23/2024	1.99	63	125.4	13.5	7.16	17.9	Yes	60
9/24/2024	1.61	63	101.5	13.0	7.06	17.1	Yes	60
9/25/2024	1.56	63	98.0	12.9	7.07	17.2	Yes	60
9/26/2024	1.49	63	94.1	13.1	7.08	16.9	Yes	60
9/27/2024	1.38	63	87.2	12.9	7.04	16.6	Yes	60
9/28/2024	1.40	63	88.4	13.3	7.10	16.5	Yes	60
9/29/2024	1.00	63	62.9	13.1	7.06	15.8	Yes	60
9/30/2024	1.58	63	99.5	12.9	7.07	17.2	Yes	60

<sup>3</sup> If Cl<sub>2</sub> at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.

Revised October 2013