

OHA - DWS

Membrane Filter Monthly Operating Report

County: **Lincoln**

System Name: **Riverbend**

Month/Year: **Jan-2026**

PWS ID#: 41 - **00601**

Minimum test pressure **applied**: **22.76** psi

Plant ID: WTP - _____
(e.g., "A")

Minimum test pressure **req'd**: **22** psi

DIT = Direct Integrity Test on filter(s) [Yes, No, or "off" if all filters are offline] ⇌

PDR = Pressure Decay Rate

LRC = Log Removal Credit

PDR _{Max} [^{psi} /min]	LRC [log removal]	DIT Daily
4.00	4.00	

Day	CFE Daily Turbidity [NTU]	Highest CFE* [NTU]	Highest IFE [NTU] (>15 minutes)	Highest PDR of day [^{psi} /min]	Lowest LRV _{ambient} of day [log removal]	[Y/N] or "off"
1	0.111		0.111	<0.099		Y
2	0.111		0.111	<0.099		Y
3	0.108		0.108	<0.099		Y
4	0.104		0.104	<0.099		Y
5	0.104		0.104	<0.099		Y
6	0.111		0.111	<0.099		Y
7	0.108		0.108	<0.099		Y
8	0.104		0.104	<0.099		Y
9	0.108		0.108	<0.099		Y
10	0.098		0.098	<0.099		Y
11	0.111		0.111	<0.099		Y
12	0.108		0.108	<0.099		Y
13	0.102		0.102	<0.099		Y
14	0.108		0.108	<0.099		Y
15	0.102		0.102	<0.099		Y
16	0.108		0.108	<0.099		Y
17	0.108		0.108	<0.099		Y
18	0.102		0.102	<0.099		Y
19	0.108		0.108	<0.099		Y
20	0.104		0.104	<0.099		Y
21	0.104		0.104	<0.099		Y
22	0.108		0.108	<0.099		Y
23	0.108		0.108	<0.099		Y
24	0.108		0.108	<0.099		Y
25	0.108		0.108	<0.099		Y
26	0.108		0.108	<0.099		Y
27	0.108		0.108	<0.099		Y
28	0.108		0.108	<0.099		Y
29	0.102		0.102	<0.099		Y
30	0.086		0.086	<0.099		Y
31	0.115		0.115	<0.099		Y

Compliance summary (operator to complete any blank fields)

95% of daily turbidity readings ≤ 1 NTU? [Y/N]	All turbidity readings ≤ 5 NTU? [Y/N]	All IFE turbidity readings ≤ 0.15 NTU? [Y/N]	Performance std met? [Y/N] (PDR ≤ PDR _{Max} , LRV ≥ LRC)	DIT Daily?
Yes	Yes	Yes	Yes	Yes
CT's met daily? (p. 2)	All Cl ₂ residual at EP ≥ 0.2 mg/L?	PDR ≤ PDR _{Max} ?	LRV _{ambient} ≥ LRC?	
Yes	Yes	Yes		

PRINTED NAME: Curtis Olson **DATE:** 2/10/26
SIGNATURE: *Curtis Olson* **WT CERT #:** 216644
Notes: **PHONE #:** 503-554-8333

* Used for optimization purposes only.

