

OHA - Drinking Water Services - Surface Water Quality Data Form

County: Lincoln

Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems
Month Year

Sep 2021

System No	Panther Creek Water Dist ID#: 41060						WTP: TP -
Day	12 AM [NTU]	4 AM [NTU]	8 AM [NTU]	NOON [NTU]	4 PM [NTU]	8 PM [NTU]	Highest Reading of the day ¹ [NTU]
1			.60				.60
2			1.00				1.00
3			.60				1.00
4			.00				1.00
5			.00				.00
6			1.00				.00
7			.60				.60
8			.00				.00
9			.60				1.00
10			.60				.60
11			.00				.00
12			.00				.00
13			.60				1.00
14			1.00				.60
15			1.00				1.00
16			1.00				.60
17			.60				.60
18			.00				.00
19			.00				.00
20			.60				1.00
21			.60				.60
22			.60				1.00
23			1.00				1.00
24			1.00				1.00
25			.00				.00
26			.00				.00
27			1.00				1.00
28			.60				.60
29			.60				1.00
30			1.00				1.00
31							

Slow Sand/Membrane/DE Filtration/Unfiltered		Monthly Summary (Answer Yes or No)	
95% of daily turbidity readings ≤ 1 NTU? ²	Yes / No	CT's met everyday? (see back)	All Cl2 residual at entry point ≥ 0.2 mg/l?
All daily turbidity readings ≤ 5 NTU?	Yes / No	Yes / No	Yes / No
Notes:		PRINTED NAME: Martin Klinger	DATE: 9/30/2021
		SIGNATURE: <i>Martin Klinger</i>	CERT #: 7152
		PHONE #: (541) 994 - 4548	

¹ Including continuous NTU data, if applicable, for optimization recording purposes. Compliance values in columns 12 AM through 8 correspond to continuous readings' maximum. ² Filtered systems only.

OHA - Drinking Water Services - Surface Water Quality Data Form

WTP: -

System No: Panther Creek Water	ID#: 4106003	Month/Year: Sep	2020	Disinfection Giardia Log Inactiv: 1.00
--------------------------------	--------------	-----------------	------	--

Date / Time	Minimum Cl ₂ Residual at 1st User (C) ³	Contact Time (T)	Actual CT	Temp	pH	Required CT	CT Met? ³	Peak Hourly Demand Flow
	[ppm or mg/L]	[minutes]	C X T	[°C]			Yes / No	[GPM]
1	1.60	82.6	132.1	7.81	7.31	40	YES	✓
2	1.71	82.6	141.2	12.82	7.32	40	YES	
3	1.70	82.6	140.4	12.3	7.31	40	YES	
4	1.24	82.6	102.4	12.3	7.39	36	YES	
5	.94	82.6	77.6	12.2	7.27	35	YES	
6	1.27	82.6	104.9	12.1	7.31	37	YES	
7	1.29	82.6	106.5	12.2	7.33	37	YES	
8	1.30	82.6	107.3	12.1	7.30	38	YES	
9	1.31	82.6	108.2	12.3	7.31	38	YES	
10	1.30	82.6	107.3	12.4	7.34	38	YES	
11	1.75	82.6	144.5	12.3	7.37	39	YES	
12	1.80	82.6	99.1	12.2	7.33	38	YES	
13	1.21	82.6	99.9	12.4	7.34	38	YES	
14	1.20	82.6	99.1	12.3	7.33	38	YES	
15	1.21	82.6	99.9	12.4	7.34	38	YES	
16	1.28	82.6	103.2	12.2	7.33	38	YES	
17	1.30	82.6	107.3	12.1	7.30	38	YES	
18	2.20	82.6	181.7	12.2	7.37	40	YES	
19	2.20	82.6	181.7	12.1	7.36	40	YES	
20	2.22	82.6	181.7	12.1	7.33	44	YES	
21	2.00	82.6	165.2	12.2	7.31	40	YES	
22	2.00	82.6	165.2	12.1	7.34	44	YES	
23	2.10	82.6	173.4	12.3	7.30	41	YES	
24	2.00	82.6	165.2	12.1	7.31	41	YES	
25	2.20	82.6	181.7	12.2	7.37	40	YES	
26	1.30	82.6	107.3	12.1	7.33	38	YES	
27	1.31	82.6	108.2	12.2	7.31	38	YES	
28	1.29	82.6	106.5	12.1	7.33	38	YES	
29	1.29	82.6	106.5	12.0	7.31	38	YES	
30	1.29	82.6	106.5	12.3	7.35	38	YES	
31		82.6						

³ If Cl₂ at entry point < 0.2 mg/l or CT not met, notify DWS within 24 hours.
 Page 4 of 11 PAGE 2 of 2

Revised October 2013