

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 03/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.019	0.018	0.018	0.018	0.019	0.019	0.025
2	0.025	0.021	0.021	0.021	0.019	0.019	0.025
3	0.019	0.021	0.021	0.018	0.023	0.018	0.023
4	0.021	0.019	0.019	0.019	0.016	0.018	0.037
5	0.018	0.019	0.016	0.018	0.016	0.019	0.021
6	0.019	0.021	0.021	0.021	0.018	0.018	0.021
7	0.019	0.018	0.018	0.016	0.019	0.019	0.023
8	0.021	0.018	0.019	0.018	0.018	0.019	0.021
9	0.018	0.018	0.019	0.019	0.019	0.021	0.023
10	0.023	0.023	0.025	0.016	0.016	0.019	0.027
11	0.018	0.018	0.018	0.019	0.016	0.016	0.021
12	0.018	0.019	0.018	0.018	0.021	0.018	0.025
13	0.018	0.018	0.016	0.016	0.018	0.018	0.019
14	0.016	0.018	0.019	0.018	0.018	0.018	0.019
15	0.019	0.018	0.018	0.016	0.019	0.016	0.019
16	0.018	0.018	0.021	0.018	0.018	0.019	0.021
17	0.016	0.018	0.018	0.019	0.019	0.019	0.023
18	0.023	0.018	0.018	0.019	0.021	0.018	0.023
19	0.021	0.016	0.016	0.016	0.018	0.019	0.021
20	0.019	0.016	0.016	0.019	0.019	0.019	0.021
21	0.018	0.018	0.018	0.021	0.019	0.021	0.021
22	0.021	0.019	0.021	0.019	0.018	0.019	0.021
23	0.016	0.019	0.019	0.018	0.018	0.019	0.019
24	0.018	0.018	0.018	0.018	0.021	0.019	0.021
25	0.018	0.019	0.019	0.019	0.019	0.019	0.023
26	0.018	0.018	0.018	0.019	0.019	0.016	0.023
27	0.019	0.018	0.019	0.019	0.018	0.016	0.021
28	0.021	0.023	0.018	0.019	0.021	0.018	0.023
29	0.019	0.019	0.021	0.019	0.019	0.018	0.021
30	0.019	0.019	0.019	0.019	0.018	0.023	0.030
31	0.030	0.025	0.021	0.025	0.023	0.016	0.030

95% of daily turbidity readings < 1 NTU? Yes/No
 turbidity readings < 5 NTU? Yes/No

All daily

CT's met everyday? (see back) Yes/No

All Cl2 residual at entry point 0.2 mg/l? Yes/No

Notes:

Printed Name: Leonard Whiteman T-09364

Signature 

Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 03/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.52	36.0	54.72	9.91	6.86	19.6	YES	700
2	1.38	36.0	49.68	10.65	6.88	18.5	YES	700
3	1.32	36.0	47.52	9.80	6.90	19.6	YES	700
4	1.36	36.0	48.96	9.80	7.31	22.7	YES	700
5	1.44	36.0	51.84	10.57	7.16	20.6	YES	700
6	1.31	36.0	47.16	9.88	6.90	19.4	YES	700
7	1.38	36.0	49.68	10.33	6.95	19.4	YES	700
8	1.44	36.0	51.84	8.97	6.98	21.5	YES	700
9	1.34	36.0	48.24	14.93	6.64	12.4	YES	700
10	1.35	36.0	48.60	12.86	6.89	15.7	YES	700
11	1.35	36.0	48.60	9.47	6.93	20.3	YES	700
12	1.40	36.0	50.40	9.88	6.94	19.9	YES	700
13	1.38	36.0	49.68	9.74	6.97	20.3	YES	700
14	1.35	36.0	48.60	10.33	6.98	19.5	YES	700
15	1.35	36.0	48.60	8.86	6.99	21.5	YES	700
16	1.41	36.0	50.76	9.05	7.03	21.7	YES	700
17	1.35	36.0	48.60	9.16	7.01	21.3	YES	700
18	1.29	36.0	46.44	9.74	6.97	20.1	YES	700
19	1.29	36.0	46.44	10.15	6.96	19.5	YES	700
20	1.45	36.0	52.20	10.09	6.94	19.8	YES	700
21	1.40	36.0	50.40	9.53	6.97	20.6	YES	700
22	1.38	36.0	49.68	11.73	6.88	17.3	YES	700
23	1.38	36.0	49.68	9.47	6.85	19.8	YES	700
24	1.47	36.0	52.92	9.56	6.94	20.5	YES	700
25	1.33	36.0	47.88	9.65	6.86	19.5	YES	700
26	1.44	36.0	51.84	10.21	6.94	19.6	YES	700
27	1.47	36.0	52.92	9.62	6.94	20.4	YES	700
28	1.51	36.0	54.36	9.45	6.96	20.9	YES	700
29	1.35	36.0	48.60	9.69	6.93	20.0	YES	700
30	1.42	36.0	51.12	10.14	6.93	19.6	YES	700
31	1.45	36.0	52.20	10.00	6.96	20.0	YES	700