

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 07/2021							
Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.019	0.019	0.018	0.021	0.025	0.019	0.027
2	0.018	0.021	0.018	0.019	0.019	0.018	0.023
3	0.019	0.021	0.019	0.018	0.019	0.018	0.023
4	0.018	0.021	0.019	0.019	0.021	0.018	0.023
5	0.023	0.019	0.019	0.019	0.021	0.018	0.023
6	0.023	0.019	0.021	0.019	0.021	0.019	0.023
7	0.021	0.019	0.019	0.019	0.019	0.019	0.021
8	0.019	0.021	0.023	0.019	0.019	0.019	0.023
9	0.021	0.025	0.019	0.018	0.019	0.019	0.025
10	0.019	0.019	0.019	0.018	0.019	0.023	0.023
11	0.018	0.018	0.019	0.027	0.018	0.019	0.028
12	0.021	0.019	0.021	0.019	0.025	0.018	0.025
13	0.021	0.021	0.019	0.018	0.023	0.021	0.023
14	0.019	0.021	0.019	0.019	0.019	0.018	0.021
15	0.021	0.019	0.021	0.019	0.019	0.019	0.023
16	0.023	0.023	0.019	0.042	0.018	0.018	0.042
17	0.019	0.021	0.023	0.019	0.019	0.019	0.025
18	0.025	0.019	0.019	0.021	0.019	0.021	0.025
19	0.021	0.021	0.018	0.019	0.021	0.019	0.021
20	0.019	0.019	0.019	0.021	0.023	0.019	0.025
21	0.021	0.019	0.019	0.019	0.016	0.019	0.021
22	0.019	0.019	0.021	0.021	0.018	0.019	0.021
23	0.019	0.019	0.019	0.019	0.019	0.019	0.021
24	0.021	0.019	0.019	0.021	0.021	0.019	0.023
25	0.021	0.019	0.018	0.021	0.018	0.019	0.023
26	0.019	0.019	0.021	0.028	0.019	0.019	0.028
27	0.021	0.021	0.018	0.019	0.019	0.018	0.021
28	0.018	0.018	0.019	0.019	0.021	0.019	0.025
29	0.023	0.019	0.019	0.019	0.018	0.018	0.023
30	0.019	0.021	0.019	0.019	0.018	0.019	0.023
31	0.019	0.019	0.019	0.019	0.023	0.018	0.023
95% of daily turbidity readings < 1 NTU? Yes/No			All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No		
turbidity readings < 5 NTU? Yes/No							
Notes:				Printed Name: Leonard Whiteman T-09364			
				Signature <i>Leonard Whiteman</i>			
				Phone # 503-965-6636			

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 07/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.19	36.0	42.84	15.55	6.89	12.9	YES	700
2	1.15	36.0	41.40	16.48	6.84	11.8	YES	700
3	1.20	36.0	43.20	16.16	6.80	12.0	YES	700
4	1.21	36.0	43.56	16.86	6.81	11.5	YES	700
5	1.21	36.0	43.56	16.15	6.81	12.0	YES	700
6	1.24	36.0	44.64	16.16	6.82	12.1	YES	700
7	1.15	36.0	41.40	15.72	6.82	12.3	YES	700
8	1.20	36.0	43.20	15.21	7.02	13.8	YES	700
9	1.29	36.0	46.44	15.70	6.89	12.9	YES	700
10	1.28	36.0	46.08	16.08	6.83	12.3	YES	700
11	1.35	36.0	48.60	15.46	6.99	13.7	YES	700
12	1.29	36.0	46.44	16.27	6.84	12.2	YES	700
13	1.30	36.0	46.80	15.58	6.90	13.1	YES	700
14	1.26	36.0	45.36	15.90	6.85	12.5	YES	700
15	1.20	36.0	43.20	15.73	6.81	12.4	YES	700
16	0.99	36.0	35.64	15.89	6.80	11.9	YES	700
17	1.02	36.0	36.72	15.05	6.86	12.9	YES	700
18	1.02	36.0	36.72	15.20	6.86	12.8	YES	700
19	1.03	36.0	37.08	15.25	6.79	12.4	YES	700
20	1.00	36.0	36.00	16.78	6.67	10.7	YES	700
21	1.15	36.0	41.40	15.08	6.85	13.0	YES	700
22	1.08	36.0	38.88	15.39	6.76	12.2	YES	700
23	1.09	36.0	39.24	15.01	6.77	12.6	YES	700
24	1.11	36.0	39.96	15.97	6.65	11.3	YES	700
25	1.05	36.0	37.80	15.98	6.63	11.2	YES	700
26	1.01	36.0	36.36	16.46	6.57	10.5	YES	700
27	1.05	36.0	37.80	16.06	6.63	11.1	YES	700
28	1.03	36.0	37.08	15.61	6.56	11.1	YES	700
29	1.00	36.0	36.00	16.09	6.60	10.9	YES	700
30	0.97	36.0	34.92	16.68	6.47	9.9	YES	700
31	1.09	36.0	39.24	15.39	6.65	11.8	YES	700