


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 07/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.018	0.023	0.019	0.018	0.021	0.018	0.023
2	0.019	0.023	0.018	0.021	0.019	0.019	0.023
3	0.019	0.021	0.019	0.019	0.019	0.019	0.021
4	0.021	0.023	0.018	0.021	0.021	0.019	0.023
5	0.023	0.021	0.021	0.018	0.023	0.021	0.023
6	0.021	0.021	0.019	0.025	0.019	0.019	0.025
7	0.021	0.021	0.018	0.019	0.021	0.019	0.021
8	0.021	0.021	0.018	0.021	0.019	0.019	0.021
9	0.021	0.021	0.021	0.027	0.019	0.018	0.027
10	0.021	0.023	0.019	0.019	0.019	0.021	0.023
11	0.021	0.023	0.019	0.018	0.018	0.021	0.023
12	0.021	0.019	0.019	0.019	0.018	0.019	0.021
13	0.021	0.019	0.021	0.023	0.019	0.019	0.023
14	0.021	0.021	0.019	0.021	0.018	0.021	0.025
15	0.021	0.018	0.021	0.021	0.019	0.019	0.021
16	0.021	0.019	0.018	0.021	0.025	0.018	0.025
17	0.021	0.019	0.023	0.019	0.019	0.019	0.025
18	0.018	0.019	0.021	0.021	0.021	0.021	0.023
19	0.021	0.019	0.021	0.019	0.018	0.019	0.023
20	0.021	0.023	0.023	0.025	0.021	0.019	0.030
21	0.019	0.021	0.019	0.019	0.021	0.021	0.023
22	0.019	0.023	0.019	0.018	0.021	0.023	0.023
23	0.023	0.021	0.021	0.019	0.018	0.021	0.023
24	0.021	0.021	0.019	0.023	0.021	0.019	0.025
25	0.021	0.023	0.019	0.019	0.019	0.021	0.025
26	0.025	0.021	0.019	0.023	0.023	0.021	0.025
27	0.021	0.019	0.019	0.021	0.019	0.019	0.027
28	0.019	0.021	0.019	0.021	0.025	0.019	0.025
29	0.019	0.019	0.021	0.019	0.019	0.023	0.023
30	0.021	0.021	0.021	0.023	0.019	0.019	0.025
31	0.023	0.023	0.019	0.023	0.023	0.023	0.023

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/No
---	-----------	---	---

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year ⁸ 07/2021								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.05	36.0	37.80	16.06	6.61	11.0	YES	700
2	1.02	36.0	36.72	16.51	6.51	10.3	YES	700
3	1.03	36.0	37.08	15.46	6.62	11.5	YES	700
4	1.00	36.0	36.00	15.95	6.60	11.0	YES	700
5	1.00	36.0	36.00	15.87	6.53	10.8	YES	700
6	0.86	36.0	30.96	15.89	6.53	10.6	YES	700
7	0.90	36.0	32.40	15.17	6.58	11.4	YES	700
8	0.89	36.0	32.04	15.46	6.67	11.5	YES	700
9	0.97	36.0	34.92	15.99	6.71	11.4	YES	700
10	1.12	36.0	40.32	16.06	7.14	13.5	YES	700
11	1.09	36.0	39.24	16.78	6.97	12.1	YES	700
12	1.13	36.0	40.68	16.07	7.04	13.1	YES	700
13	1.09	36.0	39.24	16.59	6.95	12.1	YES	700
14	1.20	36.0	43.20	16.42	6.96	12.5	YES	700
15	1.27	36.0	45.72	16.56	6.97	12.5	YES	700
16	1.29	36.0	46.44	16.03	7.01	13.2	YES	700
17	1.32	36.0	47.52	15.33	7.12	14.4	YES	700
18	1.28	36.0	46.08	15.68	7.08	13.8	YES	700
19	1.32	36.0	47.52	15.64	7.03	13.7	YES	700
20	1.41	36.0	50.76	16.26	6.99	13.1	YES	700
21	1.46	36.0	52.56	15.70	7.04	13.9	YES	700
22	1.48	36.0	53.28	15.54	7.09	14.3	YES	700
23	1.48	36.0	53.28	14.94	7.11	15.0	YES	700
24	1.48	36.0	53.28	16.12	7.11	13.9	YES	700
25	1.46	36.0	52.56	14.52	7.02	14.9	YES	700
26	1.47	36.0	52.92	15.16	6.68	12.6	YES	700
27	1.46	36.0	52.56	15.49	6.57	11.8	YES	700
28	1.54	36.0	55.44	15.41	6.68	12.5	YES	700
29	1.52	36.0	54.72	15.09	6.60	12.4	YES	700
30	1.49	36.0	53.64	14.93	6.67	12.8	YES	700
31	1.50	36.0	54.00	14.80	6.67	12.9	YES	700