

OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 12/2021

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.012	0.011	0.011	0.012	0.012	0.016
2	0.012	0.014	0.012	0.014	0.012	0.012	0.014
3	0.012	0.012	0.012	0.012	0.012	0.012	0.016
4	0.012	0.012	0.012	0.012	0.012	0.014	0.016
5	0.014	0.012	0.014	0.012	0.014	0.011	0.016
6	0.012	0.014	0.012	0.016	0.011	0.012	0.016
7	0.014	0.014	0.012	0.037	0.014	0.011	0.037
8	0.011	0.014	0.014	0.014	0.014	0.018	0.700
9	0.016	0.016	0.016	0.018	0.014	0.016	0.018
10	0.016	0.018	0.014	0.014	0.011	0.012	0.018
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	0.016	0.016	0.018	0.012	0.011	0.012	0.018
18	0.012	0.012	0.012	0.011	0.012	0.012	0.014
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	0.018	0.018	0.018	0.011	0.012	0.012	0.019
23	0.012	0.012	0.012	0.012	0.012	0.012	0.014
24	0.012	0.012	0.012	0.014	0.011	0.014	0.014
25	0.012	0.012	0.012	0.012	0.012	0.011	0.014
26	0.012	0.012	0.011	0.016	0.012	0.011	0.025
27	0.012	0.012	0.012	0.011	0.012	0.011	0.012
28	0.012	0.011	0.011	0.011	0.011	0.011	0.016
29	0.016	0.012	0.012	0.012	0.014	0.014	0.016
30	0.014	0.012	0.012	0.012	0.012	0.011	0.016
31	0.012	0.011	0.012	0.014	0.012	0.012	0.178

95% of daily turbidity readings < 1 NTU? Yes/No  Yes  No  
 turbidity readings < 5 NTU? Yes/No  Yes  No  
 All daily CT's met everyday? (see back) Yes/No  Yes  No  
 All Cl2 residual at entry point 0.2 mg/l? Yes/No  Yes  No

Notes: 12/08/2021 Calibrations  
 Printed Name: Leonard Whiteman T-09364  
 Signature   
 Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 12/2021								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	1.57	36.0	56.52	12.12	7.28	19.7	YES	700
2	1.64	36.0	59.04	11.21	7.07	19.6	YES	700
3	1.72	36.0	61.92	11.30	6.74	17.6	YES	700
4	1.68	36.0	60.48	10.62	6.62	17.5	YES	700
5	1.54	36.0	55.44	11.14	6.61	16.6	YES	700
6	1.62	36.0	58.32	9.96	6.60	18.1	YES	700
7	1.52	36.0	54.72	11.49	6.53	15.8	YES	700
8	1.55	36.0	55.80	11.31	6.60	16.4	YES	700
9	1.67	36.0	60.12	10.00	6.58	18.0	YES	700
10	1.64	36.0	59.04	11.72	6.58	16.1	YES	700
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	1.64	36.0	59.04	11.80	6.60	16.1	YES	700
18	1.53	36.0	55.08	10.73	6.54	16.7	YES	700
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
21	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
22	1.26	36.0	45.36	13.28	6.54	13.3	YES	700
23	1.57	36.0	56.52	11.99	6.50	15.3	YES	700
24	1.78	36.0	64.08	10.12	6.53	17.8	YES	700
25	1.76	36.0	63.36	10.09	6.56	17.9	YES	700
26	1.75	36.0	63.00	8.76	6.57	19.6	YES	700
27	1.74	36.0	62.64	8.19	6.57	20.3	YES	700
28	1.72	36.0	61.92	8.23	6.56	20.1	YES	700
29	1.64	36.0	59.04	9.05	6.60	19.2	YES	700
30	1.66	36.0	59.76	8.86	6.60	19.5	YES	700
31	1.63	36.0	58.68	9.34	6.60	18.8	YES	700