

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 03/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	0.034	0.032	0.032	0.012	0.011	0.011	0.034
3	0.012	0.012	0.012	0.011	0.011	0.014	0.014
4	0.011	0.012	0.011	0.011	0.011	0.012	0.012
5	0.012	0.012	0.011	0.011	0.012	0.011	0.014
6	0.012	0.012	0.012	0.011	0.011	0.012	0.012
7	0.012	0.012	0.011	0.011	0.012	0.011	0.014
8	0.012	0.011	0.011	0.014	0.012	0.011	0.014
9	0.011	0.011	0.011	0.011	0.011	0.011	0.014
10	0.014	0.012	0.011	0.011	0.016	0.012	0.016
11	0.012	0.011	0.012	0.012	0.012	0.011	0.014
12	0.011	0.012	0.012	0.012	0.012	0.012	0.014
13	0.011	0.011	0.012	0.012	0.011	0.012	0.012
14	0.011	0.012	0.012	0.012	0.011	0.012	0.016
15	0.011	0.012	0.012	0.012	0.012	0.011	0.014
16	0.011	0.011	0.011	0.012	0.012	0.011	0.018
17	0.012	0.012	0.011	0.011	0.012	0.012	0.012
18	0.012	0.012	0.011	0.012	0.012	0.011	0.014
19	0.012	0.012	0.011	0.011	0.011	0.012	0.014
20	0.012	0.012	0.011	0.012	0.011	0.011	0.014
21	0.011	0.012	0.012	0.011	0.011	0.011	0.012
22	0.012	0.012	0.011	0.014	0.012	0.012	0.014
23	0.009	0.014	0.012	0.012	0.012	0.012	0.014
24	0.011	0.012	0.012	0.011	0.018	0.012	0.018
25	0.011	0.012	0.011	0.011	0.011	0.014	0.014
26	0.011	0.011	0.011	0.011	0.012	0.011	0.014
27	0.011	0.012	0.012	0.011	0.012	0.014	0.014
28	0.011	0.011	0.011	0.011	0.012	0.011	0.012
29	0.011	0.012	0.012	0.011	0.011	0.012	0.012
30	0.011	0.012	0.012	0.012	0.012	0.012	0.014
31	0.011	0.012	0.011	0.011	0.011	0.011	0.014

95% of daily turbidity readings < 1 NTU? <i>Yes</i> /No	All daily	CT's met everyday? (see back) <i>Yes</i> /No	All Cl2 residual at entry point 0.2 mg/l? <i>Yes</i> /No
turbidity readings < 5 NTU? <i>Yes</i> /No			

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature <i>Leonard Whiteman</i>
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 03/2022								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	1.13	36.0	40.68	13.39	6.53	12.9	YES	700
3	1.37	36.0	49.32	10.39	6.54	16.7	YES	700
4	1.42	36.0	51.12	10.72	6.63	17.0	YES	700
5	1.59	36.0	57.24	9.63	6.67	18.8	YES	700
6	1.64	36.0	59.04	10.20	6.69	18.4	YES	700
7	1.60	36.0	57.60	9.95	6.70	18.7	YES	700
8	1.51	36.0	54.36	10.19	6.68	18.1	YES	700
9	1.31	36.0	47.16	10.06	6.61	17.4	YES	700
10	1.26	36.0	45.36	10.55	6.82	18.0	YES	700
11	1.48	36.0	53.28	9.36	7.00	21.2	YES	700
12	1.67	36.0	60.12	9.01	7.03	22.4	YES	700
13	1.50	36.0	54.00	9.64	6.99	20.8	YES	700
14	1.48	36.0	53.28	10.30	6.96	19.7	YES	700
15	1.59	36.0	57.24	10.38	6.94	19.7	YES	700
16	1.60	36.0	57.60	11.21	7.00	19.1	YES	700
17	1.62	36.0	58.32	10.02	7.03	20.9	YES	700
18	1.61	36.0	57.96	10.54	7.03	20.1	YES	700
19	1.56	36.0	56.16	10.67	7.00	19.7	YES	700
20	1.58	36.0	56.88	10.19	7.02	20.5	YES	700
21	1.52	36.0	54.72	9.40	6.97	21.0	YES	700
22	1.25	36.0	45.00	11.59	6.85	17.0	YES	700
23	1.52	36.0	54.72	11.17	6.94	18.6	YES	700
24	1.58	36.0	56.88	10.19	7.01	20.4	YES	700
25	1.69	36.0	60.84	10.19	7.00	20.6	YES	700
26	1.63	36.0	58.68	11.49	7.07	19.2	YES	700
27	1.59	36.0	57.24	11.21	7.03	19.2	YES	700
28	1.58	36.0	56.88	12.72	6.98	16.8	YES	700
29	1.50	36.0	54.00	11.00	6.99	19.1	YES	700
30	1.51	36.0	54.36	11.24	7.05	19.2	YES	700
31	1.60	36.0	57.60	10.17	7.02	20.5	YES	700