

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 05/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.016	0.012	0.016	0.016	0.016	0.018
2	0.016	0.018	0.018	0.012	0.014	0.016	0.018
3	0.014	0.014	0.014	0.012	0.014	0.012	0.016
4	0.012	0.016	0.014	0.014	0.012	0.014	0.016
5	0.014	0.012	0.012	0.012	0.014	0.014	0.014
6	0.011	0.012	0.014	0.011	0.012	0.014	0.016
7	0.014	0.016	0.016	0.012	0.012	0.012	0.016
8	0.012	0.012	0.012	0.012	0.016	0.014	0.016
9	0.014	0.012	0.014	0.012	0.016	0.014	0.016
10	0.014	0.012	0.012	0.014	0.014	0.016	0.016
11	0.014	0.014	0.014	0.014	0.014	0.014	0.027
12	0.016	0.014	0.016	0.019	0.014	0.012	0.019
13	0.014	0.014	0.012	0.014	0.012	0.014	0.016
14	0.014	0.014	0.016	0.016	0.018	0.018	0.019
15	0.019	0.019	0.019	0.012	0.012	0.014	0.021
16	0.014	0.014	0.012	0.014	0.012	0.012	0.014
17	0.014	0.012	0.012	0.014	0.014	0.012	0.014
18	0.012	0.014	0.014	0.012	0.014	0.014	0.016
19	0.014	0.016	0.012	0.014	0.014	0.012	0.016
20	0.011	0.012	0.014	0.012	0.014	0.012	0.016
21	0.012	0.014	0.014	0.014	0.014	0.016	0.016
22	0.012	0.016	0.016	0.012	0.014	0.012	0.016
23	0.014	0.014	0.016	0.014	0.016	0.016	0.019
24	0.012	0.014	0.014	0.012	0.014	0.012	0.016
25	0.012	0.014	0.014	0.014	0.012	0.014	0.016
26	0.014	0.016	0.016	0.014	0.014	0.014	0.016
27	0.014	0.016	0.014	0.056	0.016	0.012	0.056
28	0.012	0.012	0.012	0.012	0.012	0.011	0.016
29	0.012	0.014	0.014	0.014	0.014	0.012	0.014
30	0.014	0.016	0.016	0.011	0.012	0.014	0.016
31	0.014	0.014	0.014	0.012	0.012	0.018	0.018

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---	-----------	--------------------------------------	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 05/2022								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	1.56	36.0	56.16	11.45	6.93	18.2	YES	700
2	1.51	36.0	54.36	11.12	6.96	18.7	YES	700
3	1.37	36.0	49.32	11.65	6.94	17.7	YES	700
4	1.54	36.0	55.44	10.73	6.93	19.1	YES	700
5	1.49	36.0	53.64	11.54	6.98	18.3	YES	700
6	1.41	36.0	50.76	12.73	6.99	16.5	YES	700
7	1.38	36.0	49.68	12.19	6.94	17.1	YES	700
8	1.63	36.0	58.68	10.88	7.00	19.5	YES	700
9	1.64	36.0	59.04	10.19	7.06	20.9	YES	700
10	1.72	36.0	61.92	10.82	7.02	20.0	YES	700
11	1.61	36.0	57.96	10.61	7.05	20.2	YES	700
12	1.60	36.0	57.60	11.26	6.99	18.9	YES	700
13	1.57	36.0	56.52	10.16	6.96	20.1	YES	700
14	1.34	36.0	48.24	13.08	6.84	15.2	YES	700
15	1.20	36.0	43.20	13.36	6.82	14.5	YES	700
16	1.48	36.0	53.28	11.61	6.88	17.6	YES	700
17	1.63	36.0	58.68	11.26	6.96	18.8	YES	700
18	1.66	36.0	59.76	10.88	6.95	19.3	YES	700
19	1.60	36.0	57.60	12.55	6.93	16.7	YES	700
20	1.63	36.0	58.68	10.90	6.95	19.2	YES	700
21	1.66	36.0	59.76	11.65	7.01	18.7	YES	700
22	1.63	36.0	58.68	11.49	7.02	18.9	YES	700
23	1.59	36.0	57.24	13.16	7.01	16.5	YES	700
24	1.59	36.0	57.24	11.66	7.03	18.7	YES	700
25	1.65	36.0	59.40	12.41	7.03	17.9	YES	700
26	1.61	36.0	57.96	12.22	6.92	17.4	YES	700
27	1.60	36.0	57.60	12.60	6.94	16.7	YES	700
28	1.54	36.0	55.44	11.39	6.90	18.1	YES	700
29	1.42	36.0	51.12	11.67	6.85	17.2	YES	700
30	1.58	36.0	56.88	11.73	6.86	17.5	YES	700
31	1.66	36.0	59.76	12.55	6.91	16.7	YES	700