

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**


System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP--C Month/Year: 06/2022

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.014	0.011	0.014	0.012	0.014	0.014	0.016
2	0.014	0.014	0.016	0.014	0.014	0.014	0.019
3	0.014	0.016	0.014	0.014	Offline	Offline	0.016
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	0.012	0.014	0.012	0.014
7	0.014	0.014	0.012	0.012	0.012	0.012	0.016
8	0.012	0.014	0.014	0.014	0.012	0.014	0.016
9	0.012	0.014	0.014	0.014	0.014	0.016	0.016
10	0.014	0.016	0.014	0.014	0.014	0.012	0.016
11	0.014	0.014	0.014	0.018	0.014	0.012	0.035
12	0.014	0.014	0.014	0.012	0.014	0.014	0.016
13	0.014	0.012	0.014	0.012	0.012	0.012	0.014
14	0.012	0.012	0.014	0.014	0.012	0.012	0.016
15	0.012	0.014	0.014	0.014	0.012	0.014	0.016
16	0.014	0.014	0.012	0.012	0.014	0.012	0.016
17	0.014	0.012	0.014	0.014	0.016	0.016	0.018
18	0.014	0.018	0.012	0.014	0.014	0.012	0.018
19	0.016	0.014	0.014	0.016	0.014	0.014	0.016
20	0.014	0.016	0.016	0.016	0.016	0.014	0.016
21	0.014	0.018	0.014	0.016	0.016	0.016	0.018
22	0.016	0.014	0.014	0.011	0.012	0.014	0.016
23	0.018	0.016	0.014	0.016	0.014	0.014	0.018
24	0.014	0.014	0.014	0.014	0.014	0.012	0.014
25	0.016	0.012	0.016	0.014	0.012	0.012	0.016
26	0.014	0.014	0.014	0.014	0.012	0.014	0.014
27	0.016	0.014	0.012	0.014	Offline	Offline	0.016
28	Offline	Offline	Offline	Offline	0.012	0.014	0.014
29	0.018	0.019	0.021	0.027	0.012	0.014	0.027
30	0.014	0.014	0.012	0.016	0.016	0.016	0.016

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes / <input type="radio"/> No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes / <input type="radio"/> No
turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes / <input type="radio"/> No			

Notes: Did NTU calibrations on June 30th.

Printed Name: Leonard Whiteman T-09364

Signature: 

Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 06/2022								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.58	36.0	56.88	12.46	6.90	17.0	YES	700
2	1.60	36.0	57.60	12.39	6.92	17.2	YES	700
3	1.49	36.0	53.64	13.95	6.91	14.9	YES	700
4	1.42	36.0	51.12	15.31	6.93	13.6	YES	700
5	1.39	36.0	50.04	15.62	6.97	13.5	YES	700
6	1.37	36.0	49.32	14.31	6.94	14.5	YES	700
7	1.42	36.0	51.12	12.23	6.88	16.8	YES	700
8	1.53	36.0	55.08	12.89	6.91	16.1	YES	700
9	1.38	36.0	49.68	12.71	6.91	16.0	YES	700
10	1.29	36.0	46.44	12.44	6.82	16.0	YES	700
11	1.35	36.0	48.60	12.79	6.81	15.3	YES	700
12	1.51	36.0	54.36	11.88	6.87	17.3	YES	700
13	1.57	36.0	56.52	12.11	6.94	17.6	YES	700
14	1.53	36.0	55.08	12.20	6.93	17.3	YES	700
15	1.54	36.0	55.44	12.28	6.94	17.3	YES	700
16	1.61	36.0	57.96	12.08	6.93	17.6	YES	700
17	1.45	36.0	52.20	12.29	6.95	17.2	YES	700
18	1.53	36.0	55.08	11.74	6.94	17.9	YES	700
19	1.48	36.0	53.28	12.47	6.96	17.1	YES	700
20	1.41	36.0	50.76	12.74	6.93	16.2	YES	700
21	1.46	36.0	52.56	13.58	6.95	15.5	YES	700
22	1.55	36.0	55.80	12.94	6.90	16.0	YES	700
23	1.41	36.0	50.76	13.56	6.95	15.4	YES	700
24	1.46	36.0	52.56	12.73	6.92	16.2	YES	700
25	1.43	36.0	51.48	14.34	6.87	14.2	YES	700
26	1.35	36.0	48.60	14.67	6.86	13.8	YES	700
27	1.27	36.0	45.72	17.79	6.89	11.2	YES	700
28	0.74	36.0	26.64	16.92	6.85	11.0	YES	700
29	0.78	36.0	28.08	15.63	6.89	12.2	YES	700
30	1.56	36.0	56.16	13.52	6.94	15.7	YES	700