


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

| System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 08/2022 |          |         |         |         |         |         |                    |
|--|----------|---------|---------|---------|---------|---------|--------------------|
| Day  | 12:00 AM | 4:00 AM | 8:00 AM | NOON    | 4PM     | 8:00 PM | Highest Reading of |
| 1  | 0.014    | 0.016   | 0.016   | 0.018   | 0.018   | 0.018   | 0.018              |
| 2  | 0.018    | 0.018   | 0.018   | 0.014   | 0.018   | 0.016   | 0.018              |
| 3  | 0.023    | 0.014   | 0.018   | 0.021   | 0.018   | 0.016   | 0.023              |
| 4  | 0.019    | 0.019   | 0.018   | 0.018   | 0.018   | 0.018   | 0.019              |
| 5  | 0.016    | 0.018   | 0.018   | 0.016   | 0.016   | 0.018   | 0.018              |
| 6  | 0.019    | 0.019   | 0.019   | 0.019   | 0.018   | 0.018   | 0.019              |
| 7  | 0.016    | 0.018   | 0.016   | 0.019   | 0.012   | 0.012   | 0.019              |
| 8  | 0.016    | 0.016   | 0.012   | 0.014   | 0.012   | 0.012   | 0.016              |
| 9  | 0.012    | 0.014   | 0.012   | 0.014   | 0.012   | 0.012   | 0.014              |
| 10   | 0.012    | 0.014   | 0.014   | 0.014   | 0.014   | 0.012   | 0.014              |
| 11   | 0.106    | 0.012   | 0.012   | 0.012   | 0.012   | 0.012   | 0.106              |
| 12   | 0.012    | 0.012   | 0.014   | 0.014   | 0.014   | 0.016   | 0.016              |
| 13   | Offline  | Offline | Offline | Offline | Offline | Offline | Offline            |
| 14   | Offline  | Offline | Offline | Offline | Offline | Offline | Offline            |
| 15   | 0.028    | 0.030   | 0.030   | 0.012   | 0.012   | 0.014   | 0.030              |
| 16   | 0.012    | 0.014   | 0.012   | 0.016   | 0.012   | 0.012   | 0.016              |
| 17   | 0.014    | 0.012   | 0.012   | 0.012   | 0.012   | 0.014   | 0.014              |
| 18   | 0.012    | 0.014   | 0.014   | 0.053   | 0.012   | 0.012   | 0.053              |
| 19   | 0.014    | 0.016   | 0.018   | 0.014   | 0.011   | 0.014   | 0.018              |
| 20   | 0.014    | 0.012   | 0.012   | 0.014   | 0.012   | 0.014   | 0.014              |
| 21   | 0.012    | 0.012   | 0.011   | 0.012   | 0.014   | 0.012   | 0.014              |
| 22   | 0.012    | 0.012   | 0.011   | 0.012   | 0.012   | 0.012   | 0.014              |
| 23   | 0.012    | 0.011   | 0.014   | 0.011   | 0.012   | 0.012   | 0.014              |
| 24   | 0.014    | 0.012   | 0.012   | 0.021   | 0.011   | 0.012   | 0.014              |
| 25   | 0.012    | 0.014   | 0.012   | 0.011   | 0.012   | 0.014   | 0.014              |
| 26   | 0.018    | 0.012   | 0.011   | 0.012   | 0.011   | 0.012   | 0.018              |
| 27   | 0.012    | 0.012   | 0.012   | 0.014   | 0.014   | 0.011   | 0.014              |
| 28   | 0.012    | 0.014   | 0.011   | 0.012   | 0.011   | 0.014   | 0.014              |
| 29   | 0.012    | 0.012   | 0.012   | 0.014   | 0.011   | 0.009   | 0.014              |
| 30   | 0.011    | 0.012   | 0.012   | 0.012   | 0.012   | 0.014   | 0.014              |
| 31   | 0.014    | 0.014   | 0.012   | 0.014   | 0.019   | 0.025   | 0.025              |

|   |           |  |  |
|---|-----------|--|--|
| 95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No | All daily | CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No                       | All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No |
| turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No              |           |  |  |
| Notes:  |           | Printed Name: Leonard Whiteman T-09364   |  |
|   |           | Signature  |  |
|   |           | Phone # 503-965-6636   |  |

OHA - Drinking Water Program - Surface Quality Data Form

| System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 08/2022 |  |                 |           |         |         |                |          |                                  |
|---|--|-----------------|-----------|---------|---------|----------------|----------|----------------------------------|
| Day   | Minimum<br>CL2 residual<br>at 1st User<br>C3 | Contact<br>Time | Actual CT | Temp    | pH      | Required<br>CT | CT Met?  | Peak<br>Hourly<br>Demand<br>Flow |
|   | [ppm or<br>mg/l]                             | Minutes         |           | deg C   |         | Use<br>Tables  | Yes / No | GPM                              |
| 1   | 1.40   | 36.0            | 50.40     | 15.04   | 6.93    | 13.9           | YES      | 700                              |
| 2   | 1.39   | 36.0            | 50.04     | 15.50   | 6.97    | 13.6           | YES      | 700                              |
| 3   | 1.27   | 36.0            | 45.72     | 16.25   | 6.91    | 12.5           | YES      | 700                              |
| 4   | 1.36   | 36.0            | 48.96     | 15.21   | 6.88    | 13.4           | YES      | 700                              |
| 5   | 1.55   | 36.0            | 55.80     | 15.16   | 6.92    | 13.9           | YES      | 700                              |
| 6   | 1.46   | 36.0            | 52.56     | 14.96   | 6.91    | 13.9           | YES      | 700                              |
| 7   | 1.43   | 36.0            | 51.48     | 15.60   | 6.91    | 13.3           | YES      | 700                              |
| 8   | 1.42   | 36.0            | 51.12     | 14.77   | 6.93    | 14.1           | YES      | 700                              |
| 9   | 1.39   | 36.0            | 50.04     | 14.46   | 6.92    | 14.3           | YES      | 700                              |
| 10  | 1.36   | 36.0            | 48.96     | 15.11   | 6.91    | 13.6           | YES      | 700                              |
| 11  | 1.45   | 36.0            | 52.20     | 14.60   | 6.90    | 14.2           | YES      | 700                              |
| 12  | 1.34   | 36.0            | 48.24     | 16.36   | 6.89    | 12.4           | YES      | 700                              |
| 13  | Offline                                      | Offline         | Offline   | Offline | Offline | Offline        | Offline  | Offline                          |
| 14  | Offline                                      | Offline         | Offline   | Offline | Offline | Offline        | Offline  | Offline                          |
| 15  | 1.21   | 36.0            | 43.56     | 17.68   | 6.87    | 11.1           | YES      | 700                              |
| 16  | 1.33   | 36.0            | 47.88     | 16.14   | 6.87    | 12.5           | YES      | 700                              |
| 17  | 1.39   | 36.0            | 50.04     | 15.74   | 6.87    | 12.9           | YES      | 700                              |
| 18  | 1.35   | 36.0            | 48.60     | 16.33   | 6.88    | 12.4           | YES      | 700                              |
| 19  | 1.38   | 36.0            | 49.68     | 15.85   | 6.88    | 12.8           | YES      | 700                              |
| 20  | 1.51   | 36.0            | 54.36     | 15.53   | 6.85    | 13.2           | YES      | 700                              |
| 21  | 1.50   | 36.0            | 54.00     | 15.85   | 6.88    | 13.0           | YES      | 700                              |
| 22  | 1.41   | 36.0            | 50.76     | 16.62   | 6.88    | 12.2           | YES      | 700                              |
| 23  | 1.41   | 36.0            | 50.76     | 16.13   | 6.88    | 12.7           | YES      | 700                              |
| 24  | 1.40   | 36.0            | 50.40     | 15.94   | 6.85    | 12.7           | YES      | 700                              |
| 25  | 1.35   | 36.0            | 48.60     | 16.18   | 6.88    | 12.5           | YES      | 700                              |
| 26  | 1.44   | 36.0            | 51.84     | 15.81   | 6.92    | 13.2           | YES      | 700                              |
| 27  | 1.48   | 36.0            | 53.28     | 15.44   | 6.93    | 13.6           | YES      | 700                              |
| 28  | 1.48   | 36.0            | 53.28     | 16.16   | 6.91    | 12.9           | YES      | 700                              |
| 29  | 1.39   | 36.0            | 50.04     | 16.37   | 6.88    | 12.4           | YES      | 700                              |
| 30  | 1.48   | 36.0            | 53.28     | 15.33   | 6.90    | 13.6           | YES      | 700                              |
| 31  | 1.39   | 36.0            | 50.04     | 18.87   | 6.90    | 10.6           | YES      | 700                              |