



OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
 Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year: 06/2023							
Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.012	0.014	0.012	0.012	0.012	0.016
2	0.012	0.012	0.012	0.012	0.012	0.014	0.014
3	0.012	0.016	0.011	0.012	0.012	0.012	0.016
4	0.012	0.014	0.012	0.012	0.012	0.012	0.014
5	0.012	0.014	0.012	0.012	0.012	0.011	0.014
6	0.012	0.012	0.012	0.014	0.014	0.012	0.014
7	0.012	0.012	0.012	0.014	0.018	0.016	0.018
8	0.016	0.016	0.018	0.018	0.018	0.019	0.019
9	0.018	0.019	0.016	0.018	0.014	0.016	0.019
10	0.014	0.014	0.016	0.012	0.014	0.012	0.016
11	0.012	0.012	0.012	0.012	0.012	0.012	0.012
12	0.012	0.014	0.012	0.012	0.012	0.012	0.014
13	0.014	0.014	0.012	0.011	0.014	0.012	0.014
14	0.012	0.012	0.012	0.011	0.014	0.012	0.014
15	0.014	0.014	0.012	0.012	0.014	0.012	0.014
16	0.014	0.016	0.012	0.012	0.012	0.019	0.019
17	0.014	0.018	0.014	0.014	0.011	0.012	0.018
18	0.016	0.014	0.012	0.012	0.012	0.012	0.016
19	0.014	0.014	0.012	0.012	0.012	0.014	0.014
20	0.014	0.012	0.012	0.012	0.012	0.014	0.014
21	0.012	0.012	0.012	0.014	0.012	0.012	0.014
22	0.012	0.016	0.016	0.012	0.011	0.012	0.016
23	0.012	0.012	0.014	0.012	0.012	0.012	0.014
24	0.014	0.012	0.014	0.012	0.012	0.012	0.014
25	0.014	0.014	0.012	0.012	0.014	0.012	0.014
26	0.014	0.014	0.012	0.019	0.011	0.014	0.019
27	0.012	0.011	0.012	0.012	0.011	0.012	0.012
28	0.016	0.012	0.014	0.012	0.012	0.012	0.014
29	0.012	0.014	0.012	0.012	0.012	0.012	0.014
30	0.012	0.012	0.011	0.016	0.014	0.014	0.016
95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No				All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No	
Notes:				Printed Name: Leonard Whiteman T-09364  Signature  Phone # 503-965-6636			

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year 06/2023								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT Use Tables	CT Met?	Peak Hourly Demand Flow
		Minutes		deg C		Yes / No		
	[ppm or mg/l]							GPM
1	1.55	36.0	55.80	12.69	6.78	15.6	YES	700
2	1.55	36.0	55.80	12.75	6.81	15.7	YES	700
3	1.65	36.0	59.40	13.21	6.80	15.3	YES	700
4	1.59	36.0	57.24	13.26	6.81	15.2	YES	700
5	1.64	36.0	59.04	13.58	6.79	14.9	YES	700
6	1.65	36.0	59.40	13.13	6.72	15.0	YES	700
7	1.57	36.0	56.52	14.14	6.80	14.3	YES	700
8	1.53	36.0	55.08	13.33	6.82	15.1	YES	700
9	1.56	36.0	56.16	13.23	6.79	15.1	YES	700
10	1.65	36.0	59.40	13.31	6.77	15.1	YES	700
11	1.60	36.0	57.60	14.70	6.79	13.8	YES	700
12	1.58	36.0	56.88	14.51	6.83	14.1	YES	700
13	1.56	36.0	56.16	14.51	6.81	14.0	YES	700
14	1.52	36.0	54.72	13.60	6.82	14.8	YES	700
15	1.57	36.0	56.52	13.53	6.80	14.9	YES	700
16	1.61	36.0	57.96	13.80	6.80	14.7	YES	700
17	1.67	36.0	60.12	13.67	6.84	15.1	YES	700
18	1.66	36.0	59.76	13.38	6.83	15.4	YES	700
19	1.42	36.0	51.12	12.60	6.81	15.6	YES	700
20	1.53	36.0	55.08	13.65	6.85	15.0	YES	700
21	1.56	36.0	56.16	13.62	6.83	14.9	YES	700
22	1.55	36.0	55.80	15.80	6.74	12.5	YES	700
23	1.54	36.0	55.44	13.69	6.76	14.5	YES	700
24	1.56	36.0	56.16	14.62	6.88	14.2	YES	700
25	1.51	36.0	54.36	14.67	6.86	14.0	YES	700
26	1.46	36.0	52.56	15.34	6.88	13.4	YES	700
27	1.49	36.0	53.64	14.80	6.84	13.8	YES	700
28	1.45	36.0	52.20	15.53	6.85	13.1	YES	700
29	1.48	36.0	53.28	15.64	6.85	13.0	YES	700
30	1.50	36.0	54.00	15.78	6.82	12.8	YES	700