

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year: 07/2023							
Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.014	0.018	0.014	0.014	0.014	0.016	0.018
2	0.014	0.018	0.014	0.014	0.014	0.012	0.018
3	0.014	0.016	0.016	0.016	0.014	0.016	0.016
4	0.014	0.019	0.012	0.012	0.016	0.014	0.019
5	0.012	0.014	0.014	0.014	0.014	0.014	0.014
6	0.014	0.012	0.014	0.014	0.014	0.016	0.016
7	0.014	0.014	0.014	0.021	0.014	0.014	0.021
8	0.012	0.014	0.016	0.014	0.014	0.012	0.016
9	0.014	0.014	0.016	0.014	0.016	0.014	0.016
10	0.012	0.014	0.014	0.014	0.014	0.014	0.014
11	0.014	0.016	0.012	0.012	0.014	0.014	0.016
12	0.014	0.012	0.014	0.014	0.014	0.012	0.014
13	0.012	0.014	0.014	0.016	0.014	0.014	0.016
14	0.014	0.016	0.014	0.012	0.014	0.014	0.016
15	0.014	0.014	0.012	0.016	0.014	0.014	0.016
16	0.012	0.014	0.014	0.014	0.014	0.014	0.014
17	0.012	0.014	0.014	0.012	0.018	0.014	0.018
18	0.016	0.016	0.014	0.016	0.014	0.014	0.016
19	0.016	0.014	0.014	0.014	0.018	0.014	0.018
20	0.014	0.014	0.014	0.014	0.014	0.012	0.014
21	0.016	0.014	0.016	0.014	0.014	0.012	0.016
22	0.018	0.014	0.014	0.014	0.016	0.016	0.018
23	0.016	0.014	0.014	0.014	0.014	0.014	0.016
24	0.016	0.014	0.012	0.014	0.014	0.014	0.016
25	0.016	0.014	0.016	0.018	0.016	0.014	0.018
26	0.014	0.014	0.014	0.016	0.014	0.016	0.016
27	0.016	0.018	0.014	0.014	0.014	0.014	0.018
28	0.012	0.016	0.014	0.012	0.014	0.014	0.016
29	0.014	0.014	0.016	0.012	0.014	0.014	0.016
30	0.014	0.014	0.014	0.014	0.012	0.014	0.014
31	0.014	0.014	0.012	0.014	0.014	0.014	0.014

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? <u>Yes/No</u>	All daily	CT's met everyday? (see back) <u>Yes/No</u>	All Cl2 residual at entry point 0.2 mg/l? <u>Yes/No</u>
Notes:		Printed Name: Leonard Whiteman T-09364	
		Signature <u>Leonard Whiteman</u>	
		Phone # 503-965-6636	

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year 07/2023								
Day	Minimum CL2 residual at 1st User C3	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.45	36.0	52.20	15.23	6.82	13.2	YES	700
2	1.43	36.0	51.48	14.92	6.79	13.3	YES	700
3	1.49	36.0	53.64	14.83	6.78	13.4	YES	700
4	1.53	36.0	55.08	14.88	6.78	13.4	YES	700
5	1.53	36.0	55.08	16.01	6.81	12.6	YES	700
6	1.44	36.0	51.84	15.11	6.81	13.2	YES	700
7	1.45	36.0	52.20	15.36	6.82	13.1	YES	700
8	1.52	36.0	54.72	14.98	6.80	13.4	YES	700
9	1.45	36.0	52.20	15.77	6.85	12.9	YES	700
10	1.42	36.0	51.12	16.27	6.83	12.3	YES	700
11	1.39	36.0	50.04	16.58	6.79	11.8	YES	700
12	1.36	36.0	48.96	16.01	6.79	12.3	YES	700
13	1.31	36.0	47.16	17.08	6.74	11.1	YES	700
14	1.45	36.0	52.20	16.17	6.73	12.0	YES	700
15	1.44	36.0	51.84	16.42	6.76	11.9	YES	700
16	1.43	36.0	51.48	16.10	6.79	12.3	YES	700
17	1.34	36.0	48.24	16.71	6.53	10.6	YES	700
18	1.43	36.0	51.48	16.03	6.77	12.3	YES	700
19	1.41	36.0	50.76	16.10	6.75	12.1	YES	700
20	1.40	36.0	50.40	16.29	6.80	12.1	YES	700
21	1.40	36.0	50.40	16.99	6.79	11.5	YES	700
22	1.47	36.0	52.92	16.70	6.71	11.5	YES	700
23	1.41	36.0	50.76	16.32	6.73	11.8	YES	700
24	1.39	36.0	50.04	15.86	6.75	12.2	YES	700
25	1.22	36.0	43.92	16.52	6.69	11.2	YES	700
26	1.30	36.0	46.80	16.05	6.76	12.0	YES	700
27	1.39	36.0	50.04	16.07	6.81	12.3	YES	700
28	1.45	36.0	52.20	16.00	6.78	12.4	YES	700
29	1.47	36.0	52.92	16.04	6.78	12.3	YES	700
30	1.45	36.0	52.20	15.68	6.79	12.7	YES	700
31	1.44	36.0	51.84	16.23	6.82	12.3	YES	700