


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 08/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.014	0.016	0.014	0.014	0.012	0.016	0.016
2	0.014	0.014	0.014	0.016	0.016	0.014	0.016
3	0.014	0.014	0.016	0.014	0.014	0.014	0.016
4	0.016	0.014	0.014	0.016	0.016	0.014	0.016
5	0.014	0.014	0.012	0.014	0.018	0.014	0.018
6	0.016	0.014	0.016	0.016	0.019	0.014	0.019
7	0.012	0.014	0.014	0.014	0.014	0.014	0.014
8	0.016	0.016	0.014	0.016	0.021	0.019	0.021
9	0.018	0.021	0.023	0.014	0.014	0.014	0.023
10	0.014	0.016	0.016	0.012	0.014	0.014	0.016
11	0.014	0.014	0.014	0.014	0.014	0.012	0.014
12	0.014	0.014	0.016	0.014	0.016	0.014	0.016
13	0.014	0.016	0.016	0.014	0.016	0.012	0.016
14	0.016	0.016	0.014	0.014	0.014	0.016	0.016
15	0.016	0.014	0.016	0.016	0.014	0.014	0.016
16	0.012	0.014	0.016	0.016	0.014	0.014	0.016
17	0.014	0.016	0.014	0.016	0.014	0.016	0.016
18	0.016	0.016	0.014	0.014	0.014	0.016	0.016
19	0.014	0.016	0.014	0.016	0.016	0.014	0.016
20	0.016	0.023	0.016	0.014	0.016	0.014	0.023
21	0.014	0.016	0.014	0.012	0.027	0.016	0.027
22	0.016	0.016	0.016	0.016	0.014	0.016	0.016
23	0.016	0.018	0.018	0.018	0.018	0.018	0.018
24	0.016	0.016	0.016	0.014	0.014	0.014	0.016
25	0.014	0.016	0.014	0.016	0.019	0.014	0.019
26	0.016	0.016	0.014	0.016	0.016	0.014	0.016
27	0.016	0.016	0.016	0.016	0.016	0.016	0.016
28	0.016	0.018	0.016	0.016	0.019	0.016	0.019
29	0.019	0.019	0.019	0.019	0.019	0.019	0.019
30	0.019	0.019	0.019	0.019	0.019	0.018	0.019
31	Offline	Offline	Offline	Offline	Offline	Offline	Offline

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---	-----------	--------------------------------------	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

