

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 09/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.023	0.023	0.025	0.021	0.016	0.018	0.025
2	0.018	0.018	0.018	0.014	0.014	0.014	0.018
3	0.014	0.014	0.014	0.012	0.014	0.016	0.016
4	0.014	0.016	0.018	0.014	0.014	0.012	0.018
5	0.014	0.016	0.014	0.014	0.014	0.014	0.016
6	0.014	0.016	0.012	0.014	0.014	0.012	0.016
7	0.014	0.018	0.016	0.014	0.016	0.014	0.018
8	0.014	0.014	0.014	0.014	0.016	0.016	0.016
9	0.014	0.016	0.014	0.021	0.012	0.012	0.021
10	0.014	0.016	0.014	0.012	0.012	0.014	0.016
11	0.014	0.014	0.016	0.014	0.016	0.014	0.016
12	0.016	0.016	0.012	0.014	0.016	0.016	0.016
13	0.014	0.016	0.016	0.016	0.016	0.014	0.016
14	0.014	0.018	0.014	0.012	0.014	0.014	0.018
15	0.014	0.014	0.014	0.016	0.014	0.014	0.016
16	0.016	0.016	0.014	0.014	0.014	0.014	0.016
17	0.018	0.016	0.016	0.016	0.014	0.016	0.018
18	0.014	0.014	0.014	0.016	0.014	0.014	0.016
19	0.018	0.016	0.014	0.014	0.016	0.014	0.018
20	0.016	0.014	0.014	0.016	0.018	0.014	0.018
21	0.014	0.016	0.016	0.016	0.016	0.016	0.016
22	0.016	0.016	0.016	0.014	0.016	0.016	0.016
23	0.016	0.016	0.016	0.014	0.014	0.016	0.016
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	0.025	0.027	0.028	0.016	0.016	0.014	0.028
28	0.016	0.014	0.016	0.016	0.016	0.016	0.016
29	0.014	0.014	0.014	0.016	0.014	0.014	0.016
30	0.014	0.014	0.012	0.014	0.014	0.018	0.018

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	Yes/No <i>Yes</i>	All daily	CT's met everyday? (see back) Yes/No	Yes/No <i>Yes</i>	All Cl2 residual at entry point 0.2 mg/l? Yes/No	Yes/No <i>Yes</i>
---	-------------------	-----------	--------------------------------------	-------------------	--	-------------------

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature <i>Leonard Whiteman</i>
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP--C Month/Year 09/2023								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	1.20	36.0	43.20	17.63	6.80	10.8	YES	700
2	1.25	36.0	45.00	16.62	6.75	11.5	YES	700
3	1.31	36.0	47.16	16.12	6.81	12.2	YES	700
4	1.19	36.0	42.84	15.88	6.77	12.0	YES	700
5	1.17	36.0	42.12	15.52	6.82	12.5	YES	700
6	1.41	36.0	50.76	14.40	6.83	13.9	YES	700
7	1.48	36.0	53.28	15.16	6.83	13.4	YES	700
8	1.42	36.0	51.12	14.88	6.81	13.4	YES	700
9	1.41	36.0	50.76	15.01	6.81	13.3	YES	700
10	1.34	36.0	48.24	15.54	6.80	12.7	YES	700
11	1.31	36.0	47.16	15.63	6.84	12.7	YES	700
12	1.37	36.0	49.32	14.56	6.82	13.7	YES	700
13	1.34	36.0	48.24	15.54	6.81	12.7	YES	700
14	1.39	36.0	50.04	15.36	6.77	12.8	YES	700
15	1.33	36.0	47.88	15.86	6.80	12.4	YES	700
16	1.29	36.0	46.44	14.97	6.79	13.0	YES	700
17	1.24	36.0	44.64	14.34	6.82	13.7	YES	700
18	1.25	36.0	45.00	14.85	6.79	13.1	YES	700
19	1.19	36.0	42.84	14.32	6.77	13.4	YES	700
20	1.23	36.0	44.28	14.56	6.79	13.3	YES	700
21	1.13	36.0	40.68	14.44	6.78	13.2	YES	700
22	1.29	36.0	46.44	13.94	6.81	14.1	YES	700
23	1.29	36.0	46.44	14.15	6.76	13.6	YES	700
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	1.49	36.0	53.64	15.69	6.88	13.2	YES	700
28	1.14	36.0	41.04	14.50	6.75	13.0	YES	700
29	1.35	36.0	48.60	14.27	6.80	13.8	YES	700
30	1.17	36.0	42.12	13.74	6.79	14.0	YES	700