


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 10/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.014	0.012	0.016	0.016	0.014	0.016
2	0.016	0.014	0.012	0.014	0.014	0.014	0.016
3	0.016	0.014	0.014	0.016	0.012	0.014	0.016
4	0.012	0.016	0.014	0.012	0.016	0.014	0.016
5	0.016	0.014	0.016	0.014	0.068	0.019	0.068
6	0.021	0.019	0.019	0.018	0.018	0.019	0.021
7	0.018	0.019	0.016	0.019	0.018	0.018	0.019
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	0.019	0.019	0.018	0.018	0.018	0.021	0.021
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	0.023	0.019	0.023	0.018	0.016	0.016	0.023
18	0.018	0.019	0.018	0.019	0.018	0.019	0.019
19	0.019	0.018	0.019	0.018	0.019	0.019	0.019
20	0.019	0.016	0.018	0.019	0.018	0.018	0.019
21	0.018	0.021	0.018	0.019	0.018	0.019	0.021
22	0.019	0.018	0.023	0.019	0.016	0.018	0.023
23	0.019	0.019	0.019	0.019	0.019	0.019	0.019
24	0.019	0.018	0.018	0.019	0.023	0.019	0.023
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	0.021	0.019	0.021	0.018	0.019	0.019	0.021
31	0.018	0.019	0.019	0.018	0.018	0.018	0.019

95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="radio"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/No
---	-----------	---	---

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 10/2023								
Day	Minimum CL2 residual at 1st User C3	Contact Time	Actual CT	Temp	pH	Required CT	CT Met?	Peak Hourly Demand Flow
	[ppm or mg/l]	Minutes		deg C		Use Tables	Yes / No	GPM
1	1.38	36.0	49.68	13.10	6.78	14.9	YES	700
2	1.56	36.0	56.16	13.23	6.84	15.4	YES	700
3	1.02	36.0	36.72	14.17	6.77	13.2	YES	700
4	1.39	36.0	50.04	13.87	6.85	14.5	YES	700
5	1.70	36.0	61.20	14.55	6.87	14.5	YES	700
6	1.59	36.0	57.24	15.84	6.77	12.6	YES	700
7	1.33	36.0	47.88	15.56	6.74	12.4	YES	700
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	1.79	36.0	64.44	13.47	6.87	15.7	YES	700
14	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
15	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	1.15	36.0	41.40	15.16	6.82	12.8	YES	700
18	1.26	36.0	45.36	13.86	6.79	14.0	YES	700
19	1.47	36.0	52.92	13.57	6.84	14.9	YES	700
20	1.45	36.0	52.20	13.98	6.79	14.2	YES	700
21	1.36	36.0	48.96	13.79	6.76	14.1	YES	700
22	1.41	36.0	50.76	14.28	6.83	14.1	YES	700
23	1.36	36.0	48.96	13.62	6.82	14.6	YES	700
24	1.45	36.0	52.20	12.44	6.80	16.2	YES	700
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	1.10	36.0	39.60	11.20	6.87	17.3	YES	700
31	1.39	36.0	50.04	10.90	6.90	18.4	YES	700