

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**


System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP:-C Month/Year: 11/2023

| Day | 12:00 AM | 4:00 AM | 8:00 AM | NOON | 4PM | 8:00 PM | Highest Reading of |
|-----|----------|---------|---------|---------|---------|---------|--------------------|
| 1 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 2 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 3 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 4 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 5 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 6 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 7 | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 8 | 0.023 | 0.023 | 0.023 | 0.019 | 0.018 | 0.018 | 0.023 |
| 9 | 0.019 | 0.021 | 0.018 | 0.116 | 0.019 | 0.019 | 0.116 |
| 10 | 0.019 | 0.019 | 0.019 | 0.018 | 0.018 | 0.018 | 0.019 |
| 11 | 0.019 | 0.018 | 0.019 | 0.021 | 0.018 | 0.018 | 0.021 |
| 12 | 0.019 | 0.018 | 0.019 | 0.023 | 0.018 | 0.021 | 0.023 |
| 13 | 0.019 | 0.018 | 0.019 | 0.019 | 0.019 | 0.019 | 0.019 |
| 14 | 0.018 | 0.021 | 0.019 | 0.021 | 0.021 | 0.019 | 0.021 |
| 15 | 0.018 | 0.021 | 0.018 | 0.019 | 0.019 | 0.019 | 0.021 |
| 16 | 0.019 | 0.019 | 0.018 | 0.019 | 0.019 | 0.019 | 0.019 |
| 17 | 0.019 | 0.019 | 0.019 | 0.021 | 0.021 | 0.018 | 0.021 |
| 18 | 0.019 | 0.019 | 0.019 | 0.019 | 0.018 | 0.019 | 0.019 |
| 19 | 0.019 | 0.019 | 0.018 | 0.018 | 0.018 | 0.018 | 0.019 |
| 20 | 0.019 | 0.018 | 0.019 | 0.019 | 0.018 | 0.019 | 0.019 |
| 21 | 0.019 | 0.019 | 0.018 | 0.019 | 0.019 | 0.019 | 0.019 |
| 22 | 0.019 | 0.021 | 0.021 | 0.019 | 0.018 | 0.018 | 0.021 |
| 23 | 0.019 | 0.018 | 0.018 | 0.019 | 0.019 | 0.019 | 0.019 |
| 24 | 0.021 | 0.019 | 0.021 | 0.018 | 0.019 | 0.019 | 0.021 |
| 25 | 0.019 | 0.019 | 0.018 | 0.019 | 0.019 | 0.019 | 0.019 |
| 26 | 0.019 | 0.019 | 0.019 | 0.019 | 0.023 | 0.019 | 0.023 |
| 27 | 0.019 | 0.019 | 0.019 | 0.021 | 0.019 | 0.019 | 0.021 |
| 28 | 0.019 | 0.023 | 0.019 | 0.019 | 0.018 | 0.019 | 0.023 |
| 29 | 0.019 | 0.019 | 0.019 | 0.019 | 0.021 | 0.021 | 0.021 |
| 30 | 0.019 | 0.019 | 0.019 | 0.019 | 0.021 | 0.019 | 0.021 |

| | | | |
|---|-----------|--|--|
| 95% of daily turbidity readings < 1 NTU? <input checked="" type="radio"/> Yes/ <input type="radio"/> No | All daily | CT's met everyday? (see back) <input checked="" type="radio"/> Yes/ <input type="radio"/> No | All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="radio"/> Yes/ <input type="radio"/> No |
| turbidity readings < 5 NTU? <input checked="" type="radio"/> Yes/ <input type="radio"/> No | | | |

Notes:

Printed Name: Leonard Whiteman T-09364

Signature 

Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

| System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year 11/2023 | | | | | | | | |
|---|--|-----------------|-----------|---------|---------|----------------|----------|----------------------------------|
| Day | Minimum CL2 residual at 1st User C3 | Contact Time | Actual CT | Temp | pH | Required CT | CT Met? | Peak Hourly Demand Flow |
| | [ppm or mg/l] | Minutes | | deg C | | Use Tables | Yes / No | GPM |
| 1 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 2 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 3 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 4 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 5 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 6 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 7 | Offline | Offline | Offline | Offline | Offline | Offline | Offline | Offline |
| 8 | 1.22 | 36.0 | 43.92 | 13.06 | 6.80 | 14.8 | YES | 700 |
| 9 | 1.82 | 36.0 | 65.52 | 11.19 | 6.91 | 19.0 | YES | 700 |
| 10 | 1.73 | 36.0 | 62.28 | 10.83 | 6.90 | 19.2 | YES | 700 |
| 11 | 1.71 | 36.0 | 61.56 | 11.46 | 6.86 | 18.1 | YES | 700 |
| 12 | 1.59 | 36.0 | 57.24 | 12.21 | 6.88 | 17.1 | YES | 700 |
| 13 | 1.45 | 36.0 | 52.20 | 11.53 | 6.87 | 17.6 | YES | 700 |
| 14 | 1.75 | 36.0 | 63.00 | 10.36 | 6.85 | 19.5 | YES | 700 |
| 15 | 1.32 | 36.0 | 47.52 | 11.81 | 6.87 | 17.0 | YES | 700 |
| 16 | 1.51 | 36.0 | 54.36 | 11.22 | 6.90 | 18.2 | YES | 700 |
| 17 | 1.94 | 36.0 | 69.84 | 10.98 | 6.92 | 19.6 | YES | 700 |
| 18 | 2.12 | 36.0 | 76.32 | 10.83 | 6.94 | 20.3 | YES | 700 |
| 19 | 1.39 | 36.0 | 50.04 | 11.29 | 6.86 | 17.7 | YES | 700 |
| 20 | 1.59 | 36.0 | 57.24 | 10.17 | 6.90 | 19.7 | YES | 700 |
| 21 | 1.80 | 36.0 | 64.80 | 10.35 | 6.92 | 20.1 | YES | 700 |
| 22 | 1.83 | 36.0 | 65.88 | 11.58 | 6.93 | 18.6 | YES | 700 |
| 23 | 1.67 | 36.0 | 60.12 | 9.58 | 6.91 | 20.7 | YES | 700 |
| 24 | 1.81 | 36.0 | 65.16 | 8.67 | 6.94 | 22.6 | YES | 700 |
| 25 | 1.97 | 36.0 | 70.92 | 8.40 | 7.02 | 24.1 | YES | 700 |
| 26 | 1.83 | 36.0 | 65.88 | 8.10 | 6.99 | 23.9 | YES | 700 |
| 27 | 1.85 | 36.0 | 66.60 | 9.02 | 7.04 | 23.0 | YES | 700 |
| 28 | 1.77 | 36.0 | 63.72 | 7.53 | 7.02 | 24.9 | YES | 700 |
| 29 | 1.62 | 36.0 | 58.32 | 9.97 | 6.98 | 20.6 | YES | 700 |
| 30 | 1.70 | 36.0 | 61.20 | 9.01 | 6.94 | 21.8 | YES | 700 |