

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 12/2023

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	0.032	0.032	0.034	0.021	0.019	0.021	0.035
14	0.021	0.019	0.021	0.021	0.021	0.021	0.021
15	0.021	0.019	0.019	0.019	0.023	0.019	0.023
16	0.019	0.019	0.019	0.027	0.019	0.019	0.027
17	0.019	0.019	0.019	0.018	0.019	0.019	0.019
18	0.019	0.019	0.019	0.019	0.021	0.019	0.021
19	0.019	0.019	0.019	0.035	0.019	0.018	0.035
20	0.027	0.021	0.018	0.019	0.019	0.019	0.027
21	0.018	0.019	0.018	0.018	0.018	0.019	0.019
22	0.019	0.021	0.019	0.018	0.021	0.019	0.021
23	0.019	0.021	0.019	0.019	0.021	0.019	0.021
24	0.018	0.021	0.019	0.018	0.019	0.018	0.021
25	0.019	0.018	0.018	0.019	0.019	0.018	0.019
26	0.018	0.019	0.018	0.018	0.019	0.018	0.019
27	0.018	0.018	0.018	0.018	0.018	0.018	0.018
28	0.019	0.019	0.019	0.018	0.019	0.019	0.019
29	0.018	0.018	0.018	0.019	0.019	0.018	0.019
30	0.019	0.019	0.019	0.019	0.019	0.019	0.019
31	0.019	0.019	0.019	0.019	0.016	0.016	0.019

95% of daily turbidity readings < 1 NTU? Yes/No turbidity readings < 5 NTU? Yes/No	All daily	CT's met everyday? (see back) Yes/No	All Cl2 residual at entry point 0.2 mg/l? Yes/No
---------------------------------------------------------------------------------------	-----------	--------------------------------------	--------------------------------------------------

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

OHA - Drinking Water Program - Surface Quality Data Form

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year 12/2023								
Day	Minimum CL2 residual at 1st User C3 [ppm or mg/l]	Contact Time Minutes	Actual CT	Temp deg C	pH	Required CT Use Tables	CT Met? Yes / No	Peak Hourly Demand Flow GPM
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
7	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
8	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	1.16	36.0	41.76	12.24	6.54	14.6	YES	700
14	1.82	36.0	65.52	11.42	6.52	16.4	YES	700
15	1.95	36.0	70.20	11.72	6.61	16.8	YES	700
16	1.73	36.0	62.28	10.84	6.55	17.0	YES	700
17	2.00	36.0	72.00	10.74	6.59	17.8	YES	700
18	1.86	36.0	66.96	11.38	6.60	16.9	YES	700
19	1.64	36.0	59.04	11.12	6.60	16.8	YES	700
20	1.64	36.0	59.04	10.61	6.54	17.0	YES	700
21	1.62	36.0	58.32	10.83	6.30	15.4	YES	700
22	1.76	36.0	63.36	10.91	6.59	17.2	YES	700
23	1.68	36.0	60.48	9.69	6.57	18.3	YES	700
24	1.87	36.0	67.32	10.11	6.63	18.6	YES	700
25	1.82	36.0	65.52	10.33	6.64	18.3	YES	700
26	1.38	36.0	49.68	11.06	6.55	16.1	YES	700
27	1.49	36.0	53.64	11.22	6.57	16.3	YES	700
28	1.74	36.0	62.64	10.80	6.59	17.3	YES	700
29	1.60	36.0	57.60	12.06	6.65	16.0	YES	700
30	1.56	36.0	56.16	11.33	6.61	16.5	YES	700
31	1.35	36.0	48.60	10.85	6.59	16.5	YES	700