


**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-:C Month/Year: 01/2024

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	0.016	0.018	0.018	0.016	0.018	0.016	0.018
2	0.018	0.016	0.018	0.018	0.018	0.018	0.018
3	0.019	0.018	0.019	0.016	0.016	0.016	0.019
4	0.016	0.018	0.019	0.014	0.016	0.014	0.019
5	0.016	0.016	0.014	0.012	0.014	0.014	0.016
6	0.016	0.014	0.014	0.014	0.016	0.016	0.016
7	0.014	0.014	0.014	0.016	0.014	0.014	0.016
8	0.014	0.014	0.016	0.014	0.014	0.014	0.016
9	Offline	Offline	Offline	Offline	Offline	Offline	Offline
10	Offline	Offline	Offline	Offline	Offline	Offline	Offline
11	Offline	Offline	Offline	Offline	Offline	Offline	Offline
12	Offline	Offline	Offline	Offline	Offline	Offline	Offline
13	Offline	Offline	Offline	Offline	Offline	Offline	Offline
14	0.018	0.016	0.016	0.018	0.014	0.018	0.018
15	0.018	0.016	0.018	0.014	0.016	0.014	0.018
16	Offline	Offline	Offline	Offline	Offline	Offline	Offline
17	Offline	Offline	Offline	Offline	Offline	Offline	Offline
18	Offline	Offline	Offline	Offline	Offline	Offline	Offline
19	Offline	Offline	Offline	Offline	Offline	Offline	Offline
20	0.016	0.016	0.019	0.016	0.016	0.018	0.019
21	0.016	0.018	0.016	0.016	0.016	0.016	0.018
22	Offline	Offline	Offline	Offline	Offline	Offline	Offline
23	Offline	Offline	Offline	Offline	Offline	Offline	Offline
24	Offline	Offline	Offline	Offline	Offline	Offline	Offline
25	Offline	Offline	Offline	Offline	Offline	Offline	Offline
26	Offline	Offline	Offline	Offline	Offline	Offline	Offline
27	Offline	Offline	Offline	Offline	Offline	Offline	Offline
28	Offline	Offline	Offline	Offline	Offline	Offline	Offline
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline
30	Offline	Offline	Offline	Offline	Offline	Offline	Offline
31	Offline	Offline	Offline	Offline	Offline	Offline	Offline

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
---	-----------	--	--

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

