

**OHA - Drinking Water Program - Turbidity Monitoring Report Form County: Tillamook  
Slow Sand, Membrane, Diatomaceous Earth Filtration, or Unfiltered Systems**

System Name: Pacific City Joint Water-Sanitary Authority ID#: 4100609 WTP-C Month/Year: 02/2024

Day	12:00 AM	4:00 AM	8:00 AM	NOON	4PM	8:00 PM	Highest Reading of
1	Offline	Offline	Offline	Offline	Offline	Offline	Offline
2	Offline	Offline	Offline	Offline	Offline	Offline	Offline
3	Offline	Offline	Offline	Offline	Offline	Offline	Offline
4	Offline	Offline	Offline	Offline	Offline	Offline	Offline
5	Offline	Offline	Offline	Offline	Offline	Offline	Offline
6	0.019	0.021	0.021	0.014	0.016	0.016	0.021
7	0.016	0.014	0.014	0.037	0.018	0.019	0.037
8	0.028	0.018	0.021	0.034	0.019	0.019	0.034
9	0.019	0.023	0.018	0.016	0.016	0.014	0.023
10	0.014	0.016	0.014	0.014	0.014	0.014	0.016
11	0.016	0.016	0.014	0.016	0.016	0.016	0.016
12	0.014	0.014	0.016	0.014	0.014	0.016	0.016
13	0.018	0.019	0.019	0.014	0.014	0.014	0.019
14	0.014	0.016	0.014	0.014	0.016	0.018	0.018
15	0.018	0.018	0.019	0.014	0.014	0.014	0.019
16	0.014	0.014	0.014	0.016	0.014	0.014	0.016
17	0.014	0.014	0.014	0.014	0.014	0.014	0.014
18	0.014	0.014	0.014	0.014	0.014	0.014	0.014
19	0.014	0.016	0.014	0.014	0.014	0.014	0.016
20	0.014	0.014	0.014	0.016	0.018	0.018	0.018
21	0.016	0.014	0.016	0.016	0.014	0.014	0.016
22	0.014	0.014	0.016	0.014	0.014	0.014	0.016
23	0.012	0.014	0.016	0.016	0.014	0.016	0.016
24	0.014	0.016	0.014	0.016	0.016	0.014	0.016
25	0.016	0.016	0.014	0.014	0.016	0.014	0.016
26	0.016	0.014	0.014	0.014	0.014	0.014	0.016
27	0.014	0.016	0.014	0.014	0.014	0.016	0.016
28	0.016	0.014	0.014	0.014	0.016	0.016	0.016
29	Offline	Offline	Offline	Offline	Offline	Offline	Offline

95% of daily turbidity readings < 1 NTU? <input checked="" type="checkbox"/> Yes/No	All daily	CT's met everyday? (see back) <input checked="" type="checkbox"/> Yes/No	All Cl2 residual at entry point 0.2 mg/l? <input checked="" type="checkbox"/> Yes/No
turbidity readings < 5 NTU? <input checked="" type="checkbox"/> Yes/No			

Notes:	Printed Name: Leonard Whiteman T-09364
	Signature 
	Phone # 503-965-6636

